

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		3		3		3			
6	RR(E)	168	403									
7	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		2		2		2			
3	MDK	107	933		2		2		2			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 19.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Reddygudem	Reddygudem	11kv	Suryapet	15.20	16.40	01.20	EL	Jumper cut	-
2		Palakeedu	Palakeedu	11kv	Huzurnagar	06.30	09.10	02.30	EL	11 kv line snapped at Palakeedu village	-
1	MDK	Shankarampet' R	Kamaram	11kv	Medak	11.10	13.20	02.10		B/D Due to 11 KV Jumper cut.	-
2		Shankarampet	Kolapally	11kv	Medak	09.00	13.10	04.10		B/D Due to Jumper cut at venkatapur thanda	-
1	RR N	Madinaguda	Bk Enclave	11kv	Kukatpally	12.53	13.53	01.00	BD	11kv Breaker ProblemIn sub station	-
2		Kandlakoya	Kandlakoya	11kv	Medchal	13.30	14.50	01.20	BD	11KV Pole damaged by Lorry at Kandlakoya X Road	-
3		Subash Nagar	Suchitra	11kv	Medchal	13.40	14.50	01.10	BD	(11KV AB Cable failed at S Mart)Backfeeding arranged from 11KV Ramraj Nagar feeder	-
1	HYD S	Kandikalgate	Patel Nagar	11kv	Charminar	22.35	00.07	01.32	EL	Cable fault at Railway Bridge	Arranged B/F on 11KV Moinbagh fdr

TSSPDCL - LMRC / Corporate office

Date: 19.03.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	RWS	33kv	Gadwal	16.30	19.00	02.30	E/L	R Phase Insulator Replacement near Genco Guest House	RWS	-