

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		3		3		3			
6	RR(E)	168	403									
7	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		3		3		3			
3	MDK	107	933	1		1		1				
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	1	5	1	5	1	5	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.03.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Sadashivapet	Koheer	33KV	Sangareddy	11:15	15:00	3:45		Jumper cut near Pothireddy pally.	Koheer	No

TSSPDCL - LMRC / Corporate office

Date: 22.03.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Lokirev	11KV	Jadcherla	07.00	09.30	02.30		11KV Wire cut near nawabpet beside	No
2		Ponnakal	Vemula	11KV	Jadcherla	13.30	15.00	01.30		11KV Wire cut near shale thirupathi reddy DTR	No
1	NLG	Kudakuda	Iyalapuram	11KV	Suryapeta	4:30	7:00	2:30	E/L	11KV Conductor snapped	No
2		Repala	V.R.Puram	11KV	Huzumagar	11.00	14.00	03.00	E/L	11 KV Jumper cut	No
3		Arlagaddagudem	Naragudem	11KV	Nalgonda	11.20	02.50	03.30	E/L	11 KV Jumper cut	No
1	RR N	Jeedimetla SS - I	JETL	11KV	Jeedimetla	12:15	13:40	1:25	EL/OL	11KV AB Cable failed at phase - I	No
2		Gowdavelly	Gowdavelly	11KV	Medchal	09.00	10.30	01.30	BD	Tree branches fallen on the 11KV Line at Gowdavelly	No
3		HMT	Qutubullapur	11KV	Medchal	19.00	19.50	00.50	BD	11KV Conductor snapped at Ganesh Nagar	No
1	HYD N	Kalyan Nagar	Vengalrao Nagar	11KV	Banjara Hills	22.37	00.10	01.33	EL,OL-Rph	Cable fault at Drugs Control Board	Partial fdr charged & remaining loads added on 11KV Vishwa Bharathi fdr