

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550	2	1	2	1	2	1			
6	RR(E)	168	403		1		1		1			
7	Hyd	194	1044									
	Total	606	3055	2	2	2	2	2	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	1	2	1	2	1	2	0	0	
	Grand Total	1082	6468	3	4	3	4	3	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thungathurthy	Vempaty	11KV	Suryapet	05.50	08.00	02.10	EL	Insulator failed	-
2		Seethya Thanda	seethya Thanda	11KV	Miryalaguda	05.00	09.00	04.00	EL/OL	11 KV jumper cut	-
1	RR N	Devarayamjal	Kottapet	11KV	Medchal	14.55	16.35	01.40	BD	Tree Fallen on 11KV Line at Rambabu Poultry farm	-
1	RR E	chakripuram	Ayyappa	11KV	Keesara	14.00	14.37	00.37		Pin insulator fail at Dammaiguda	-

TSSPDCL - LMRC / Corporate office

Date: 24.03.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narva	33KV	Mahabubnagar	12.40	14.20	01.40	E/L	Pin Binding Failed at Makthal	Makthal	-
1		Jeedimetla-I	JETL	33KV	Jeedimetla	15.30	16.25	00.55	BD	AB Cable failure at Phase-I .near VIP Foods	Jeedimetla-I	-
2	RR N	Dulapally	Steelcity	33KV	Medchal	15.25	16.21	00.56	BD	Bird fallen on 11KV Line at Jio Tower,IDA Dulapally	Dulapally	-