

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		2		2		2			
6	RR(E)	168	403		2		2		2			
7	Hyd	194	1044		1		1		1			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	2	1	2	1	2			
3	MDK	107	933									
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	2	2	2	2	2	2	0	0	
	Grand Total	1082	6468	2	7	2	7	2	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	SLC Mills	33KV	Mahabubnagar	10.55	14.15	03.20	E/L&O/L	Industrial Internal Fault SLC Mills Industry unit-2 CT Blast.	SLC Mills	-
1	NLG	Miryalguda	Tripuraram	33KV	Miryalguda	13.35	19.00	05.25	E/L	CT problem at 220 KV SS Miryalaguda	Tripuraram	-

TSSPDCL - LMRC / Corporate office

Date: 28.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Velugupally	Keshavapuram	11KV	Suryapet	04.00	06.30	02.30	E/L	11Kv Conductor snapped	-
2		Damarcherla	Damarcherla Agl	11KV	Miryalguda	06.30	11.00	04.30	E/L	11KV Pin Insulator Failed	-
1	RR N	JDMSS-III	Andra polymars	11KV	JDM	16.20	17.25	01.05	EL/OL	11kv line Pin Insulator failure at Near Sub-station	-
2		Medchal	victory (Kurai Kandlakoya)	11KV	Medchal	22.10	22.50	00.40	BD	11KV Pole damaged by Lorry at Ceikon Company	-
1	RR E	Aushapur	Sandupatlaguda	11KV	Keesara	08.15	09.30	01.15		11KV Jumper cut at Edulabad Village	-
2		Narapally	Narapally Indl	11KV	Keesara	14.35	15.45	01.10		11KV Jumper cut at Narapally Main Road	-
1	HYD S	Santosh Nagar	Raja Nagar	11KV	VIII	14.57	16.15	01.18	EL	AB Cable fault at opp.Santosh Nagar FOC	Arranged B/F on 11KV Sravani Hospital fdr