

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		1		1		1			
6	RR(E)	168	403		7		7		7			
7	Hyd	194	1044		5		5		5			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988	3	3	3	3	3	3			
3	MDK	107	933		7		7		7			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>4</b>	<b>11</b>	<b>4</b>	<b>11</b>	<b>4</b>	<b>11</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>4</b>	<b>24</b>	<b>4</b>	<b>24</b>	<b>4</b>	<b>24</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 01.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kankurcxy	33KV	Mahabubnagar	14.40	18.45	04.05	EL	No visible fault due to heavy wind supply stood ok	Kankurcxy	-
1	NLG	K.M.Pally	Angadipeta	33KV	Devarakonda	19.33	20.53	01.20	E/L	Heavy gale and wind	Angadipeta	-
2		K.M.Pally	Water grid	33KV	Devarakonda	19.30	20.40	01.07	E/L	Heavy gale and wind	Water grid	-
3		Suryapeta	Nemmikal	33KV	Suryapeta	17.00	20.10	03.10	E/L	Heavy gale and wind	Nemmikal	-

TSSPDCL - LMRC / Corporate office

Date: 01.05.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Narayanpet	Tellapur	11KV	Mahabubnagar	08.30	12.10	03.40		11KV DTR fault	-
1	NLG	Penpahad	Potlapahad	11KV	Suryapeta	04.30	06.45	02.15	E/L	Bird fallen on the line	-
2		Mamidala	Aregudem	11KV	Nalgonda	02.40	06.00	03.20	E/L	11 KV Line cut	-
3		Nunavath Thanda	Nunavath Thanda	11KV	Miryalaguda	12.30	15.00	02.30	E/L	Insulator failure	-
1	MDK	Jangapally	Jangapally	11KV	Siddipet	14.10	15.25	01.15		Male Female Burning	
2		Badipadaga	Badipadaga	11KV	Siddipet	19.30	21.30	02.00		11KV Wire Cutting	
3		Raghavapur	Raorukula	11KV	Siddipet	11.11	17.30	06.19		HT/LT wire phase to phase	
4		Laxmidevipally	Laxmidevipally	11KV	Siddipet	13.15	14.30	01.15		Transfarmar Problem	
5		HUSNABAD	HUSNABAD TOWN-2	11KV	Siddipet	20.45	21.15	00.30		Line Fault	
6		BEJJANKI	RWS	11KV	Siddipet	09.40	12.40	03.00		Due to Tree Fall	
7		GUGGILLA	GUGILLA	11KV	Siddipet	10.40	10.55	00.15		Tripped on EL No visible fault	
1	RR N	Hudatruckpark	Sangeeth Nagar	11KV	Kukatpally	14.27	15.28	01.01	EL&OL	Plastic Cover Fallon the 11kv line near kukatpally Main Road	-
1	RR E	NAGOLE	NEW NAGOLE	11KV	SAROORNAGAR	17.47	18.51	01.04	EL	BALLI FALL ON DTR AB SWITCH AT NAGOLE ROAD NO 3	-
2		PEDDAMBERPET	TARAMATHIPET	11KV	SAROORNAGAR	09.00	12.10	02.10	EL	NEMALI TOUCHED TO 11KV LINE & 11KV LINE TOUCHED AT PASAMALA	-
3		RAJIVSWAGRU	VISHALANDHRA	11KV	SAROORNAGAR	19.28	20.27	00.59	EL/OL	DTR COPPER PATTI CUT AT VISHALANDHRA	-
4		RAJIVSWAGRU	RAJIVSWAGRU B&C	11KV	SAROORNAGAR	19.28	20.34	01.06	EL/OL	HG FUSE CUT AT C BLOCK	-
5		Moula Ali	Spectra	11KV	Sainikpuri	19.35	20.25	00.50		11Kv line AB Switch opened at IDA Moula ali Due to line patrolling done but no fault found (ADE ASNR)	-
6		Keesara	Bogaram	11KV	Keesara	13.45	17.10	03.25		11kv line twisting at SC colony	-
7		Keesara	Cheryala	11KV	Keesara	20.20	21.10	00.50		11kv insulaotr fail at Vikulagulla colony	-
1	HYD S	E.N.T.	Rang Mahal	11KV	IX	07.30	09.08	01.38	Master Relay	3 Way RMU fault at Traffic P.S	Charged & remaining loads added on
2		Salarjung	Purani Haveli	11KV	III	14.10	16.40	02.30	All Indication	Jumper cut at SS & insulator flash over at Chatta Bazar	-----
3		C.R.P.F	Baba Nagar	11KV	III	16.15	18.15	02.00	EL,OL-Rph	Faulty loads of 11KV Omar Colony feeder	-----
4		Miralam	Amzadullah Bagh	11KV	III	19.05	20.46	01.41	All Indication	RMU Cable fault at Macca Colony Nala	-----
1	HYD C	Lumbini Park	T.T.D	11KV	I	19.44	21.10	01.26	EL,OL-Rph	3No. Banners fallen on lines at Liberty	-----