

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234		1		1		1			
5	RR(N)	54	550		2		2		2			
6	RR(E)	168	403									
7	Hyd	194	1044		14		14		14			
	Total	606	3055	0	17	0	17	0	17	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	1	3	1	3	1			
2	NLG	144	988		10		10		10			
3	MDK	107	933									
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	3	11	3	11	3	11	0	0	
	Grand Total	1082	6468	3	28	3	28	3	28	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Shanthinagar -1	33KV	Gadwal	07.50	08.30	00.40	E/L & O/L	No Visible fault for AB Switch Opened at Budidapad Supply Stude OK	Shanthinagar -1	-
2		Amangal	Polepally	33KV	Jadcherla	01.40	10.35	08.55	EL	Insulator failed and Replaced at Amangal	Polepally	-
3		Midjil	Velgomula	33KV	Jadcherla	20.05	01.45	05.40	EL	33KV Conductor snapped	Velgomula	-

TSSPDCL - LMRC / Corporate office

Date: 02.05.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Balanagar	Amith Cottin mill	11KV	Jadcherla	11.44	12.22	00.38		Cable fail near Chintha kunta thanda	-
1	NLG	Arlagaddagudem	Chinna Suraram	11KV	Nalgonda	11.35	12.45	01.10	E/L	11KV Insulator failed	-
2		Arlagaddagudem	Mangalapally	11KV	Nalgonda	09.45	11.15	01.30	E/L	11KV Line milting	-
3		Chervupally	Dacharam	11KV	Nalgonda	05.00	06.00	01.00	E/L	11KV Insulator failed	-
4		Penpahad	Macharam	11KV	Suryapet	06.00	08.55	02.55	E/L	Insulator flashover	-
5		Athmakur(S)	Athmakur Agl	11KV	Suryapet	04.30	07.45	03.15	E/L	Jumper cut	-
6		T.Giri	Thonda	11KV	Suryapet	06.30	08.45	02.15	E/L	Line Melt	-
7		Chinthapally	Chinthapally	11KV	Devarakonda	04.00	06.58	02.58	E/L	Chinthapally	-
8		Chinthapally	Nasarlappally	11KV	Devarakonda	05.10	06.25	01.15	E/L	Jumper Cutt	-
9		Mellavi	Revali	11KV	Devarakonda	06.00	07.30	01.30	E/L	Jumper Cutt	-
10		Amaravaram	Srinivasapuram	11KV	Huzurnagar	05.30	08.50	03.20	E/L	11 kv line snapped at Srinivasapuram village	-
1	RR S	Puppalaguda	Manikonda	11KV	IBGH	17.24	18.24	01.00	B/D	Plastic cover fallen on 11KV Line at Manikonda	-
1	RR N	GP Pally	Neibarwood	11KV	Medchal	16.30	18.05	01.35		11KV Line Cut and replaced at Prakash rao Thota	-
2		Nuthankal	Bharathi	11KV	Medchal	17.20	17.55	00.35		Snake Fallen on the 11KV Line at Ricemill, Nuthankal	-
1	HYD N	Chilkaiguda	Dandu Pentaiah	11KV	V	16.15	17.20	01.05	EL	Tree branches fallen on lines	-----
2		Chilkaiguda	New Boiguda	11KV	V	16.10	20.00	03.50	EL	No Visible fault	17:20 breaker charged on Zero load
3		Jamestreet	Food World	11KV	V	17.10	18.35	01.25	EL	Conductor snapped at New Vision Apts	-----
4		Chinna Thokatta	Central Exise Colony	11KV	VI	16.45	17.50	01.05	All Indication	No Visible fault	-----
5		Gymkhana	Pared Ground	11KV	V	16.40	19.25	02.45	EL	Tree branches fallen on lines at Pared Ground	-----
6		Gymkhana	Appolo	11KV	V	16.40	19.10	02.30	EL	Jumper Cut at Appolo Hospital	-----
7		Gymkhana	Tadbun Temple	11KV	V	16.40	18.55	02.15	EL	Tree branches fallen on lines at Balaji Temple	-----
8		Gymkhana	Balaji Enclave	11KV	V	16.40	18.05	01.25	EL	Big Tree fallen on lines at Balaji Enclave	Arranged BTR on 11KV Gymkhana fdr
9		Gymkhana	Rani Bagh	11KV	V	16.40	19.11	02.31	EL	I/C Cable fault at Rani Bagh	Arranged BTR on 11KV Balaji fdr
10		Marredpally	Ramser Café	11KV	V	17.15	18.40	01.25	EL,OL-Rph	Tree branches fallen on lines at Sec.Dad Nursing Home	-----
11		Chilkaiguda	New Boiguda	11KV	V	20.55	00.08	03.13	EL	3way RMU fault Opp Gandhi Hospital	Arranged BTR on 11KV C.C Nagar fdr
1	HYD S	Salarjung	Abid Ali Eye Hospital	11KV	VIII	01.15	02.20	01.05	EL,OL,	AB Cable fault	11KV Chaderghat
1	HYD C	Industrial Area	Azamabad I.E	11KV	II	18.30	20.58	02.28	All Indication	No Visible fault	Remaining Loads
2		Toli Chowki	Hakeemsha	11KV	VII	18.55	21.00	02.05	OL-Y&Bph	Tree branches on lines & AB Cable End Kit fault at Yan Residency, Brindhavan Colony	-----