

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		24		24		24			
7	RR(E)	168	403		14		14		14			
8	Hyd	194	1044		244		244		244			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>282</b>	<b>0</b>	<b>282</b>	<b>0</b>	<b>282</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	22	1	22	1	14	1	8		8 no.s 33kv still
2	NLG	144	988	28	99	28	99	16	34	12	65	12 no.s 33kv & 65 No.s 11 kv still
3	MDK	107	933	8	13	8	13	8	13			
4	SDPT			12	43	12	43	11	31	1	12	1 no 33kv & 12 No.s 11kv still
5	RR(S)	58	396	1		1		1				
6	RR(N)	38	114									
7	RR(E)	22	133		9		9		9			
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>71</b>	<b>165</b>	<b>71</b>	<b>165</b>	<b>50</b>	<b>88</b>	<b>21</b>	<b>77</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>71</b>	<b>447</b>	<b>71</b>	<b>447</b>	<b>50</b>	<b>370</b>	<b>21</b>	<b>77</b>	

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Salguti	11kv	Jadcherla	12.00	15.00	03.00		Cross arm Blade Cut At Kucharkal Lotus Company.	-
1	NLG	Koduru	Kommala	11kv	Suryapet	06.30	09.00	02.30	E/L	11Kv Insulator failed	-
2	NLG	Penpahad	Dubba thanda	11kv	Suryapet	05.30	07.40	02.10	E/L	11Kv Jumper cut	-
3	NLG	Penpahad	S.R Palem	11kv	Suryapet	17.00	19.30	02.30	E/L	11Kv Jumper cut	-
4	NLG	Dirsenapally	Yerrapahad	11kv	Suryapet	16.30	18.10	01.40	E/L	11Kv Conductor Snapped	-
5	NLG	Bibigudem	Ilapuram Agl	11kv	Suryapet	17.30	19.10	01.40	E/L	11Kv Jumper cut	-
6	NLG	Kudakuda	MG Nagar thanda	11kv	Suryapet	17.30	19.10	01.40	E/L	DTR AB Switch Problem	-
7	NLG	G.T Giri	Gunjalooru	11kv	Suryapet	17.30	18.55	01.25	E/L	11Kv Conductor Snapped	-
8	NLG	Durajpally	Durajpally Agl	11kv	Suryapet	17.15	19.00	01.45	E/L	11Kv Jumper cut	-
9	NLG	Bopparam	Kothagudem	11kv	Suryapet	17.40	21.00	03.20	E/L	11Kv Insulator flashover	-
10	NLG	Bopparam	Bopparam	11kv	Suryapet	18.00	19.30	01.30	E/L	11Kv Conductor Snapped	-
11	NLG	S.V Collage	Layola Express	11kv	Suryapet	15.00	17.00	02.00	E/L	11Kv Line Melt	-
12	NLG	R.C Puram	Solipeta	11kv	Suryapet	16.30	18.40	02.10	E/L	11Kv Insulator flashover	-
13	NLG	Shivanagudam	K.B.Pally	11kv	Devarakonda	18.35	00.00	05.25	E/L		-
14	NLG	Shivanagudam	S.R.Guda	11kv	Devarakonda	18.35	19.20	00.45	E/L	Tree Follan on 11Kv Line	-
15	NLG	Shivanagudam	R.R Pally	11kv	Devarakonda	18.42	00.00	05.18	E/L		-
16	NLG	D.B.Pally	Nerellapally	11kv	Devarakonda	18.19	00.00	05.41	E/L		-
17	NLG	K.M.Pally	Chennaram	11kv	Devarakonda	18.45	00.00	05.15	E/L		-
18	NLG	K.M.Pally	Palvai	11kv	Devarakonda	18.45	00.00	05.15	E/L		-
19	NLG	Midigonda	Gottimukala	11kv	Devarakonda	17.00	20.30	03.30	E/L	11Kv Conductor Sanpped	-
20	NLG	Midigonda	Mudigonda	11kv	Devarakonda	16.00	18.00	02.00	E/L	11Kv Conductor Sanpped	-
21	NLG	Singarajupally	Veeraboinapally	11kv	Devarakonda	19.00	00.00	05.00	E/L		-
22	NLG	Singarajupally	Singarajupally	11kv	Devarakonda	19.00	20.00	01.00	E/L	11Kv Jumpr cut	-
23	NLG	Dindi	Dindi Townen	11kv	Devarakonda	16.00	00.00	08.00	E/L		-
24	NLG	Angadipeta	P.A.pally	11kv	Devarakonda	15.30	00.00	08.30	E/L		-
25	NLG	Ghanapuram	Kodhandlapuram	11kv	Devarakonda	17.30	00.00	06.30	E/L		-
26	NLG	Ghanapuram	Polkampally	11kv	Devarakonda	17.30	00.00	06.30	E/L		-
27	NLG	RAGUNADPUR	RAGUNADPUR IND	11kv	Bhongir	18.30	20.00	02.30	E/L	Tree Follan Conductor Sanpped HT/LT	-
28	NLG	MOTHKUR	ANAJIPUR	11kv	Bhongir	18.00	19.47	01.47	E/L	Tree Follan Conductor Sanpped HT/LT	-
29	NLG	Arjalabavi	Arjalabavi IND	11kv	Nalgonda	15.30	22.50	07.20	E/L	Heavy gale and wind	-
30	NLG	Arjalabavi	Arjalabavi AGL	11kv	Nalgonda	15.30	22.30	07.00	E/L	Heavy gale and wind	-
31	NLG	Arjalabavi	Marrigudem Ind	11kv	Nalgonda	15.30	22.50	07.20	E/L	Heavy gale and wind	-
32	NLG	Arjalabavi	Cherlapally 24 Hrs	11kv	Nalgonda	15.30	22.45	07.15	E/L	Heavy gale and wind	-
33	NLG	Anneparthi	Anneparthi AGL	11kv	Nalgonda	15.30	22.50	07.20	E/L	Heavy gale and wind	-
34	NLG	Anneparthi	Batalian	11kv	Nalgonda	15.30	22.45	07.15	E/L	Heavy gale and wind	-
35	NLG	Anneparthi	Cherlapally AGL	11kv	Nalgonda	15.30	22.50	07.20	E/L	Heavy gale and wind	-
36	NLG	SLBC	M.D.Pally	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
37	NLG	SLBC	Kothapally	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
38	NLG	SLBC	Dorapally	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
39	NLG	SLBC	Darveshpuram	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
40	NLG	SLBC	Kathalguda	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
41	NLG	SLBC	SLBC	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
42	NLG	SLBC	SRST Collage	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
43	NLG	Mamillagudem	Anantharam	11kv	Nalgonda	15.30	20.12	04.42	E/L	Heavy gale and wind	-
44	NLG	Mamillagudem	Kothapally	11kv	Nalgonda	15.30	20.20	04.50	E/L	Heavy gale and wind	-

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
45	NLG	Edulur	Parada	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
46	NLG	Edulur	Munukuntla	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
47	NLG	Edulur	Garlabaigudam	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
48	NLG	Edulur	Kurumarthi	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
49	NLG	Edulur	Naragudam	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
50	NLG	Edulur	Edulur (T)	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
51	NLG	Pamangundla	Pittampally	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
52	NLG	Pamangundla	Ismailpally	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
53	NLG	Pamangundla	Yerrasanigudem	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
54	NLG	Pamangundla	Indl.	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
55	NLG	Pamangundla	A.P.Lingotam	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
56	NLG	Veliminedu	Veliminedu	11kv	Nalgonda	15.30	20.20	04.50	E/L	Heavy gale and wind	-
57	NLG	Veliminedu	Corramandal	11kv	Nalgonda	15.30	20.40	05.10	E/L	Heavy gale and wind	-
58	NLG	Veliminedu	Perapally	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
59	NLG	Veliminedu	Pittampally	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
60	NLG	Veliminedu	Gundrampally	11kv	Nalgonda	15.30	20.12	04.42	E/L	Heavy gale and wind	-
61	NLG	Gundrampally	Gundrampally	11kv	Nalgonda	15.30	20.20	04.50	E/L	Heavy gale and wind	-
62	NLG	Gundrampally	Apoor	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
63	NLG	Aregudem	Aregudam	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
64	NLG	Aregudem	Chinna Kaparathi	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
65	NLG	Aregudem	Pedda Kaaparathi	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
66	NLG	Aregudem	Chityala AGL	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
67	NLG	Ch.Annaram	Annaram	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
68	NLG	Ch.Annaram	Thotlavarigudem	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
69	NLG	Ch.Annaram	Garlabaigudam	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
70	NLG	Ch.Annaram	Vallala	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
71	NLG	Ch.Annaram	Industrial	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
72	NLG	Kadaparthi	Kadaparthi	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
73	NLG	Kadaparthi	Chandampally	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
74	NLG	Kadaparthi	Shivalayam AGL+Dom	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
75	NLG	Kadaparthi	Kondaram	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
76	NLG	Akaram	Akaram	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
77	NLG	Akaram	Shanthi Nagar	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
78	NLG	Akaram	Vaddipamula	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
79	NLG	Akaram	Vallala	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
80	NLG	Wangamarthy	Wangamarthy	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
81	NLG	Wangamarthy	Madharam	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
82	NLG	Wangamarthy	Chithaluru	11kv	Nalgonda	15.30	00.00	08.30	E/L	Heavy gale and wind	-
83	NLG	Biravunibanda	Biravunibanda	11kv	Nalgonda	15.30	20.35	05.05	E/L	Heavy gale and wind	-
84	NLG	Biravunibanda	Thakalapadu	11kv	Nalgonda	15.30	20.15	04.45	E/L	Heavy gale and wind	-
85	NLG	Biravunibanda	M.G.Kothapally	11kv	Nalgonda	15.30	20.40	05.10	E/L	Heavy gale and wind	-
86	NLG	Peddavoora	Charalkurthy	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind	-
87	NLG	Pottichelma	Ramannagudem	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind	-
88	NLG	Peddavoora	Peddavoora Rual	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind	-
89	NLG	Pottichelma	Nayanivanikunta	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind	-
90	NLG	Pottichelma	Shankannmayak thanda	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind	-

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
91	NLG	Pottichelma	Gaddameedithanda	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind	-
92	NLG	Muppam	Lift	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind (S-phase OK)	-
93	NLG	Muppam	Utkur	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind (S-phase OK)	-
94	NLG	Matoor	Matoor	11kv	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind (S-phase OK)	-
95	NLG	Kamareddygudem	Konthalapally	11kv	Miryalagudem	17.30	00.00	07.00	E/L	Due to heavy gale and wind	-
96	NLG	Haliya	Ibrahimpet	11kv	Miryalagudem	18.30	00.00	07.00	E/L	Due to heavy gale and wind (S-phase OK)	-
97	NLG	Haliya	Naidupalem	11kv	Miryalagudem	18.30	00.00	07.00	E/L	Due to heavy gale and wind (S-phase OK)	-
98	NLG	Haliya	Anumula	11kv	Miryalagudem	18.30	00.00	07.00	E/L	Due to heavy gale and wind (S-phase OK)	-
99	NLG	Haliya	Thirumalagiri	11kv	Miryalagudem	18.30	00.00	07.00	E/L	Due to heavy gale and wind (S-phase OK)	-
1	MDK	CHERYAL	KANDI	11kv	Sangareddy	15.40	21.30	05.50		B/D DUE TO TREE FALLEN ON LINE	-
2	MDK	RUDRARAM	RUDRARAM	11kv	Sangareddy	16.10	18.50	02.40		B/D DUE TO TREE FALLEN ON LINE	-
3	MDK	RUDRARAM	GANESH TEMPLE	11kv	Sangareddy	16.30	19.30	03.00		B/D DUE TO TREE FALLEN ON LINE	-
4	MDK	Fasalwadi	MNR	11kv	Sangareddy	15.50	19.35	03.45		B/D DUE TO TREE FALLEN ON LINE	-
5	MDK	CHERYAL	TURBOVENT	11kv	Sangareddy	18.10	22.30	04.20		B/D DUE TO TREE FALLEN ON LINE	-
6	MDK	ISNAPUR	PASHAMAILARAM	11kv	Sangareddy	08.00	08.35	00.35		B/D DUE TO TREE FALLEN ON LINE	-
7	MDK	RUDRARAM	LATRICATE	11kv	Sangareddy	16.10	20.50	04.40		B/D DUE TO TREE FALLEN ON LINE	-
8	MDK	AROOR	INDUSTRIAL	11kv	Sangareddy	20.00	21.40	01.40		B/D DUE TO INSULATORS FAILED	-
9	MDK	EPIP-I	CHITRAKUT	11kv	Sangareddy	19.20	23.30	04.10		B/D DUE TO INSULATORS FAILED	-
10	MDK	EPIP-I	OLD NEULAND	11kv	Sangareddy	19.20	23.30	04.10		B/D DUE TO INSULATORS FAILED	-
11	MDK	EPIP-I	NEW LAND	11kv	Sangareddy	19.20	23.30	04.10		B/D DUE TO INSULATORS FAILED	-
12	MDK	EPIP-II	EXPORT	11kv	Sangareddy	16.00	21.00	05.00		B/D DUE TO INSULATORS FAILED	-
13	MDK	EPIP-II	SRINIVASA CASTING	11kv	Sangareddy	16.00	23.30	07.30		B/D DUE TO INSULATORS FAILED	-
1	SDPT	Nangnoor	Siddannapet	11kv	SDPT	15.10	17.40	02.30		LT wire cut	-
2	SDPT	Nangnoor	Nangnoor Town	11kv	SDPT	15.15	16.45	01.30		LT wire cut	-
3	SDPT	Kondamrajally	Gatlamalyala	11kv	SDPT	15.30	16.00	00.30		near at DTR problem	-
4	SDPT	Khajipur	Bhoompally	11kv	SDPT	19.00	21.30	02.30		Tree branches fallen on the line	-
5	SDPT	Dubbak	Dubbak	11kv	SDPT	15.41	17.04	01.23		Face to face	-
6	SDPT	Peddagundavelly	Peddagundavelly	11kv	SDPT	15.00	16.00	01.00		Face to face	-
7	SDPT	Peddagundavelly	Balwanthapur	11kv	SDPT	15.45	16.45	01.00		Face to face	-
8	SDPT	Chellapur	Rajakkapet	11kv	SDPT	16.10	18.00	01.50		LT wire cut	-
9	SDPT	Pedda Cheekode	Pedda Cheekode	11kv	SDPT	15.40	18.00	02.20		Tree branches fallen on the line	-
10	SDPT	Pedda Cheekode	Achumaiplly	11kv	SDPT	17.30	20.00	02.30		LT wire cut	-
11	SDPT	Gambeerpur	Gambeerpur	11kv	SDPT	15.30	17.30	02.00		Tree branches fallen on the line	-
12	SDPT	Gambeerpur	Shilajinagar	11kv	SDPT	15.30	18.30	03.00		Pole Broken	-
13	SDPT	Gambeerpur	Potharam	11kv	SDPT	15.30	17.00	01.30		Tree branches fallen on the line	-
14	SDPT	POTHARAM	Nagaram	11kv	SDPT	14.25	17.35	01.10		Heavy Gale and Wind	-
15	SDPT	POTHARAM	Potharam rural	11kv	SDPT	16.57	17.05	00.08		Heavy Gale and Wind	-
16	SDPT	POTHARAM	Mirzapur	11kv	SDPT	12.25	16.50	04.25		Heavy Gale and Wind	-
17	SDPT	POTHARAM	Potharam town	11kv	SDPT	12.25	18.45	06.20		Heavy Gale and Wind	-
18	SDPT	POTHARAM	Keshavapur	11kv	SDPT	12.25	18.25	06.00		Heavy Gale and Wind	-
19	SDPT	AKKANNAPET	Fakkimayak thand	11kv	SDPT	20.45	00.00	03.15		Heavy Gale and Wind still under B/D	-
20	SDPT	THOTAPALLY	Mallampally	11kv	SDPT	15.00	19.00	03.00		Heavy Gale and Wind	-
21	SDPT	THOTAPALLY	Mallampally	11kv	SDPT	08.30	00.00	15.30		Insulator Failure Still under B/D	-
22	SDPT	KATKUR	Katkur rural	11kv	SDPT	12.35	00.00	11.25		Heavy Gale and Wind still under B/D	-
23	SDPT	KATKUR	Kannaram	11kv	SDPT	12.35	00.00	11.25		Heavy Gale and Wind still under B/D	-
24	SDPT	KATKUR	Mallaram	11kv	SDPT	12.35	00.00	11.25		Heavy Gale and Wind still under B/D	-

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
25	SDPT	KATKUR	Katkur town	11kv	SDPT	12.35	19.15	06.40		Heavy Gale and Wind	-
26	SDPT	GANDIPALLY	Ramavaram	11kv	SDPT	21.00	00.00	03.00		Heavy Gale and Wind still under B/D	-
27	SDPT	GOURAVELLI	Gudatipally	11kv	SDPT	20.45	00.00	03.15		Heavy Gale and Wind still under B/D	-
28	SDPT	DHARMARAM	Dharmaram rural	11kv	SDPT	13.40	00.00	10.20		Heavy Gale and Wind still under B/D	-
29	SDPT	HUSNABAD	Husnabad town 1	11kv	SDPT	15.00	16.15	01.15		Heavy Gale and Wind	-
30	SDPT	HUSNABAD	Madatha	11kv	SDPT	15.00	15.40	16.00		Heavy Gale and Wind	-
31	SDPT	HUSNABAD	Mallapally	11kv	SDPT	15.10	16.40	01.30		Disk Failure	-
32	SDPT	BEJJANKI	Bejanki town	11kv	SDPT	14.50	15.50	01.00		Heavy Gale and Wind	-
33	SDPT	KOHEDA	Venkateshwarapally	11kv	SDPT	13.30	16.50	03.20		Break down	-
34	SDPT	RAMCHANDRAPUR	Varikolu	11kv	SDPT	16.00	00.00	08.00		Heavy Gale and Wind still under B/D	-
35	SDPT	RAMCHANDRAPUR	Vinjapally	11kv	SDPT	16.00	00.00	08.00		Heavy Gale and Wind still under B/D	-
36	SDPT	THOTAPALLY	Thotapally rural	11kv	SDPT	17.15	20.00	02.45		Heavy Gale and Wind	-
37	SDPT	AKUNOOR	Rampur	11kv	SDPT	15.25	16.25	01.00		Heavy Gale and Wind	-
38	SDPT	DHOOLMITTA	Lingapur	11kv	SDPT	16.00	17.15	01.05		Heavy Gale and Wind	-
39	SDPT	DHOOLMITTA	Dhoolmitta Agl	11kv	SDPT	16.00	19.20	03.20		Heavy Gale and Wind	-
40	SDPT	DHOOLMITTA	Dhoolmitta 24 hrs	11kv	SDPT	16.00	17.45	01.45		Heavy Gale and Wind	-
41	SDPT	GAGILLAPUR	Gagillapur Agl	11kv	SDPT	13.35	00.00	10.25		Heavy Gale and Wind still under B/D	-
42	SDPT	GAGILLAPUR	Vallampatla	11kv	SDPT	14.15	19.20	05.05		Heavy Gale and Wind	-
43	SDPT	REGULAPALLY	All Feeders	11kv	SDPT	13.15	00.00	10.45		Heavy Gale and Wind still under B/D	-
1	RR N	Mayurinagar	Mayurinagar	11kv	kukatpally	18.45	19.30	00.45	EL&OL	11kv jumper cut near ladies hostel at Mayurinagar	-
2	RR N	Vemana Colony	Bhavanipuram	11kv	kukatpally	15.45	16.45	01.00	EL	Due To Heavy Wind	-
3	RR N	G Vikas	VoVo	11kv	kukatpally	15.53	17.45	01.52	EL&OL	Due To Heavy Wind	-
4	RR N	G Vikas	Aparana	11kv	kukatpally	15.58	17.45	01.47	EL&OL	Due To Heavy Wind	-
5	RR N	Mayurinagar	Mayurinagar	11kv	kukatpally	15.40	17.10	01.30	EL&OL	Due To Heavy Wind	-
6	RR N	Mayurinagar	Prashanthinagar	11kv	kukatpally	16.00	17.00	01.00	EL&OL	Due To Heavy Wind	-
7	RR N	Mayurinagar	K T R Colony	11kv	kukatpally	16.10	17.20	01.10	EL&OL	Due To Heavy Wind	-
8	RR N	Jeedimetla ss III	Ramreddy nagar	11kv	Jeedimetla	15.35	16.25	00.50	EL&OL	Due to heavy wind	-
9	RR N	R G K suraram	Krusha colony	11kv	Jeedimetla	15.53	17.03	01.10	EL&OL	Due to heavy wind	-
10	RR N	J D M SS-IV	Tagorea	11kv	Jeedimetla	08.50	10.08	01.18	EL&OL	11kv Jumper Cut Opp Venkatesha Wara Chemical	-
11	RR N	Subash Nagar	Jeedimetla	11kv	Medchal	15.10	16.30	01.20	BD	Tree Fallen on the 11KV Line at Green Park	-
12	RR N	Subash Nagar	Padma Nagar	11kv	Medchal	15.10	16.30	01.20	BD	Tree Fallen on the 11KV Line at Padma Nagar	-
13	RR N	Jagathgirigutta	Maqdoom Nagar	11kv	Medchal	17.30	18.30	01.00	BD	Tree Fallen on the 11KV Line at Seethal Basti	-
14	RR N	Athiwelly	SPIC	11kv	Medchal	18.20	20.20	02.00	BD	Breaker Mechanical Problem in SS	-
15	RR N	Ravalkole	IDA Ganapathi	11kv	Medchal	14.50	18.10	03.20	BD	11KV Pin Insulator failed at Rajabollaram Monark Company	-
16	RR N	Medicity	IDA-I	11kv	Medchal	15.12	16.00	00.48	BD	Tree Fallen on the 11KV Line at Medicity X Road	-
17	RR N	Gowdavelly	Ayodhya	11kv	Medchal	15.40	19.40	04.00	BD	Tree fallen on the 11KV Line at Poultry Farm ( 11KV Jumper opened )	-
18	RR N	Athiwelly	Dabeerapur	11kv	Medchal	16.20	18.53	02.33	BD	Tree fallen on the 11KV Line at Lingapur Village	-

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
19	RR N	Shameerpet	Shameerpet	11kv	Medchal	15.30	18.20	02.50	BD	3Nos 11KV Poles damaged at Ettigadda ( 11KV Jumper opened )	-
20	RR N	Devarayamjal	DMC	11kv	Medchal	16.20	18.10	01.50	BD	Tree fallen on the 11KV Line at DMC	-
21	RR N	Keshavaram	Adraspally	11kv	Medchal	17.40	20.57	03.17	BD	11KV Disc failed at Keshavaram Village	-
22	RR N	Keshavaram	Dairy	11kv	Medchal	17.40	19.45	02.05	BD	11KV Pole damaged at Keshavaram Village	-
23	RR N	Bandamadaram	Barmajiguda	11kv	Medchal	18.40	20.45	02.05	BD	11KV Pin Insulator failed at Lingapur Village	-
24	RR N	Kistapur	IDA Hanuman	11kv	Medchal	18.50	20.00	01.10	BD	Stick fallen on the 11KV Line at Kistapur Road	-
1	RR E	NGRI	Scienctist colony	11kv	Habsiguda	14.50	16.02	01.12		Coconut tree fallen on 11kv line at Scientist colony	-
2	RR E	Mallapur2	Krishna nagar	11kv	Habsiguda	14.36	17.08	02.32		Tree fallen on 11kv line at Krishna nagar	-
3	RR E	Cherlapally-l	Nagaram	11kv	Sainikpuri	17.05	18.25	01.20		11Kv Insuletor failure at Vasavi Shiva Nagar (AE/OP)	-
4	RR E	Kushaiguda	Sri Ram Nagar	11kv	Sainikpuri	15.15	17.00	01.45		MT Pole Bend on 11Kv line Toched at Gandhi Nagar (AE/OP)	-
5	RR E	Moula-Ali	Malkajiri	11kv	Sainikpuri	16.10	17.10	01.00		Tree fallen on 11Kv line at Hanuman Nagar (AE/OP)	-
6	RR E	VP Nagar	Ambedkar Nagar	11kv	Sainikpuri	15.55	16.35	00.40		Tree fallen on Jumper cut 11Kv line at Sri Colony (AE/OP)	-
7	RR E	Malkajiri	Anandbagh	11kv	Sainikpuri	14.44	17.56	03.12		4 Trees fallen on 11Kv line at Vani Nagar Street No 2 (AE/Vasanthapuri)	-
8	RR E	Malkajiri	Durga Nagar Cable	11kv	Sainikpuri	14.45	16.09	01.24		LT Cable failure on HG Fuses replacement at Hanumanpet (AE/OP)	-
9	RR E	Vasanthapuri	Old Mirzalaguda	11kv	Sainikpuri	16.15	16.58	00.43		HT/LT line toched at Old Mirzalaguda (AE/OP)	-
10	RR E	Vinayak Nagar	Neredmet Dite	11kv	Sainikpuri	16.20	17.00	00.40		Tree Branches fallen on 11Kv line at Dhinakar Nagar (AE/OP)	-
11	RR E	MOHAN NAGAR	R K PURAM	11kv	SAROORNAGAR	15.08	16.16	01.08	EL	COVER FALL ON 11KV LINE AT TELE PHONE COLONY ROAD NO 7	-
12	RR E	NAGOLE	SAMATHAPURI	11kv	SAROORNAGAR	14.58	18.03	03.05	EL	11KV INSULATER FAIL AT BHAVYA HOSPITAL	-
13	RR E	NAGOLE	ADARESH NAGAR	11kv	SAROORNAGAR	15.10	16.40	01.30	EL	TREE BRACHANS FALL ON 11KV LINE AT ADARESH NAGAR ROAD NO 1	-
14	RR E	AUTO NAGAR	SOUTHENDPARK	11kv	SAROORNAGAR	15.02	18.25	03.23	EL	33/11KV 33KV LINE 11KV LINE TOUCHED AT AUTO NAGAR	-
15	RR E	Keesara	Ankireddy pally	11kv	Keesara	16.50	17.30	00.40		Tree fallehn on 11kvline ar Ankiraddy palaly	-
16	RR E	Keesara	Kadevi	11kv	Keesara	15.50	17.00	01.10		insulator fail at Jahidar company	-
17	RR E	Keesara	Cheryala	11kv	Keesara	16.40	17.00	00.20		Tree fallen on 11kv line at Gowdhmakutta	-
18	RR E	Keesara	Vardhana	11kv	Keesara	16.00	17.00	01.00		15KVA T/F Fail at Kundanpalay	-
19	RR E	Keesara	Bogaram	11kv	Keesara	16.45	18.15	01.30		Tre fallen on 11kv line at kessaragutta back side	-
20	RR E	Yadgarpalaly	Cheryala	11kv	Keesara	15.20	17.50	02.30		insulator fail at Cheryala	-
21	RR E	Yadgarpalaly	Thmaipally	11kv	Keesara	15.20	18.42	03.22		Tree fallen on 11 kv line at Thimaipally	-
22	RR E	GKSR	Balaji nagar	11kv	Keesara	15.50	16.30	00.40		Line petroling done but no visiable falt found	-
23	RR E	Peerzathiguda	Shankar nagar	11kv	Keesara	17.05	17.25	00.20		Tree fallen on 1kvline at Shnakar nagar	-
1	HYD N	Nehru Nagar	West Marredpally	11kv	V	14.44	16.51	02.07	EL,OL	No Visible Fault (Heavy Rain & Gale)	----

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
2	HYD N	H.A.L	I.A.L	11kv	VI	14.40	15.45	01.05	EL	No Visible Fault (Heavy Rain & Gale)	-----
3	HYD N	H.A.L	Samrat	11kv	VI	14.40	15.45	01.05	EL	No Visible Fault (Heavy Rain & Gale)	-----
4	HYD N	Muffakamja College	Times of India	11kv	X	15.11	16.12	01.01	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
5	HYD N	Zamistanpur	Sanjeevapuram	11kv	V	15.10	18.30	03.20	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
6	HYD N	Tirumalagiri	Chinna Kamela	11kv	VI	14.30	16.50	02.20	EL,OL-R&Yph	Tree branches fallen on lines at Syndicate Bank	-----
7	HYD N	Tirumalagiri	Srinagar Colony	11kv	VI	14.35	16.30	01.55	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	-----
8	HYD N	Seethaphalmandi	Seethaphalmandi	11kv	V	14.45	19.45	05.00	EL	Tree branches fallen on lines at Garuda Apts, Opp: Sridevi Theater	-----
9	HYD N	Bansilalpet	Nagannakunta	11kv	V	14.40	20.10	05.30	All Indication	Tree branches fallen on lines at Nagannakunta	-----
10	HYD N	Lalaguda	Nagarjuna Nagar	11kv	V	15.40	19.10	03.30	EL	No Visible Fault (Heavy Rain & Gale)	-----
11	HYD N	Lalaguda	Chenna Reddy Nagar	11kv	V	14.50	16.05	01.15	EL	No Visible Fault (Heavy Rain & Gale)	-----
12	HYD N	Lalaguda	Vijayapuri	11kv	V	14.48	19.10	04.22	EL	No Visible Fault (Heavy Rain & Gale)	-----
13	HYD N	Greenlands	Ameerpet	11kv	IV	15.00	16.10	01.10	All Indication	Add Board fallen on lines at Ameerpet X-Roads	-----
14	HYD N	Bowenpally	Pension Line	11kv	VI	15.50	17.15	01.25	EL	Tree branches fallen on lines at Pension Line	-----
15	HYD N	Bowenpally	Jaya Nagar	11kv	VI	15.50	17.15	01.25	EL,OL-Rph	Tree branches fallen on lines at Jaya Nagar	-----
16	HYD N	Bowenpally	Sancharapuri Colony	11kv	VI	15.50	17.15	01.25	EL,OL-Rph	Tree branches fallen on lines at Sancharapuri Colony	-----
17	HYD N	Bowenpally	Plassy Lines	11kv	VI	15.50	17.20	01.30	EL,OL-Rph	Tree branches fallen on lines at Plassy Lines	-----
18	HYD N	H.A.L	Indian Rubber	11kv	VI	17.08	18.15	01.07	All Indication	No Visible Fault (Heavy Rain & Gale)	-----
19	HYD N	Patigadda	Rani Gunj	11kv	V	16.30	19.35	03.05	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	-----
20	HYD N	Patigadda	Zeera	11kv	V	17.25	21.20	03.55	EL	Tree branches fallen on lines at Ranigunj Bus Depot	-----
21	HYD N	Patigadda	Rasoolpura	11kv	V	17.40	21.15	03.35	EL	Cable fault at Rasoolpura X Road	-----
22	HYD N	R.P.Nilayam	Alwal	11kv	VI	14.20	16.25	02.05	EL	No Visible Fault (Heavy Rain & Gale)	-----
23	HYD N	R.P.Nilayam	E.M.E.	11kv	VI	14.25	16.02	01.37	EL	No Visible Fault (Heavy Rain & Gale)	-----
24	HYD N	R.P.Nilayam	Naga Devatha	11kv	VI	14.30	18.55	04.25	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	-----
25	HYD N	R.P.Nilayam	Venkatapuram	11kv	VI	14.30	18.20	03.50	EL	No Visible Fault (Heavy Rain & Gale)	-----
26	HYD N	R.P.Nilayam	Saraswathi Nagar	11kv	VI	14.30	16.07	01.37	EL	No Visible Fault (Heavy Rain & Gale)	-----
27	HYD N	R.P.Nilayam	Rythu Bazar	11kv	VI	14.30	18.50	04.20	EL	No Visible Fault (Heavy Rain & Gale)	-----
28	HYD N	R.P.Nilayam	Vaishnavi Matha	11kv	VI	15.20	16.55	01.35	EL	No Visible Fault (Heavy Rain & Gale)	-----
29	HYD N	Nehru Nagar	J.B.S.	11kv	V	14.43	17.25	02.42	OL-R&Yph	No Visible Fault (Heavy Rain & Gale)	-----
30	HYD N	Nehru Nagar	J.B.S.	11kv	V	17.36	21.27	03.51	EL,OL	Tree branches fallen on lines at L.I.C. Colony	-----
31	HYD N	Gymkhana	Vikrampuri	11kv	V	14.38	18.20	03.42	EL	Tree branches fallen on lines at Vikrampuri	-----
32	HYD N	Gymkhana	Mud Fort	11kv	V	14.40	17.30	02.50	EL	Tree branches fallen on lines at Mud Fort	-----
33	HYD N	Gymkhana	Balamrai	11kv	V	14.37	17.10	02.33	EL	Tree branches fallen on lines at Balamrai	-----
34	HYD N	Gymkhana	Balaji Enclave	11kv	V	14.40	18.40	04.00	EL	Tree branches fallen on lines at Balaji Enclave	-----
35	HYD N	Gymkhana	Rani Bagh	11kv	V	14.55	18.40	03.45	EL	Tree branches fallen on lines at Rani Bagh	-----
36	HYD N	Gymkhana	Laxmi Nagar	11kv	V	14.44	18.30	03.46	EL	Tree branches fallen on lines at Laxmi Nagar	-----
37	HYD N	Gymkhana	Apollo	11kv	V	14.45	19.20	04.35	EL	Tree branches fallen on lines at Apollo Hospital	-----
38	HYD N	Gymkhana	Pared Ground	11kv	V	14.48	18.39	03.51	EL	Tree branches fallen on lines at Pared Ground	-----

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
39	HYD N	Gymkhana	Sikh Village	11kv	V	14.48	18.35	03.47	EL	Tree branches fallen on lines at Sikh Village	-----
40	HYD N	Gymkhana	Vayu Sena	11kv	V	14.44	18.55	04.11	EL	Tree branches fallen on lines at Vayu Sena	-----
41	HYD N	Gymkhana	Vasavi Nagar	11kv	V	14.45	18.25	03.40	EL	Tree branches fallen on lines at Vasavi Nagar	-----
42	HYD N	Nehru Nagar	Teachers Colony	11kv	V	14.44	17.06	02.22	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
43	HYD N	Chinna Thokatta	Parkview Enclave	11kv	VI	14.35	16.05	01.30	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	-----
44	HYD N	Bansilalpet	Viceroy	11kv	V	14.40	22.40	08.00	All Indication	No Visible Fault (Heavy Rain & Gale)	Arranged B/F on 11KV Naganna Kunta fdr
45	HYD N	Prakash Nagar	Shoppers Stop	11kv	IV	14.55	16.21	01.26	EL	No Visible Fault (Heavy Rain & Gale)	-----
46	HYD N	Vasanthapuri	Siripuri Colony	11kv	V	17.22	19.59	02.37	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
47	HYD N	K.I.M.S	D.V.Colony	11kv	V	14.49	18.40	03.51	EL	Tree branches fallen on lines at D.V.Colony	-----
48	HYD N	Gunrock	A.W.H.O.	11kv	VI	14.40	17.35	02.55	EL	No Visible Fault (Heavy Rain & Gale)	Arranged B/F on 11KV L.N.Colony feeder
49	HYD N	Sanjeevaiah Park	Police Lines	11kv	V	16.02	19.00	02.58	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
50	HYD N	Nehru Nagar	Contonement	11kv	V	14.43	19.32	04.49	EL,OL-Yph	Tree branches fallen on lines at Various Locations	-----
51	HYD N	Gunrock	Lal Bazar	11kv	VI	14.40	16.15	01.35	EL	No Visible Fault (Heavy Rain & Gale)	Arranged B/F on 11KV Chinna Kamela fdr
52	HYD N	Gunrock	Surya Enclave	11kv	VI	14.40	17.55	03.15	EL,OL	No Visible Fault (Heavy Rain & Gale)	Arranged B/F on 11KV Tirumalagiri fdr
53	HYD N	Gunrock	Tirumalagiri	11kv	VI	14.40	16.50	02.10	EL,OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
54	HYD N	Chilkaiguda	New Boiguda	11kv	V	14.46	17.39	02.53	EL	Tree branches fallen on lines at New Boiguda	-----
55	HYD N	Chilkaiguda	Dandu Pentaiah	11kv	V	14.45	19.20	04.35	EL	Tree branches fallen on lines at Sai Baba Temple Lane	-----
56	HYD N	Chilkaiguda	Pragatools	11kv	V	14.47	18.50	04.03	EL	Tree branches fallen on lines & Jumper cut at Mekala Mandi	-----
57	HYD N	Chilkaiguda	P.R.Nagar	11kv	V	15.14	17.05	01.51	EL	No Visible Fault (Heavy Rain & Gale)	-----
58	HYD N	H.P.S.	Mayuri Marg	11kv	IV	14.50	16.15	01.25	OL-Bph	Tree branches fallen on lines at Mayuri Marg	-----
59	HYD N	Kundanbagh	Shanthi Shikara	11kv	IV	14.48	16.45	01.57	EL	No Visible Fault (Heavy Rain & Gale)	Arranged B/F on 11KV B.S.Maktha feeder
60	HYD N	Tirumalagiri	Khanajiguda	11kv	VI	14.20	18.30	04.10	EL,OL-Yph	Tree branches fallen on lines at Khanajiguda	-----
61	HYD N	Road No.13	Road No.1	11kv	X	14.52	16.11	01.19	EL	Tree branches fallen on lines at Servy Hotel	-----
62	HYD N	Monda Market	Gandhi Nagar PS	11kv	V	15.15	16.35	01.20	EL	No Visible Fault (Heavy Rain & Gale)	-----
1	HYD S	Salarjung	Purani Haveli	11kv	III	10.05	11.20	01.15	All Indication	Breaker Releay fault at SS	Arranged B/F on 11KV Salarjung Museum fdr
2	HYD S	Madannapet	Waheed Nagar	11kv	VIII	15.10	16.15	01.05	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	-----
3	HYD S	Petlaburz	Petlaburz	11kv	III	15.01	16.32	01.31	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
4	HYD S	Petlaburz	Shah Gunj	11kv	III	15.06	16.12	01.06	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
5	HYD S	Petlaburz	Chowk	11kv	III	15.10	16.40	01.30	EL	No Visible Fault (Heavy Rain & Gale)	-----



TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
6	HYD S	Santosh Nagar	Moon Star	11kv	VIII	14.24	16.18	01.54	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	-----
7	HYD S	Santosh Nagar	Dry Land	11kv	VIII	15.05	18.18	03.13	EL	Pin Insulator flash over at Mee Seva	-----
8	HYD S	Santosh Nagar	Jahangir Nagar	11kv	VIII	15.06	18.20	03.14	EL	No Visible Fault (Heavy Rain & Gale)	-----
9	HYD S	Santosh Nagar	SRT Colony	11kv	VIII	15.06	16.17	01.11	EL,OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
10	HYD S	Santosh Nagar	Edi Bazar	11kv	VIII	15.07	16.14	01.07	EL	No Visible Fault (Heavy Rain & Gale)	-----
11	HYD S	Santosh Nagar	SRT Colony	11kv	VIII	16.52	18.13	01.21	EL	No Visible Fault (Heavy Rain & Gale)	-----
12	HYD S	Moosarambagh	Moosarambagh	11kv	VIII	14.57	17.45	02.48	EL	No Visible Fault (Heavy Rain & Gale)	-----
13	HYD S	Moosarambagh	Dilsukh Nagar	11kv	VIII	14.59	17.05	02.06	EL	No Visible Fault (Heavy Rain & Gale)	-----
14	HYD S	Moosarambagh	Shalivahana Nagar	11kv	VIII	15.15	17.47	02.32	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
15	HYD S	Teegalaguda	Housing Board Colony	11kv	VIII	14.57	16.07	01.10	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
16	HYD S	Teegalaguda	RTA Saleem Nagar	11kv	VIII	14.58	16.06	01.08	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
17	HYD S	Teegalaguda	Milk Booth	11kv	VIII	14.58	16.05	01.07	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
18	HYD S	Teegalaguda	Sri Nagar	11kv	VIII	14.58	16.06	01.08	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
19	HYD S	Teegalaguda	Shivalayam	11kv	VIII	14.58	16.07	01.09	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
20	HYD S	C.R.P.F	Jamal Banda	11kv	III	15.10	16.50	01.40	All Indication	No Visible Fault (Heavy Rain & Gale)	-----
21	HYD S	Vittalwadi	Ramkoti	11kv	IX	15.00	18.10	03.10	EL,OL-Rph	Tree branches fallen on lines at College	-----
22	HYD S	Salarjung	Q.Q Stadium	11kv	III	16.40	18.30	01.50	EL,OL	Tree branches fallen on lines at Q.Q Stadium	-----
23	HYD S	Salarjung	Sadath Nagar	11kv	VIII	14.48	18.50	04.02	EL	No Visible Fault (Heavy Rain & Gale)	-----
24	HYD S	Salarjung	Yakuthpura	11kv	VIII	16.50	18.50	02.00	EL	No Visible Fault (Heavy Rain & Gale)	-----
25	HYD S	Aliyabad	Sather Bagh	11kv	III	15.05	18.47	03.42	EL	Tree fallen on lines at Sainabad Kabestan	-----
26	HYD S	Aliyabad	Rooplal Bazar	11kv	III	15.05	18.55	03.50	EL	Twisted Lines at Lal Pasha Masjid	-----
27	HYD S	Aliyabad	Sharada College	11kv	III	15.06	17.58	02.52	EL	Tree fallen on lines at Sharada College	-----
28	HYD S	Aliyabad	Police Quarters	11kv	III	15.05	18.02	02.57	OL	No Visible Fault (Heavy Rain & Gale)	-----
29	HYD S	Aliyabad	Police Quarters	11kv	III	18.07	19.54	01.47	EL	Faulty loads of 11KV Falaknuma AB Cable fdr	-----
30	HYD S	Gunj	Gunj	11kv	VIII	15.05	16.10	01.05	EL	No Visible Fault (Heavy Rain & Gale)	-----
31	HYD S	Gunj	Super Bazar	11kv	VIII	15.15	16.25	01.10	EL	No Visible Fault (Heavy Rain & Gale)	-----
32	HYD S	Yakuthpura	Dharmavanth	11kv	VIII	15.10	18.55	03.45	EL,OL-R&Bph	No Visible Fault (Heavy Rain & Gale)	-----
33	HYD S	Kandikalgate	Kandikalgate	11kv	III	15.15	17.40	02.25	EL,OL	Top Jumper cut at Olympic Gym & O/G Jumper cut at SS	-----
34	HYD S	Kandikalgate	Saibaba Nagar	11kv	III	15.15	18.20	03.05	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
35	HYD S	Kandikalgate	Rakshapuram	11kv	III	15.15	18.10	02.55	EL,OL	DTR fault at Rakshapuram	-----
36	HYD S	Kandikalgate	Naseeb Nagar	11kv	III	15.15	17.00	01.45	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
37	HYD S	Jiyaguda	Nalla Pochamma Temple	11kv	IX	15.05	17.30	02.25	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
38	HYD S	Jiyaguda	Goshala	11kv	IX	15.05	17.30	02.25	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
39	HYD S	Gunj	Palton	11kv	VIII	16.20	17.50	01.30	EL	No Visible Fault (Heavy Rain & Gale)	-----
40	HYD S	Falaknuma	Guntal Shah Darga	11kv	III	15.55	17.52	01.57	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
41	HYD S	Falaknuma	Falaknuma UG	11kv	III	15.55	17.50	01.55	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
42	HYD S	Falaknuma	Jangammet OH	11kv	III	15.55	18.17	02.22	OL-Rph	Tree branches fallen on lines at Jangammet	-----
43	HYD S	Falaknuma	Chatrinaka	11kv	III	15.43	18.40	02.57	OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
44	HYD S	Miralam	Tadbun	11kv	III	15.00	17.00	02.00	EL,OL-R&Bph	Tree braches fallen on lines at Tadbun & O/G Jumper cut at SS	-----

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
45	HYD S	Miralam	Teegala Kunta	11kv	III	15.00	17.10	02.10	All Indication	Tree braches fallen on lines at Teegala Kunta	----
46	HYD S	Miralam	Mustafa Nagar	11kv	III	15.00	17.40	02.40	All Indication	No Visible Fault (Heavy Rain & Gale)	----
47	HYD S	Miralam	Hasan Nagar	11kv	III	15.00	17.50	02.50	EL,OL-R,Y&Bph	No Visible Fault (Heavy Rain & Gale)	----
48	HYD S	Laxmi Nagar	Dhobi Ghat	11kv	VIII	17.10	18.39	01.29	OL-Bph	No Visible Fault (Heavy Rain & Gale)	----
49	HYD S	Laxmi Nagar	Singareni Colony	11kv	VIII	16.30	18.39	02.09	OL-Rph	No Visible Fault (Heavy Rain & Gale)	----
50	HYD S	Kandikal Gate	Gazimillath Colony	11kv	III	17.00	18.05	01.05	EL,OL-R&Yph	No Visible Fault (Heavy Rain & Gale)	----
51	HYD S	Laxmi Nagar	Dhobi Ghat	11kv	VIII	19.05	20.11	01.06	EL	Faulty AB Switch at Swikar Hotel	----
52	HYD S	Teegalaguda	Housing Board Colony	11kv	VIII	17.32	20.54	03.22	OL-Rph	Tree branches fallen on lines at Housing Board Colony	----
53	HYD S	Kandikal Gate	Kandikalgate	11kv	III	19.05	20.11	01.06	EL	Faulty AB Switch at Swikar Hotel	----
54	HYD S	Kanchanbagh	Kanchanbagh	11kv	VIII	14.56	16.15	01.19	EL,OL	No Visible Fault (Heavy Rain & Gale)	----
55	HYD S	Kanchanbagh	Jamal Colony	11kv	VIII	14.58	16.18	01.20	EL,OL	No Visible Fault (Heavy Rain & Gale)	----
56	HYD S	Kanchanbagh	Riyasath Nagar	11kv	III	15.00	16.14	01.14	OL	No Visible Fault (Heavy Rain & Gale)	----
57	HYD S	Kanchanbagh	Riyasath Nagar	11kv	III	16.20	18.05	01.45	OL	No Visible Fault (Heavy Rain & Gale)	----
58	HYD S	Kanchanbagh	I.S.Sadan	11kv	III	16.24	20.08	03.44	OL	Tree branches fallen on lines at I.S.Sadan	----
59	HYD S	Kanchanbagh	Kanchanbagh	11kv	VIII	16.25	17.56	01.31	OL	Faulty DTR at Max Ice Cream	----
60	HYD S	Kanchanbagh	Jamal Colony	11kv	VIII	16.25	17.58	01.33	EL,OL	No Visible Fault (Heavy Rain & Gale)	----
61	HYD S	Teegalaguda	Teegalaguda	11kv	VIII	14.50	16.05	01.15	OL-R&Yph	No Visible Fault (Heavy Rain & Gale)	----
62	HYD S	Teegalaguda	Teegalaguda	11kv	VIII	17.31	19.05	01.34	OL-R&Yph	No Visible Fault (Heavy Rain & Gale)	----
63	HYD S	Devi Bagh	Bandlaguda	11kv	III	16.26	18.25	01.59	OL	Pole Bend at Bharath Petrol Pump	----
64	HYD S	Yakuthpura	Somnath Temple	11kv	VIII	15.15	17.05	01.50	EL,OL-R&Yph	No Visible Fault (Heavy Rain & Gale)	----
65	HYD S	Yakuthpura	Sravani Hospital	11kv	VIII	15.16	16.20	01.04	EL	No Visible Fault (Heavy Rain & Gale)	----
66	HYD S	Aliyabad	Shamsheergunj	11kv	III	15.05	21.17	06.12	EL	Tree branches fallen on lines at Imamam Bada	----
67	HYD S	Yakuthpura	Bada Bazar	11kv	VIII	15.00	18.30	03.30	EL,OL-Bph	HT Jumper cut at 5Star DTR	----
68	HYD S	Gosha Mahal	M.J.Market	11kv	IX	14.30	16.35	02.05	EL,OL-Bph	Tree branches fallen on lines at M.J.Market	----
69	HYD S	Seetharambagh	Dattatreya Nagar OH	11kv	IX	14.55	17.30	02.35	EL	No Visible Fault (Heavy Rain & Gale)	----
70	HYD S	Seetharambagh	Agapura	11kv	IX	14.57	16.40	01.43	OL-R&Bph	Tree branches fallen on lines at Agapura Nala	----
71	HYD S	Seetharambagh	Seetharambagh	11kv	IX	15.28	19.50	04.22	EL,OL	Tree branches fallen on lines at R.K.Pet	----
72	HYD S	Seetharambagh	Zinsi Chowrah	11kv	IX	15.30	18.30	03.00	OL-R,Y&Bph	Tree branches fallen on lines at Prakash Theater	----
73	HYD S	Seetharambagh	Asif Nagar	11kv	IX	16.10	17.20	01.10	EL	No Visible Fault (Heavy Rain & Gale)	----
74	HYD S	Gosha Mahal	Gosha Mahal	11kv	IX	14.58	16.44	01.46	EL,OL-Yph	No Visible Fault (Heavy Rain & Gale)	----
75	HYD S	Gosha Mahal	Gyan Bagh Colony	11kv	IX	15.04	20.29	05.25	EL,OL-Yph	Cable fault at Gyanbagh Colony	Arranged B/F on 11KV Zinsi Chowrah fdr
76	HYD S	Gosha Mahal	Hindi Nagar	11kv	IX	15.06	21.10	06.04	EL,OL-Y&Bph	No Visible Fault (Heavy Rain & Gale)	----
77	HYD S	Petlaburz	Hussaini Alam	11kv	III	15.02	19.45	04.43	OL-R&Yph	No Visible Fault (Heavy Rain & Gale)	----
78	HYD S	Khilwath	Khilwath	11kv	III	15.00	16.25	01.25	EL	No Visible Fault (Heavy Rain & Gale)	----
79	HYD S	Asmangadh	Gowtham Nagar	11kv	VIII	14.58	17.30	02.32	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	----

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
80	HYD S	Asmangadh	Asmangadh	11kv	VIII	15.11	16.55	01.44	EL	No Visible Fault (Heavy Rain & Gale)	-----
81	HYD S	Gunj	H.H.Skhetra	11kv	VIII	14.51	20.24	05.33	EL	Tree branches fallen on lines at Various Locations	-----
82	HYD S	Fever Hospital	Kachiguda	11kv	IX	14.50	15.55	01.05	Without Indication	No Visible Fault (Heavy Rain & Gale)	-----
83	HYD S	Koti Womens College	Quthbiguda	11kv	IX	17.40	20.46	03.06	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
84	HYD S	Chanchalguda	Chanchalguda	11kv	VIII	16.27	17.50	01.23	EL,OL-Rph	HT Jumper cut at Chanchalguda Jail	-----
85	HYD S	Osm. Hospital	Osmangunj	11kv	IX	15.15	19.45	04.30	EL,OL	Faulty 3Way RMU at Kishan Gunj	-----
86	HYD S	Malakpet	Malakpet	11kv	VIII	16.40	18.20	01.40	EL	No Visible Fault (Heavy Rain & Gale)	-----
87	HYD S	Malakpet	Komatiwadi	11kv	VIII	15.10	18.05	02.55	EL	O/G Jumper cut & Post type Insulator flash over & Relay problem at SS	Arranged B/F on 11KV Bibi Ka Alwa fdr
88	HYD S	Malakpet	Chaderghat	11kv	VIII	16.50	18.15	01.25	EL	No Visible Fault (Heavy Rain & Gale)	-----
89	HYD S	Malakpet	Azampura	11kv	VIII	17.10	19.55	02.45	EL	Foreign material fallen on line at Azampura Chaman	-----
90	HYD S	Malakpet	M.M.H.	11kv	VIII	15.00	17.00	02.00	EL	No Visible Fault (Heavy Rain & Gale)	-----
91	HYD S	Malakpet	Farhath Nagar	11kv	VIII	15.00	17.15	02.15	EL	No Visible Fault (Heavy Rain & Gale)	-----
92	HYD S	Malakpet	Yasodha Hospital	11kv	VIII	17.10	19.45	02.35	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
93	HYD S	Malakpet	Plant Protection	11kv	VIII	15.00	18.30	03.30	EL	Tree branches fallen on lines at Water Works	-----
94	HYD S	Malakpet	Bibi Ka Alwa	11kv	VIII	15.00	17.00	02.00	EL	No Visible Fault (Heavy Rain & Gale)	-----
1	HYD C	Golnaka	Kamala Nagar	11kv	II	14.48	16.03	01.15	EL	Brass Patti cut at Lanka DTR	-----
2	HYD C	Indira Park	Kuchipudi	11kv	I	14.58	16.20	01.22	EL	No Visible Fault (Heavy Rain & Gale)	-----
3	HYD C	Industrial Area	RTC X-Roads	11kv	II	14.40	16.15	01.35	EL,OL	Street Light Pole fallen on HT lines at Risalagadda	-----
4	HYD C	Industrial Area	Mother Dairy	11kv	II	14.40	18.55	04.15	EL,OL	Tree branches fallen on lines & Serial bulb wire fallen on lines at Gowri Shanker Apts	-----
5	HYD C	Jawahar Nagar	Anjaiah Bhavan	11kv	I	14.52	17.10	02.18	EL	No Visible Fault (Heavy Rain & Gale)	-----
6	HYD C	Jawahar Nagar	Ashok Nagar	11kv	I	14.52	17.10	02.18	EL	No Visible Fault (Heavy Rain & Gale)	-----
7	HYD C	S.D Hospital	Cha Cha Nehru Park	11kv	VII	14.55	16.50	01.55	EL	Tree branches fallen on lines at Cha Cha Nehru Park	-----
8	HYD C	S.D Hospital	Humyun Nagar	11kv	VII	14.58	16.50	01.52	EL	Twisted Lines at Humayun Nagar	-----
9	HYD C	S.D Hospital	Police Mess	11kv	VII	15.00	16.20	01.20	EL,OL-Rph	No Visible Fault (Heavy Rain & Gale)	-----
10	HYD C	Industrial Area	R.O.M	11kv	II	16.15	17.50	01.35	EL	Tree branches fallen on lines at VST Function Hall	-----
11	HYD C	Jawahar Nagar	J.N Home	11kv	I	14.50	18.10	03.20	EL	No Visible Fault (Heavy Rain & Gale)	-----
12	HYD C	Jawahar Nagar	Bank of Baroda	11kv	I	14.50	19.15	04.25	EL	No Visible Fault (Heavy Rain & Gale)	-----
13	HYD C	Jawahar Nagar	Post Office	11kv	I	15.20	18.10	02.50	EL	No Visible Fault (Heavy Rain & Gale)	-----
14	HYD C	A.S.R.Raju Nagar	Jeevan Kalyan Nagar	11kv	VII	15.04	16.18	01.14	EL	No Visible Fault (Heavy Rain & Gale)	-----
15	HYD C	A.S.R.Raju Nagar	Ushodaya Colony	11kv	VII	15.10	16.40	01.30	EL	No Visible Fault (Heavy Rain & Gale)	-----
16	HYD C	Nampally	Red Hills	11kv	VII	14.53	16.42	01.49	EL	Tree branches fallen on lines at Red Hills	-----
17	HYD C	Nampally	Vijay Nagar Colony	11kv	VII	14.55	16.47	01.52	EL	Tree branches fallen on lines at Meera Garden	-----
18	HYD C	Nampally	FAPCCI	11kv	VII	15.00	16.10	01.10	EL	No Visible Fault (Heavy Rain & Gale)	-----
19	HYD C	Vittalwadi	Y.M.C.A	11kv	II	15.05	18.30	03.25	EL,OL-R&Bph	No Visible Fault (Heavy Rain & Gale)	-----

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
20	HYD C	Golconda	Darga OH	11kv	VII	16.20	17.50	01.30	EL	No Visible Fault (Heavy Rain & Gale)	----
21	HYD C	Golconda	Water Works	11kv	VII	16.40	17.55	01.15	EL	No Visible Fault (Heavy Rain & Gale)	----
22	HYD C	Bathkammakunta	D.D Colony	11kv	II	14.46	16.15	01.29	EL	Tree branches fallen on lines at D.D Colony	----
23	HYD C	Bathkammakunta	Ayyappa Temple	11kv	II	14.49	16.50	02.01	EL	Tree branches fallen on lines at Library	----
24	HYD C	Bathkammakunta	Shivam	11kv	II	14.51	16.15	01.24	EL	Tree branches fallen on lines at Saketh Apts	----
25	HYD C	Bathkammakunta	Saibaba Temple	11kv	II	14.56	16.25	01.29	EL	Tree branches fallen on lines at Saibaba Temple	----
26	HYD C	Hyderguda	Urdu Hall	11kv	I	16.15	20.10	03.55	EL	Tree branches fallen on lines at Various Locations	----
27	HYD C	Z.P Office	Nirankari Bhavan	11kv	I	14.52	16.22	01.30	OL	Tree branches fallen on lines at Nirankari Bhavan	----
28	HYD C	Z.P Office	Golconda Hotel	11kv	I	14.54	20.32	05.38	EL,OL	No Visible Fault (Heavy Rain & Gale)	----
29	HYD C	Z.P Office	Seven Temple	11kv	I	14.58	18.02	03.04	EL,OL	Tree branches fallen on lines at Seven Temple	----
30	HYD C	I.T.I Mallepally	P.S Nagar	11kv	VII	14.54	18.20	03.26	EL	Tree branches fallen on lines at P.S Nagar	----
31	HYD C	I.T.I Mallepally	Anjuman	11kv	VII	14.58	19.00	04.02	EL,OL	No Visible Fault (Heavy Rain & Gale)	----
32	HYD C	I.T.I Mallepally	Anwar Ul Uloom	11kv	VII	15.53	17.39	01.46	EL,OL	No Visible Fault (Heavy Rain & Gale)	----
33	HYD C	I.T.I Mallepally	Zaheera Masjid	11kv	VII	15.01	17.13	02.12	EL,OL	No Visible Fault (Heavy Rain & Gale)	----
34	HYD C	Mothi Mahal	Saleh Nagar	11kv	VII	17.15	18.38	01.23	EL,OL-R&Yph	No Visible Fault (Heavy Rain & Gale)	----
35	HYD C	Z.P.Office	Anand Nagar	11kv	I	15.36	17.20	01.44	EL	No Visible Fault (Heavy Rain & Gale)	----
36	HYD C	Nizam College	Roseary Convent	11kv	I	14.52	17.50	02.58	EL	No Visible Fault (Heavy Rain & Gale)	----
37	HYD C	Nizam College	Nizam College	11kv	I	14.52	17.38	02.46	EL	No Visible Fault (Heavy Rain & Gale)	----
38	HYD C	Nizam College	Little Flower	11kv	I	14.52	19.40	04.48	EL	No Visible Fault (Heavy Rain & Gale)	----
39	HYD C	Nizam College	Shanathi Bai Nursing Home	11kv	I	14.52	19.44	04.52	EL	No Visible Fault (Heavy Rain & Gale)	----
40	HYD C	Nizam College	Galaxy Hotel	11kv	I	14.52	19.08	04.16	EL,OL-Bph	HT Jumper cut at Galaxy Hotel	----
41	HYD C	Indira Park	Secretariat	11kv	I	14.40	16.30	01.50	EL	No Visible Fault (Heavy Rain & Gale)	----
42	HYD C	Indira Park	Domalguda	11kv	I	14.45	21.40	06.55	EL	4No. Trees fallen on lines at Street No.6,7 & Advocate Colony	----
43	HYD C	Indira Park	Himayath Nagar	11kv	I	15.05	16.20	01.15	EL	No Visible Fault (Heavy Rain & Gale)	----
44	HYD C	Lumbini Park	Avanthi Nagar	11kv	I	15.10	19.58	04.48	All Indication	No Visible Fault (Heavy Rain & Gale)	----
45	HYD C	Lumbini Park	Lokayuktha	11kv	I	15.10	18.05	02.55	All Indication	No Visible Fault (Heavy Rain & Gale)	----
46	HYD C	Lumbini Park	A.I.R.	11kv	I	15.10	19.35	04.25	All Indication	No Visible Fault (Heavy Rain & Gale)	----
47	HYD C	Lumbini Park	T.T.D.	11kv	I	15.10	18.05	02.55	All Indication	No Visible Fault (Heavy Rain & Gale)	----
48	HYD C	Lake View	Kapadiya Lane	11kv	I	14.49	16.05	01.16	EL	Tree branches fallen on lines at Kapadiya Lane	----
49	HYD C	N.I.M.S.	Erramanzil	11kv	I	15.05	19.35	04.30	OL	Tree branches fallen on lines at Erramanzil Colony	----
50	HYD C	Narayanguda	City Central Library	11kv	I	14.40	15.50	01.10	EL,OL-R&Bph	No Visible Fault (Heavy Rain & Gale)	----
51	HYD C	I.T.I Mallepally	Anwar Ul Uloom	11kv	VII	18.15	19.22	01.07	EL,OL	Jumper cut at Bada Masjid	----
52	HYD C	I.T.I Mallepally	Afzal Sagar	11kv	VII	18.10	19.16	01.06	EL,OL	No Visible Fault (Heavy Rain & Gale)	----
53	HYD C	Hyderguda	Abids	11kv	I	16.15	23.50	07.35	EL	Tree branches fallen on lines at Abids	----
54	HYD C	Hyderguda	Boggula Kunta	11kv	I	16.15	20.24	04.09	EL	Tree branches fallen on lines at Boggula Kunta	----

TSSPDCL - LMRC / Corporate office  
11KV BREAKDOWNS

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
55	HYD C	Nizam College	Babu Khan Estate	11kv	I	14.52	23.53	09.01	EL,OL-Bph	Faulty DTR at Babu Khan Estate	-----
56	HYD C	Nizam College	Galaxy Hotel	11kv	I	19.50	22.38	02.48	EL	Jumper cut at Chakni's Hotel	-----
57	HYD C	Indira Park	Ambedkar Nagar	11kv	I	14.50	22.05	07.15	EL	Tree branches fallen on lines at Anna DTR	-----
58	HYD C	Lumbini Park	A.P.Tourism	11kv	I	15.10	23.00	07.50	EL	No Visible Fault (Heavy Rain & Gale)	-----
59	HYD C	Vittalwadi	Commissioner Office	11kv	I	14.58	22.20	07.22	EL,OL-R&Bph	Tree branches fallen on lines at Krishna Kunj Apts	-----
60	HYD C	Vittalwadi	I.C.I.C.I.	11kv	I	15.02	21.10	06.08	EL,OL-Bph	HT Jumper cut at Highway Hotel	-----
61	HYD C	Vittalwadi	Kamineni Hospital	11kv	I	15.40	19.00	03.20	EL	HT Jumper cut at Boggula Kunta Water Works	-----
62	HYD C	Vittalwadi	Taj Mahal	11kv	I	16.30	21.50	05.20	EL,OL-R&Bph	No Visible Fault (Heavy Rain & Gale)	-----
63	HYD C	Z.P.Office	H.P.Sabha	11kv	I	16.23	18.07	01.44	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	-----
64	HYD C	Narayanguda	Narayanguda	11kv	II	14.45	17.05	02.20	EL	Faulty AB Switch at Narayanguda	-----
65	HYD C	Chilkaiguda	Musheerabad	11kv	I	15.14	19.40	04.26	EL,OL	HT Line snapped at Musheerabad X Road	-----
66	HYD C	Chilkaiguda	Parsigutta	11kv	II	14.50	16.40	01.50	EL	Tree branches fallen on lines at Parsigutta	-----
67	HYD C	Chilkaiguda	Parsigutta	11kv	II	16.58	18.45	01.47	EL	Tree branches fallen on lines at Gangaputra	-----
68	HYD C	Chilkaiguda	Golconda X Road	11kv	II	15.14	17.50	02.36	EL	Tree branches fallen on lines at Golconda X Road	-----
69	HYD C	Lake View	N.K.M's Hotel	11kv	I	16.15	20.50	04.35	EL	End Kit failed at Eenadu backside	-----
70	HYD C	Lake View	A.P.S.E.B.E.A.	11kv	I	16.15	19.15	03.00	EL	HT Jumpers cut at Various Location	-----
71	HYD C	Lake View	Dilkusha	11kv	I	16.55	20.40	03.45	EL	No Visible Fault (Heavy Rain & Gale)	-----
72	HYD C	Lake View	Katriya Hotel	11kv	I	15.45	21.50	06.05	EL	Pole damaged at Katriya Hotel	-----
73	HYD C	Golnaka	Tulsi Nagar	11kv	II	14.47	16.15	01.28	EL	Tree branches fallen on lines at Tulsi Nagar	-----
74	HYD C	Fever Hospital	Fever Hospital	11kv	II	16.00	17.10	01.10	EL,OL-Rph	Tree branches fallen on lines at S.N.Nagar	-----
75	HYD C	Fever Hospital	Nalla Kunta	11kv	II	14.50	16.30	01.40	EL,OL-R&Bph	No Visible Fault (Heavy Rain & Gale)	-----
76	HYD C	Fever Hospital	C.C.S.Hospital	11kv	II	14.49	16.10	01.21	EL,OL-Bph	No Visible Fault (Heavy Rain & Gale)	-----
77	HYD C	Fever Hospital	Sri Ram Nagar	11kv	II	14.50	17.36	02.46	Without Indication	Tree branches fallen on lines Opp. SS	-----
78	HYD C	Langerhouse	Military Hospital	11kv	VII	15.25	16.30	01.05	EL	No Visible Fault (Heavy Rain & Gale)	-----
79	HYD C	Z.P.Office	Seven Temple	11kv	I	20.10	21.58	01.48	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
80	HYD C	Exhibition	Jagadish Market	11kv	I	15.45	17.00	01.15	EL,OL	No Visible Fault (Heavy Rain & Gale)	-----
81	HYD C	Exhibition	Gandhi Bhavan	11kv	I	15.45	17.00	01.15	EL	No Visible Fault (Heavy Rain & Gale)	-----
82	HYD C	Exhibition	A.P.P.S.C	11kv	I	15.45	17.35	01.50	EL	No Visible Fault (Heavy Rain & Gale)	-----
83	HYD C	Exhibition	Collector Office	11kv	I	15.45	19.15	03.30	EL	No Visible Fault (Heavy Rain & Gale)	-----
84	HYD C	Exhibition	J.N.	11kv	I	15.45	20.20	04.35	EL	No Visible Fault (Heavy Rain & Gale)	-----
85	HYD C	A.C.Guards	Mahaveer OH	11kv	I	15.00	20.30	05.30	EL	Tree branches fallen on lines at A.C.Guards & Faulty DTR at Chit Chat Hotel	-----
86	HYD C	A.C.Guards	N.M.D.C.	11kv	VII	15.55	17.30	01.35	EL,OL-Rph	Tree branches fallen on lines at Hockey Ground	-----
87	HYD C	A.C.Guards	Care Hospital	11kv	I	15.00	19.44	04.44	EL	Tree branches fallen on lines at Care Hospital	-----
88	HYD C	A.C.Guards	Niloufer	11kv	VII	14.55	16.20	01.25	EL,OL-Rph	Tree branches fallen on lines & HT Line snapped at Niloufer Hospital	-----

TSSPDCL - LMRC / Corporate office  
33KV BREAKDOWNS

Date: 03.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effectcd	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Grid	33KV	Mahabubnagar	17.00	00.00	8.00		Not Rectified	Koilkonda Water Grid	-
2	MBNR	Amarchinta	Chandra Gattu Lift	33KV		18.33	00.00	05.27		Tree fallen on the 33KV line at Mohammedabad	Chandra Gattu Lift	-
3	MBNR	Puttapad	Nancherla	33KV	Narayanapet	18.00	19.25	01.25	E/L	Tree fallen on the 33KV line at Mohammedabad	Nancherla	-
4	MBNR	Gadwal	Dharoor	33KV	Gadwal	17.45	23.50	06.05	E/L	Tree Branches Fallen on the Line	Dharoor	-
5	MBNR	Gadwal	Nandinne	33KV		17.25	23.50	06.25	E/L	Due to Heavy Gale & Wind & AB Switch Opened at Peddapad(V)	Nandinne	-
6	MBNR	Gadwal	RWS	33KV		17.16	01.05	07.49	E/L	Due to Heavy Gale & Wind & AB Switch Opened at Revulapally	RWS	-
7	MBNR	leeza	Maddelabanda	33KV		21.40	00.00	02.20	O/L	Not Rectified	Maddelabanda	-
8	MBNR	leeza	Gattu	33KV		23.44	00.00	00.16	E/L&O/L	Not Rectified	Gattu	-
9	MBNR	leeza	Mittadoddy	33KV		23.25	00.00	00.35	E/L&O/L	Not Rectified	Mittadoddy	-
10	MBNR	Balanagar	G.R Cable	33KV		16.01	18.30	02.29	E/L	Due to Heavy Gale & Wind	G.R Cable	-
11	MBNR	Kothur	Thimmapur	33KV	Jadcherla	14.30	19.40	05.10	O/L	4Nos Insulator at Johnson& Johnson Company	Thimmapur	-
12	MBNR	Kothur	Raghavendra	33KV		15.50	19.30	03.40	O/L	Cable Fault in Jagruti Company	Raghavendra	-
13	MBNR	Kothur	P&G	33KV		16.20	20.35	04.15	O/L&E/L	Reconnecting Lug On at Tirupati Udyog Company	P&G	-
14	MBNR	Kothur	Natco Chemical	33KV		18.20	21.45	03.25	E/L	Jumper Cut in Natco Comapany	Natco Chemical	-
15	MBNR	Shadnagar	Mamidipally	33KV		16.00	19.40	03.40	E/L	Pin Binding Failed at 220KV SS Shadnagar	Mamidipally	-
16	MBNR	Shadnagar	Rayalseema	33KV		18.35	00.00	05.25	E/L&O/L	Not Rectified	Rayalseema	-
17	MBNR	Shadnagar	Stem Core	33KV		15.55	18.10	02.15	E/L&O/L	Clamp& Condcutor Snapping work at 220KVSS Shadnagar	Stem Core	-
18	MBNR	Midjil	Vemula	33KV	Nagarkurnool	15.50	23.50	08.00	E/L	Tree Fallen on the Line	Vemula	-
19	MBNR	Polepally	Gangapur	33KV		20.05	21.23	01.18		Due to Heavy Gale & Wind	Gangapur	-
20	MBNR	Nagarkurnool	Peddakothapally	33KV		19.12	20.17	01.05	E/L	Tree Fallen on the Line at Nakkalapally SS	Peddakothapally	-
21	MBNR	Singotam	Narsaipally	33KV	Nagarkurnool	16.32	00.00	07.28	E/L&O/L	Not Rectified	Narsaipally	-
22	MBNR	Singotam	Kollapur	33KV		16.37	00.00	07.23	E/L	Not Rectified	Kollapur	-
1	NLG	W.Kothapally	Thungathurty	33KV	Suryapet	17.40	00.00	06.20	E/L	Due to Heavy Gale and Wind	Thungathurty	-
2	NLG	Thungathurty	Phanigiri	33KV	Suryapet	17.30	00.00	06.30	E/L	Due to Heavy Gale and Wind	Phanigiri	-
3	NLG	Suryapet	Annaram	33KV	Suryapet	17.30	21.20	03.30	E/L	5No. 33Kv Insulator flashover	Annaram	-
4	NLG	K.M.Pally	Water grade	33KV	Devarakonda	15.25	17.05	01.40	E/L	1No. 33Kv Insulator Failed	Water grade	-
5	NLG	K.M.Pally	Neredugommu	33KV	Devarakonda	15.26	00.00	08.34	E/L	Due to Heavy Gale and Wind	Neredugommu	-
6	NLG	Kandhukur	Dindi	33KV	Devarakonda	15.46	00.00	08.14	E/L	Due to Heavy Gale and Wind	Dindi	-
7	NLG	Kanagal	Kopple	33KV	Devarakonda	17.20	00.00	06.40	E/L	Due to Heavy Gale and Wind	Kopple	-
8	NLG	Marriguda	T.P.Gouraram	33KV	Devarakonda	18.00	00.00	06.00	E/L	Due to Heavy Gale and Wind	T.P.Gouraram	-
9	NLG	HANMAPUR	MT PALLY	33KV	Bhongir	14.00	19.00	05.00	E/L	33Kv Insulator Failed	MT PALLY	-
10	NLG	HANMAPUR	ANANTHARAM	33KV	Bhongir	14.00	18.00	04.00	E/L	33Kv Insulator Failed	ANANTHARAM	-
11	NLG	HANMAPUR	MR GUDEM	33KV	Bhongir	14.00	19.00	05.00	E/L	33Kv Insulator Failed	MR GUDEM	-
12	NLG	BIBINAGAR	KONDAMADUGU	33KV	Bhongir	14.00	18.00	04.00	E/L	33Kv Insulator Failed	KONDAMADUGU	-
13	NLG	BIBINAGAR	VENKIRYALA	33KV	Bhongir	14.00	18.00	04.00	E/L	33Kv Insulator Failed	VENKIRYALA	-
14	NLG	MOTHKUR	AZIMPET	33KV	Bhongir	14.00	19.00	05.00	E/L	33Kv Insulator Failed	AZIMPET	-
15	NLG	Dilshancherla	Palakidu	33KV	Huzurnagar	17.45	21.45	04.00	O/L	Tree Fillan Line	Palakidu	-
16	NLG	Monagala	Betholu	33KV	Huzurnagar	16.15	17.30	01.15	E/L	Due to Heavy Gale and Wind	Betholu	-

TSSPDCL - LMRC / Corporate office  
33KV BREAKDOWNS

Date: 03.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
17	NLG	Ramapuram	Dondapadu	33KV	Huzurnagar	16.40	21.45	05.05	O/L	33Kv Insulator Failed	Dondapadu	-
18	NLG	Nalgonda	Velugupally(SLBC)	33KV	Nalgonda	15.30	00.00	08.30	E/L	Due to Heavy Gale and Wind	Velugupally(SLBC)	-
19	NLG	Nalgonda	Cheekatimamidi	33KV	Nalgonda	15.30	00.00	08.30	E/L	Due to Heavy Gale and Wind	Cheekatimamidi	-
20	NLG	Narkatpally	Eduloor	33KV	Nalgonda	15.30	00.00	08.30	E/L	Due to Heavy Gale and Wind	Eduloor	-
21	NLG	Shaligouraram	Nakrekal	33KV	Nalgonda	15.30	00.00	08.30	E/L	Due to Heavy Gale and Wind	Nakrekal	-
22	NLG	Miryalguda	Tripuraram	33KV	Miryalagudem	16.00	22.00	06.00	E/L	33Kv Insulator Failed	Tripuraram	-
23	NLG	Miryalguda	NATL	33KV	Miryalagudem	16.00	00.00	08.00	E/L	Due to heavy gale and wind	NATL	-
24	NLG	Miryalguda	Reddy's lab	33KV	Miryalagudem	16.00	21.45	05.45	E/L	33Kv Insulator Failed	Reddy's lab	-
25	NLG	Madgulapally	Laxmidevigudem	33KV	Miryalagudem	17.00	00.00	07.00	E/L	Due to heavy gale and wind	Laxmidevigudem	-
26	NLG	Madgulapally	Buggabaigudem	33KV	Miryalagudem	17.00	21.00	04.00	E/L	33Kv Insulator Failed	Buggabaigudem	-
27	NLG	Yerrabelli	Mupparam	33KV	Miryalagudem	14.20	17.45	03.25	E/L	Tree Fallen on Line	Mupparam	-
28	NLG	Yerrabelli	Kannekal	33KV	Miryalagudem	14.20	17.45	03.25	E/L	Tree Fallen on Line	Kannekal	-
1	MDK	Sadhashivapet	Koheer	33kv	Sangareddy	16.10	18.30	02.20		BD due to Insulators failed Alternate supply given from 132KV Zaheerabad	Koheer	-
2	MDK	Sadhashivapet	Jackwell	33kv		16.15	18.35	02.20		BD due to Tree fallen on line Alternate supply Arranged from Muniapally feeder	Jackwell	-
3	MDK	Bollaram	Shathavahana	33kv		15.45	20.20	04.35		BD due to Jumper cut & tree fallen on line	Shathavahana	-
4	MDK	Pashamailaram	SOL	33kv		15.35	21.30	05.55		BD due to Tree fallen on line	SOL	-
5	MDK	Pashamailaram	BOC	33kv		15.55	22.20	06.25		BD due to Tree fallen on line & Jumper cut	BOC	-
6	MDK	Pashamailaram	APL5	33kv		15.59	21.48	05.49		BD due to Tree fallen on line	APL5	-
7	MDK	Zaheerabad	Jharasangam	33kv	Zaheerabad	09.00	18.15	09.15		BD due to Tree fallen on line	Jharasangam	-
8	MDK	Narsapur	Arobindo	33kv	Medak	15.40	22.30	06.50		BD due to Tree fallen on line	Arobindo	-
1	SDPT	Chandlapur	Jakkapur	33kv	SDPT	14.06	15.32	01.26		Due to Heavy Rain	Jakkapur	-
2	SDPT	Gajwel	Ahmedipur	33kv	SDPT	13.45	19.55	07.10		Double pole damage	Ahmedipur	-
3	SDPT	Thukkapur	mettu	33kv	SDPT	16.20	18.15	01.55		Insulater Failed	mettu	-
4	SDPT	Thunki Bollaram	Vantimamidi	33kv	SDPT	15.18	17.52	02.34		Due to Heavy Rain	Vantimamidi	-
5	SDPT		Sitarampally	33kv	SDPT	15.18	17.52	02.34		Due to Heavy Rain	Sitarampally	-
6	SDPT		Markook	33kv	SDPT	14.35	16.20	01.45		Due to Heavy Rain	Markook	-
7	SDPT			33kv	SDPT	21.30	00.00	02.30		Still under B/D		-
8	SDPT	Musthayla	Tharigopulla	33kv	SDPT	16.30	17.45	01.15		Due to Heavy air	Tharigopulla	-
9	SDPT		Komuravelly	33kv	SDPT	02.30	07.25	04.55		Due to Heavy air	Komuravelly	-
10	SDPT			33kv	SDPT	16.50	19.50	03.00		Due to Heavy air		-
11	SDPT	Husnabad	Thotapally	33kv	SDPT	12.45	16.10	03.15		Insulater Failed	Thotapally	-
12	SDPT		Katkur	33kv	SDPT	14.55	16.05	01.10		Insulater Failed	Katkur	-
1	RR S	132kv RC Puram	33kv Giridharispat	33kv	RJNR	15.55	18.25	02.30	B/D	Breaker Fault	33kv Giridharispat	-