

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		8		8		8			
2	NLG	144	988		24		24		24			
3	MDK	107	933									
4	SDPT			3	10	2	10	2	10	1		33KV 1 No. Still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	42	2	42	2	42	1	0	
	Grand Total	1082	6468	3	50	2	50	2	50	1	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Appampally	11KV	Mahabubnagar	15.00	22.00	16.00		11KV Insulator Damage near Advi	No
2		Marikal	Madwar	11KV	Mahabubnagar	08.00	09.00	01.00		11KV Jumper cut Near Madwar	No
3		Marikal	Eligandla	11KV	Mahabubnagar	17.00	09.00	18.00		Tree fallen on conductor Near SS	No
4		Marikal	Ibrahimpattanam	11KV	Mahabubnagar	19.00	12.30	17.30		11KV Phase to Phase near Ibrahimpattanam	No
5		Marikal	Marikal town	11KV	Mahabubnagar	07.00	09.00	02.00		11KV Jumper cut Near SS	No
6		Marikal	Theelair	11KV	Mahabubnagar	17.00	19.00	02.00		11KV Phase to Phase near theelair	No
7		Dhanwada	Mandipally	11KV	Mahabubnagar	19:30	10:30	15:00		11KV Tree fallen on conductor at Mandipally (V)	No
8		Janampet	Polkampally	11KV	Jadcherla	07.45	09.16	01.31		11 KV Wire Cut Near Thimmapur(V)	No
1	NLG	Shivanagudam	S.R.Guda	11KV	Devarakonda	6:10	11:30	5:20	E/L	11 KV Disc failed	No
2		D.B.Pally	S.P.Thanda	11KV	Devarakonda	06.00	08.50	02.50	E/L	Tree Fallen	No
3		Singarajupally	Thwakalapur	11KV	Devarakonda	06.00	08.00	02.00	E/L	11KV Insuletor Failed	No
4		Angadipeta	R.R.Gudam	11KV	Devarakonda	06.00	10.45	04.45	E/L	11 KV Disc Fail	No
5		Angadipeta	Gudipally	11KV	Devarakonda	09.00	10.50	01.50	E/L	tree fallen	No
6		Koppel	A.B.Colony	11KV	Devarakonda	07.40	10.30	02.50	E/L	tree fallen	No
7		Koppel	L.D.Gudem	11KV	Devarakonda	07.40	10.10	02.30	E/L	tree fallen	No
8		Mamidala	Godavarigudam	11KV	Nalgonda	06.00	07.45	01.45	E/L	Heavy gale and wind effect	No
9		Akkenapally	Chinna Thumalagudam	11KV	Nalgonda	09.10	11.20	02.10	O/L	Heavy gale and wind effect	No
10		Akkenapally	Amanabolu	11KV	Nalgonda	09.00	11.00	02.00	E/L	Heavy gale and wind effect	No
11		Urumadla	Thala Velamla	11KV	Nalgonda	07.00	09.55	02.55	O/L	Heavy gale and wind effect	No
12		Nerada	Nerada AGL	11KV	Nalgonda	06.00	12.00	06.00	E/L	Heavy gale and wind effect	No
13		Cheekatimamidi	Velmakanne	11KV	Nalgonda	07.00	08.45	01.45	E/L	Heavy gale and wind effect	No
14		Nakrekal	Nomula	11KV	Nalgonda	07.00	10.00	03.00	O/L	Heavy gale and wind effect	No
15		Nakrekal	Chandupatla	11KV	Nalgonda	07.00	10.00	03.00	E/L	Heavy gale and wind effect	No
16		Kethepally	Korlapahad	11KV	Nalgonda	07.40	11.00	03.20	E/L	Heavy gale and wind effect	No
17		Kethepally	Inupamula	11KV	Nalgonda	07.00	09.00	02.00	E/L	Heavy gale and wind effect	No
18		Nagaram	Machireddy pally	11KV	Suryapet	02.40	08.30	05.50	E/L	Pole Damaged & Conductor snapped	No
19		Arvapally	Arvapally Agl	11KV	Suryapet	02.30	08.30	06.00	E/L	Jumper cut & Insulator flashover	No
20		Thirumalagiri	Thonda	11KV	Suryapet	02.30	09.30	07.00	E/L	Insulators flashover	No
21		Thirumalagiri	Thatipamula	11KV	Suryapet	02.40	08.45	06.05	E/L	Disc Flasover	No
22		Bondugula	Godumakunt	11KV	Bhongir	07.20	11.15	03.55	EL	somaram& godumakunta 11kv Insulator failed	No
23		Kandukur	Bhahupet	11KV	Bhongir	07.20	12.00	04.40	EL	11kv Insulator failed & Conductor burnt Mechanic Anjaneyulu Well	No
24		Solipet	Ramulthanda	11KV	Bhongir	8:00	9:40	1:40	EL	Insulator failed thimapur(v)	No

1	SDPT	Raghavapur	Bachaipally	11KV	Siddipet	15:35	18:45	3:10		11KV Wire cut	No
2		Chinthamadka	Chinthamadka	11KV	Siddipet	13.02	14.35	01.33		Jumper cut	No
3		Chinthamadka	Machapur	11KV	Siddipet	06.20	11.00	04.40		Disc failed	No
4		Peddacheekode	Peddacheekode	11KV	Siddipet	15.10	17.15	02.05		Tree branches fall on the 11 KV line	No
5		Gambeerpur	Gambeerpur	11KV	Siddipet	07.00	11.00	04.00		Tree branches fall on the 11 KV line	No
6		Gambeerpur	Shilajionagar	11KV	Siddipet	06.30	11.30	05.00		Pole Damage	No
7		Gambeerpur	Potharam	11KV	Siddipet	07.00	08.00	01.00		Tree branches fall on the 11 KV line	No
8		Mirdoddy	Mirdoddy	11KV	Siddipet	18.45	07.50	13.05		Disk failed	No
9		Thornal	Appanapally	11KV	Siddipet	17.10	10.10	17.00		Insulater failed	No
10		Thornal	Thornal	11KV	Siddipet	17.00	12.00	19.00		Tree branches fall on the 11 KV line	No
1	RR N	Jeedimetla-I	Phase-II	11KV	Jeedimetla	10:50	13:50	3:00	EL&OL	11KV AB Cable failed near Substation	No
2		Yellampet	IDA	11KV	Medchal	12.58	13.40	00.42	BD	Tree fallen on the 11KV Line at Rekula Bhavi	No
3		Nuthankal	Nuthankal	11KV	Medchal	13.20	14.25	01.05	BD	Breaker Mechanical Problem in SS	No
1	RR E	Aushpur	Edulabad	11KV	Keesara	7:00	13:00	6:00		3Nos Pin insulaotor failed at Edulabad village	No
1	HYD N	Lalaguda	Shanthi Nagar	11KV	Sec'bad	00.15	02.15	02.00	EL	Road Crossing Cable fault at Shanthi Nagar	No
2		Nehru Nagar	Contonment	11KV	Sec'bad	17:13	18:25	1:12	EL	No Visible Fault	Arranged B/F on 11KV Lalitha Nagar feeder
1	HYD S	Malakpet	Bibi Ka Alam	11KV	Asmangadh	03.15	04.18	01.03	EL	Cable fault	Partial loads arranged B/F on 11KV Yakuthpura fdr
2		Sulthan Bazar	Koti	11KV	Begumbazar	4:45	6:30	1:45	EL,OL-Rph	Cable fault Opp: Gokul Chat	No

