

TSSPDCL - LMRC / Corporate office

Date: 07.05.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Koppole	Koppole	11kv	Nalgonda	12.30	16.40	04.10	E/L	11KV jumper cut at village end	-
2		Phanigiri	Phanigiri Agl	11kv	Suryapet	10.25	11.50	01.25	O/L	Conductor Snapped	-
3		Dirsincherla	Dirsincherla	11kv	Huzurnagar	07.30	08.30	01.00	EL	Due to 11Kv Line cuuted near Dirsincherla village	-
4		Mukundapuram	Somaram	11kv	Huzurnagar	20.10	23.10	03.00	EL	Due to Jumper cutted near Somaram village	-
1	MDK	ISMAILKANPET	ARUTLA	11kv	Sangareddy	07.30	17.30	10.00		B/D DUE TO INSULATORS FAILED	-
2		CHERYAL	KANDI	11kv	Sangareddy	09.40	11.20	01.40		B/D DUE TO JUMPER CUT	-
3		MUNIPALLY	BUDERA	11kv	Sangareddy	07.20	11.19	03.59		B/D DUE TO JUMPER CUT	-
4		Lingapur	Lingapur	11kv	Medak	00.00	09.30	09.30		BD due to 11 KV Jumper Cut	-
1	RR N	Ravalkole	Ravalkole	11kv	Medchal	03.48	05.20	01.32	BD	Tree fallen on the 11KV Line at Cheruvkatta	-
1	HYD N	Allwyn	Mothi Nagar	11KV	IV	12.29	13.50	01.21	EL	Cable fault	Arranged B/F on 11KV Mothi Nagar fdr / Jana Priya SS

TSSPDCL - LMRC / Corporate office

Date: 07.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Kondapur	33kv	Mahabubnagar	16.15	18.05	01.50	O/L	Alternate Supply Arranged to Koilkonda Water Grid Feeder	Kondapur	-
2		Kodangal	Peddandandigama	33kv	Mahabubnagar	17.35	22.15	04.40	E/L	Alternate Supply Arranged to Kodangal Feeder	Peddandandigama	-
3		Kodangal	Kothur	33kv	Mahabubnagar	18.10	19.00	00.50	E/L	Alternate Supply Arranged to Bomraspet Feeder	Kothur	-

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		3				
2	NLG	144	988		4		4		4			
3	MDK	107	933		4		4		4			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	8	3	8	3	8	0	0	
	Grand Total	1082	6468	3	10	3	10	3	10	0	0	