

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT				13		13		13			
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	16	0	16	0	16	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	(Within 24)		(Above 24)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933		4		4		4			
4	SDPT			2		2		2				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	2	22	2	22	2	22	0	0	

TSSPDCL - LMRC / Corporate office

Date: 08.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Thukkapur	Dommata	33KV	Gajwel	16.25	18.20	01.55		Tree fallen on Line	Dommata	-
2		Shanigaram	Bejjanki	33KV	Husnabad	15.30	00.00	08.30		Pole broken	Bejjanki	Supply taken from begumpet ss

TSSPDCL - LMRC / Corporate office

Date: 08.05.2018

S.No	Circle	Name of	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	Dubba Thanda	11KV	Suryapet	07.25	09.30	02.05	O/L	Bird fallen on the line	-
2		Marriguda	Konduru	11KV	Devarakonda	18.30	23.30	05.00	E/L	3-PH DTR Failed at Konduru	-
1	MDK	Thogita	Aurangabad	11KV	Medak	13.29	16.32	03.03		B/d due to tree fallen on 11KV wire	-
2		Venkatraopet	Venkatraopet	11KV	Medak	09.30	11.05	01.35		B/d due to Jumper conductor cut.	-
3		Rajpet	Thimmapur	11KV	Medak	06.35	10.35	04.00		B/d due to insulater fail	-
4		Gadipeddapur	Gadipeddapur	11KV	Medak	14.00	16.30	02.30		B/d due to 11 KV line cut at bijilipur	-
1	Siddipet	Pedda Chepyal	Alwal	11KV	SIDDIPET	15.30	18.05	02.35		Heavy wind & gale, poles broken	-
2		AKKANAPET	GOLLAKUNTA	11KV	HUSNABAD	13.05	16.35	03.30		B/D TREE BUNCH FALLEN ON LINE	-
3		GANDIPALLY	GANDIPALLY	11KV	HUSNABAD	00.00	06.40	06.40		B/D INSULATOR FAILED	-
4		GOURAVELLY	GUDATIPALLY	11KV	HUSNABAD	07.35	09.45	02.10		B/D JUMPER CUT	-
5		BEJJANKI	KALLLEPALLY	11KV	HUSNABAD	17.15	18.00	00.45		B/D JUMPER CUT	-
6		BEJJANKI	BEJJANKI & RWS	11KV	HUSNABAD	20.00	20.30	00.30		B/D WIRE BINDING	-
7		GUGGILLA	GUGGILLA	11KV	HUSNABAD	16.20	16.35	00.15		B/D 1 PHASE OK	-
8		GUGGILLA	THIMMAIPALLY	11KV	HUSNABAD	16.20	20.16	03.56		B/D LINE BINDING	-
9		REGULAPALLY 1X5 MVA	REGULAPALLY	11KV	HUSNABAD	12.50	13.50	01.00		B/D DUE TO GAIL AND WIND	-
10		REGULAPALLY 1X5 MVA	REGULAPALLY	11KV	HUSNABAD	15.30	18.30	03.00		B/D POLE BROKEN	
11		SAMUDRALA	SAMUDRALA (R)	11KV	HUSNABAD	17.00	17.20	00.20		B/D LT LINE BINDING	
12		Komuravelly	Kistampet	11KV	HUSNABAD	13.05	15.30	02.25		B/D PEACOCK FALLEN ON LINE	
13		Komuravelly	Inapur 24 hrs	11KV	HUSNABAD	10.40	11.30	00.50		B/D LINE SNAPPED	
1	RR N	GP Pally	GP Pally	11KV	Medchal	09.00	10.00	01.00	BD	Bird Fallen on the 11KV Line at Ayodhaya	-
1	HYD S	Salarjung	Sadath Nagar	11KV	VIII	15.22	16.46	01.24	EL,OL-Yph	Cable fault	11KV Murtuza Ngr
2		Salarjung	Q.Q Stadium	11KV	III	23.30	01.00	01.30	EL,OL-Bph	DTR Cable fault near City College	-----