

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		7		7		7			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	12	0	12	0	12	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	7		2		2		5		
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	8	6	3	6	3	6	5	0	
	Grand Total	1082	6468	8	18	3	18	3	18	5	0	

TSSPDCL - LMRC / Corporate office

Date: 12.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Devarkadra	33KV	Mahabubnagar	20.25	24.00	#VALUE!	E/L	Pin insulator failed	Marikal	Alternate Supply Arranged from 33KV Koukuntla feeder at 20.30 hrs
2		Wanaparthy	Buddaram	33KV	Wanaparthy	22.49	05.50	7.01	E/L	lines twisted	Wanaparthy	-
3		Wanaparthy	Rajapur	33KV	Wanaparthy	22.55	24.00	#VALUE!	E/L		Wanaparthy	-
4		Gadwal	Dharoor	33KV	Gadwal	22.40	24.00	#VALUE!	E/L		Gadwal	-
5		Gadwal	RWS	33KV	Gadwal	22.40	24.00	#VALUE!	E/L		Gadwal	-
6		Balanagar	G R Cable	33KV	Jadcherla	14.40	16.45	02.05	E/L	No Visible fault supply stude OK	Balanagar	Jumper open at Rangareddy guda DTN industri
7		Ghanapur	Lattupally	33KV	Nagarkurnool	21.44	24.00	#VALUE!	E/L		Ghanapur	Alternate Supply Arranged from 33KV Bijinepally feeder at 23.50 hrs
1	NLG	HANMAPUR	MT.PALLY	33KV	Bhongir	07.15	09.05	01.50	E/L	33Kv Insulater Failed Near Rampur (V)	HANMAPUR	-

TSSPDCL - LMRC / Corporate office

Date: 12.05.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	G.T. Giri	Namavaram	11KV	Suryapet	07.00	09.15	02.15	E/L	11Kv Jumper Cut Near ss-8	-
2		Gondriyala	Chimiryala	11KV	Huzurnagar	10.55	14.00	03.05	OL	11Kv in snapped near Chimiryala (v)	-
3		S.Gouraram	S.Gouraram	11KV	Nalgonda	02.00	07.00	05.00	E/L	11KV Jumper Cut at S.Gouraram (V)	-
4		PALDUGU	INDASTIAL	11KV	Bhongir	08.00	12.30	04.30	E/L	Heavy Gale & Wind 11KV POLSE DAMAGED	-
1	MDK	Reddypally	Khajipet	11KV	Medak	14.15	17.40	03.25		B/D due to CONDUCTOR SNAPPED	-
2		Gavvalapally	Achampet	11KV	Medak	07.25	09.30	02.05		B/D due to Jumper cut	-
1	RR N	J D M SS-I	Shapurnagar	11KV	Jeedimetla	07.55	08.55	01.00	OL	Tree branches Fallen On The 11kv Line At Mansa Food	-
2		J D M SS-I	CS Wire	11KV	Jeedimetla	20.00	21.00	01.00	EL & OL	11Kv AB Cable Failure at Deepak Nitrate Unit Phase-I Pipe Line Road	-
3		Subash Nagar	Ramraj nagar	11KV	Medchal	08.40	09.40	01.00	BD	Tree fallen on the 11KV Line at OM Books	-
4		Keshavaram	Keshavaram	11KV	Medchal	09.10	11.25	02.15	BD	11KV Line cut and replaced at Dairy Company	-
5		Aliabad	Jaganguda	11KV	Medchal	09.27	11.20	01.53	BD	Tree fallen on the 11KV Line at ALFA MED Company	-
6		Bommarajpet	Karkamma	11KV	Medchal	09.20	11.27	02.07	BD	100KVA T/F LT Pole Damaged & 11KV Line Cut at Ramana Reddy Thota	-
7		Bommarajpet	Ponnal	11KV	Medchal	09.28	12.10	02.42	BD	Tree fallen on the 11KV Line at Pochamma Temple	-
1	RR E	VP Nagar	RK Puram	11KV	Sainikpuri	09.40	11.00	01.20		11Kv post of Insulator failed at RK Puram Bridge (LM Chandra Shekar)	-
2		Moula-Ali	Venkateshwar Nagar	11KV	Sainikpuri	18.53	19.26	00.33		Ground petrolling done but no visible fault found (Foc Srinu)	-
3		Yadgarapally	Yadgarapally	11KV	Habsiguda	10.30	12.10	01.40		11kv line cut at Outer Ring Road	-
1	HYD C	Golnaka	Moulana Azad Nagar	11KV	Azamabad	09.58	11.30	01.32	OL-Rph	Cable fualt	-
2	HYD S	E.N.T	Rang Mahal	11KV	Begumbazar	22.50	00.10	01.20	EL	No Visible fault	-