

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	27	3	27	3	27			
2	NLG	144	988		4		4		4			
3	MDK	107	933		1		1		1			
4	SDPT			1	9	1	9	1	9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	41	4	41	4	41	0	0	
	Grand Total	1082	6468	4	45	4	45	4	45	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Kondapur	33kv	Narayanapet	00.30	12.10	11.40	E/L	Replacement of 8 Poles 2no Disc and 12 Pin insulator replaced	Kondapur	-
2		Marikal	Koilkonda Water Grid	33kv	Narayanapet	10.32	13.45	03.13	E/L	Pin insulator replaced Chandapur Village	Koilkonda Water Grid	-
3		Nagarkurnool	Peddakothapally	33kv	Nagarkurnool	11.30	13.26	01.56	E/L	33KV Line Phase to Phase near Janalabaguda Village at Peddakothapally	Peddakothapally	-
1	SDPT	Chandlapur	Jakkapur	33kv	SDPT	11.30	02.05	02.35		insulator failed	Jakkapur	

TSSPDCL - LMRC / Corporate office

Date: 13.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothapally	Dupally	11KV	Mahabubnagar	19.15	23.00	03.45		11KV Phase to Phase at dupally (Vi)	-
2		Kothapally	Gopanpet	11KV	Mahabubnagar	19.30	23.20	03.50		11KV Tree fallen on conductor at Karnee (vi)	
3		Koukuntla	b) Muchinthalla	11KV	Mahabubnagar	06.00	09.05	03.05		11KV Phase to Phase at muchinthalla (Vi)	
4		Koukuntla	c) Gopanpally	11KV	Mahabubnagar	07.30	10.55	03.25		11KV pole damage at jingarala (Vi)	
5		Kurumurthy	e) Maddur	11KV	Mahabubnagar	23.00	11.00	12.00		11KV pole damage at Wagugandi (Vi)	
6		Devarkadra	b) Lalkota	11KV	Mahabubnagar	18.30	13.00	18.30		11KV pole damage near lalkota (Vi)	
7		Devarkadra	a) Koilsagar	11KV	Mahabubnagar	18.00	12.00	18.00		11KV pole damage near gurakonda (Vi)	
8		Devarkadra	e) Gudibanda	11KV	Mahabubnagar	18.00	12.00	18.00		11KV Tree fallen at gudibanda (Vi)	
9		Kotakonda	Thirumalapur	11KV	Mahabubnagar	22.30	23.30	01.00		Heavy gale wind	
10		Narwa	Undekode	11KV	Mahabubnagar	18.30	09.30	15.00		11Kv Poles Damaged	
11		Kaverammamet	Bandamidipally	11KV	Jadcherla	18.00	22.00	04.00		11Kv Jumper cut near Bandamidipally	
12		Kaverammamet	Town	11KV	Jadcherla	18.00	09.00	15.00		Poles Brokan near Town and Bandamidipally	
13		Jadcherla	Badepally	11KV	Jadcherla	19.30	22.50	03.20		11Kv Jumper cut near Badepally	
14		Jadcherla	Mallaboipally	11KV	Jadcherla	18.20	22.20	04.00		11Kv Jumper cut near Mallaboipally	
15		Rajapur	Mallepally	11KV	Jadcherla	18.00	22.20	04.20		Tree follon the line near Mallepally	
16		Kothamolgara	Kothamolgara	11KV	Jadcherla	18.00	22.00	04.00		11Kv Jumper cut near Kothamolgara	
17		Kaverammamet	Industrial	11KV	Jadcherla	18.00	16.30	22.30		Poles Damaged At Polepally Industrial	
18		Jadcherla	Nagasala	11KV	Jadcherla	19.30	11.55	17.00		11 Kv Insulator Failure And Tree Follen On The 11 Kv Line Near Cherlapally.	
19		Jadcherla	Burgupally	11KV	Jadcherla	19.30	16.00	22.00		11 KV Insulator Failure Near Burgupally Tanda.	
20		Polepally	Vallur	11KV	Jadcherla	18.20	09.30	15.00		11 Kv Phase To Phasae Near Chinnapally	
21		Janampet	Moosapet(13.05.2018)	11KV	Jadcherla	07.30	09.30	02.00		AB Switch Jumper Touched By The 11 Kv Line Near Achaiahpally(Vi).	
22		Kothamolgara	Karvena	11KV	Jadcherla	18.00	11.00	17.00		11 Kv Disc fail Praveen DTR Side Kothamolgara	
23		Kothamolgara	Elkicherla	11KV	Jadcherla	18.00	11.00	17.00		11 Kv Pinbinding Failure Near Mabbav Elkicherla.	
24		Kothamolgara	Madigatla	11KV	Jadcherla	18.00	11.00	17.00		11 Kv Poles Damaged At Hanuman Temple Maddigatla.	
25		Kothamolgara	L and T Town feedar	11KV	Jadcherla	19.00	09.00	14.00		11 Kv Wire Cut Touched By The Crissarm Near Kanal Side Kothamolgara(Vi).	
26		Addakal	Thimmaipally	11KV	Jadcherla	19.10	09.56	15.00		11 Kv Poles Damaged At Kothapally.	
27		Addakal	Gudibanda	11KV	Jadcherla	19.10	08.20	13.00		Lt wires Cut Follen The Near Govt School Gudibanda(VI).	
1	NLG	Ambedkar nagar	Ambedkar nagar	11KV	Suryapeta	15.30	17.30	02.00	E/L	Jumper cut	-
2		Addagudur	Addagudur	11KV	Bhongiri	06.20	09.20	03.00	E/L	Insulator failure	-
3		Gondiryala	Chimiryala	11KV	Huzurnagar	02.00	05.00	03.00	E/L	11KV Snapped	-
4		Ananthagiri	Shanthi nagar	11KV	Huzurnagar	08.30	10.30	02.00	E/L	Jumper cut	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Sangareddy Town -II	No.2	11KV	Sangareddy	07.50	09.20	01.30		B/D due to Conductor snapped Near Kalabgoor (V).	-
1	SDPT	Habsipur	Habsipur	11KV	SDPT	17.30	06.00	11.30		tree fallen on 11 kv line	
2		Mustabad X Road	Kotilingalu	11KV	SDPT	05.00	05.35	00.35		11 KV wire Netting	
3		Mirdoddy	Andhey	11KV	SDPT	15.10	16.40	01.30		Jumper Cut Location at Ramula temple	
4		33/11KV SS POTHARAM	POTHARAM TOWN	11KV	SDPT	08.00	11.00	03.00		B/D 11KV JUMPER CUT	
5		33/11KV SS THOTAPALLY	KONDAPUR	11KV	SDPT	05.00	11.00	06.00		B/D 11 KV JUMPER CUT	
6		33/11KV SS BASWAPUR	BASWAPUR (R)	11KV	SDPT	04.50	08.00	03.10		B/D TREE BRANCH FALL	
7		33/11KV SS Komuravelly	Komuravell 24 Hrs	11KV	SDPT	12.05	12.45	00.40		B/D TREE BRANCH FALL	
8			Posanpally	11KV	SDPT	10.35	12.10	01.35		B/D CONDUCTER SNAPPED	
9		33/11KV SS Marmamula	Salakpoor	11KV	SDPT	05.15	06.05	00.50		B/D LINE SNAPPED	
1	RR N	Jeedimetla-II	N R S A	11KV	Jeedimetla	15.55	17.00	01.05	EL&OL	11kv AB Cable Endy Kit Failure At Shathavahana Packing Phase_4	-
2		Jeedimetla-II	N R S A	11KV	Jeedimetla	19.47	21.00	01.13	EL&OL	11kv Ab Cable Failure At Phase-4	-
1	HYD S	Yakuthpura	Murthuza Nagar	11KV	VIII	09.15	10.38	01.23	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Moulaka Chilla fdr
2	HYD C	Industrial Area	Mother Dairy	11KV	II	21.10	22.20	01.10	EL,OL-Rph	Cable fault at Ram Nagar	Arranged B/F on 11KV 44 Bus Depot fdr