

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		10		10		10			
6	RR(N)	54	550		19		19		19			
7	RR(E)	168	403									
8	Hyd	194	1044	2	258	2	258	2	258			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>2</b>	<b>287</b>	<b>2</b>	<b>287</b>	<b>2</b>	<b>287</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	9		9		9				
2	NLG	144	988		4		4		4			
3	MDK	107	933	7	7	7	7	7	7			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>16</b>	<b>11</b>	<b>16</b>	<b>11</b>	<b>16</b>	<b>11</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>18</b>	<b>298</b>	<b>18</b>	<b>298</b>	<b>18</b>	<b>298</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 17.05.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Hanwada	33KV	Mahabubnagar	17.48	20.00	02.12	EL	Insuator failed and supply stude OK.	Hanwada	Alternate Supply Arranged from 132KV Puttapad SS
2		Maddur	Kothapally	33KV	Narayanapet	19.30	21.20	01.50	EL	No visible fault Supply Stude OK	Kothapally	Alternate supply arranged from 33KV Vepur SS
3		Maddur	Vepur	33KV	Narayanapet	19.30	20.40	01.10	EL	Pin Binding damaged at Kothapally	Vepur	No
4		Wanaparthy	Buddaram	33KV	Wanaparthy	16:20	23:35	7:15		Breaker problem at 132KV WNP	Buddaram	Tag on to 33KV kothakota feeder
5		Gadwal	Nandinne	33KV	Gadwal	17:27					Nandinne	
6		Gadwal	Rws	33KV	Gadwal	17:59	0:41	6:42		Tree branch fallen on the line near Chinnatarevally	Rws	No
7		Balanagar	G.R Cable	33KV	Jadcherla	18:05	19:55	1:50	EL	No visible fault Supply Stude OK	G.R Cable	Jumper opened at Rangareddy guda (V)
8		Polepally	Gangapur	33KV	Jadcherla	16:30	19:40	3:10	EL	Tree fallen on the line at JDCL	Gangapur	No
9		Polepally	Jadcherla	33KV	Jadcherla	16.30	19.03	02.33	EL	Disc failed and Replaced at Kavarampet	Jadcherla	No
1	MDK	Kandhi	Aradhana	33KV	Sangareddy	15:05	17:45	2:40		No visible fault	Aradhana	No
2		Pashamailaram	SOL	33KV	Sangareddy	15.15	18.56	03.41		BD Due to disc failed	SOL	No
3		Bollaram	Agarwal Globle Steel	33KV	Patancheru	15.10	16.45	01.35		BD Due to heavy wind & Gale Insulator failed	Agarwal Globle Steel	No
4		Bollaram	Coca Cola	33KV	Patancheru	15.10	18.50	03.40		BD Due to heavy wind & Gale Insulator failed	Coca Cola	No
5		Bollaram	Shathavahana	33KV	Patancheru	15.10	17.10	02.00		BD Due to Tree fallen on the line	Shathavahana	No
6		Gummadidala	GPSS-1	33KV	Patancheru	15.35	18.25	02.50		BD Due to Tree fallen on the line	GPSS-1	No
7		Gummadidala	GPSS-2	33KV	Patancheru	14:50	19:20	4:30		BD Due to heavy wind & Gale Insulator failed	GPSS-2	No
1	HYD S	220KV Osm. University	Lalaguda	33KV	Chilalguda	02.00	02.15	00.15	OL	Cable damaged digging by L&T near Tarnaka Chowrastha	Lalaguda	Loads transferred onto 220KV Osm. University SS via 33KV S.C.R. fdr
2		220KV Ch' Gutta	D.R.D.L.	33KV	Malakpet	17:12	20:09	2:57	EL	Tree fallen on the line	D.R.D.L.	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	Mukundapuram	11KV	Suryapeta	12:30	14:30	2:00	E/L	Conductor snapped	No
2		Pamangundla	Pittampally	11KV	Nalgonda	12.40	13.50	01.10	E/L	11KV Line cut	No
3		Pamangundla	Ismailpally	11KV	Nalgonda	09.00	10.35	01.35	E/L	11 KV Disc failed	No
4		Repala	Narsimhulagudem	11KV	Huzurnagar	12.40	15.00	02.20	E/L	11KV Line cut	No
1	MDK	Cheryal	Turbovent	11KV	Sangareddy	16:20	20:15	3:55		BD Due to Tree fallen on line	No
2		Bollaram II	Kottam	11KV	Patancheru	15.15	18.08	02.53		BD Due to Tree fallen on line	No
3		Bollaram II	Vasagatta	11KV	Patancheru	15.15	18.08	02.53		BD Due to Tree fallen on line	No
4		Bollaram II	Rupa	11KV	Patancheru	15.15	19.12	03.57		BD Due to Tree fallen on line	No
5		Thogita	Aurangabad	11KV	Medak	06.22	07.45	01.23		B/d due to conductor snapped	No
6		Thogita	Kuchanpally	11KV	Medak	11.20	12.15	00.55		B/d due to conductor snapped	No
7		Seelampally	Chilipched	11KV	Medak	14:30	15:33	1:03		B/D due to 11 KV Jumper cut.	No
1	RR S	Gaganpahad	Gaganpahad	11KV	RJNR	16:58	18:05	1:07		No Visible Fault Due To heavy Rain wind and Gale	No
2		Gaganpahad	Jaibhavani	11KV	RJNR	16.58	18.25	01.27		11kv Insulator failed at Venkateshwara Flexo Company	No
3		Kattedan-II	New citizenkanta	11KV	RJNR	16.53	18.02	01.09		11kv Insulator failed at new citizenkanta	No
4		Chandanagar	Taranagar	11KV	GCB	15.10	18.10	03.00		11KV Line Phase to Phase line touched at Pochamma Temple.	No
5		Chandanagar	HUDA Colony	11KV	GCB	16.40	17.40	01.00		11KV Line AB Switch Sparked at Radha Krishna Apartment.	No
6		KPHB	6th Phase	11KV	GCB	16.31	18.15	01.44		11KV Disc failed near HIG - 337 at 6th Phase.	No
7		Nanakramguda	Manjeera Daimond	11KV	GCB	15.45	19.17	03.32		11KV AB Cable Failure to Replacement near Gopanpally Thanda.	No
8		IIIT	GPRA	11KV	GCB	15.54	17.16	01.22		Tree branches fallen on the 11KV line near Indian Bank at Indra Nagar.	No
9		Gachibowli	Gopanpally	11KV	GCB	16.20	17.40	01.20		11KV Line Phase to Phase at Sai Raghavendra near lorry Shed.	No
10		Mathrusrinagar	Kalyan Garden	11KV	GCB	16:05	17:10	1:05		11KV Line AB Switch opened at Ujwala Plywood. 11Kv Disc failed near Bommarillu Function Hall.	No
1	RR N	Mayurinagar	Iaxminagar	11KV	Kukatpally	15:40	16:50	1:10		Due to rain	No
2		JTPL	RTC Colony	11KV	Kukatpally	15.30	17.30	02.00		11kv line Pin Insulater failed at RTC Colony	No
3		Mayurinagar	Mayurinagar	11KV	Kukatpally	21.30	22.30	01.00		Lorry Touched 11kv line at Indiramma House	No
4		Guntur Vikas	Volvo	11KV	Kukatpally	15.43	17.55	02.12		Tree braches fallen on the 11kv line near Volvo Gate	No
5		Guntur Vikas	Apparana	11KV	Kukatpally	15.43	17.52	02.09		Tree brachesh fallen on the 11kv line	No
6		VemanaColony	Bhavanipuram	11KV	Kukatpally	15.20	16.00	00.40		HT/LT Lt line Pole Damedged	No
7		Nizampet	Bandari Lay Out	11KV	Kukatpally	15.00	16.26	01.26		Due to rain	No
8		Nizampet	Rajadhani School	11KV	Kukatpally	15.00	16.20	01.20		Due to rain	No
9		Nizampet	Journalist Colony	11KV	Kukatpally	15.10	16.20	01.10		Due to rain	No
10		JDMSS-V	Wing Tools	11KV	Jeedimetla	15.15	17.30	02.15		11kv line Endkit failed	No
11		JDMSS-I	Phase-II	11KV	Jeedimetla	14.32	16.23	01.51		Jumper cut & Tree branches fallen on the 11kv line	No
12		Suraram	Sai Baba Nagar	11KV	Jeedimetla	15.17	17.00	01.43		11kv line Endkit failed	No
13		Suraram	Matrix	11KV	Jeedimetla	16.22	17.55	01.33		Jumper cut	No

14		DPPally	Bowrampet	11KV	Jeedimetla	15.40	19.23	03.43		Tree brachesh fallen on the 11kv line	No
15		DPPally	Gagillapur	11KV	Jeedimetla	15.50	19.40	03.50		Tree brachesh fallen on the 11kv line	No
16		Medchal	Victory	11KV	Medchal	14.50	16.40	01.50		11KV Pin Insulator failed near Sumangali Aluminium Company	No
17		Dulapally	IDA-I	11KV	Medchal	15.22	16.52	01.30		Tree brachesh fallen on the 11kv line	No
18		Gowdavelly	Basaragadi	11KV	Medchal	16.00	17.52	01.52		11KV Pin insulator failed	No
19		Bandamadaram	Srirangavaram	11KV	Medchal	19:55	23:45	3:50		11KV Pin Insulator and Disc failed near Srirangavaram Village	No
1	HYD N	Tirumalagiri	Srinagar Colony	11KV	VI	15.44	17.20	01.36	All Indication	Tree branches fallen on lines at Foot Ball Ground	No
2		Sanjeevaiah Park	Patigadda Quarters	11KV	IV	16:27	17:50	1:23	EL	Tree branches fallen on lines at Auto Stand	No
3		Yellareddyguda	Akber Form	11KV	X	15:50	17:20	1:30	EL	No Visible Fault due to heavy rain & wind	No
4		Addagutta	Ambedkar Nagar	11KV	V	15:45	17:35	1:50	EL	No Visible Fault due to heavy rain & wind	No
5		Addagutta	Shanthi Niketan	11KV	V	15:35	17:30	1:55	OL-Bph	Tree branches fallen on lines at Shanthi Niketan	No
6		Addagutta	Tagore Home	11KV	V	15:45	21:45	6:00	EL	Tree branches fallen on lines at Manju Apts	No
7		Patigadda	Sanjeevaiah Park	11KV	V	15:38	19:10	3:32	EL,OL	HT Cable Jumper cut at Sanjeevaiah Park & Tree branches fallen on lines at Opp: Yogi Bear	No
8		Zamistanpur	Sanjeevapuram	11KV	V	15:40	17:55	2:15	All Indication	DTR fault at Grave Yard, Sunnam Batti	No
9		Zamistanpur	MCH Park	11KV	V	15:48	20:23	4:35	EL,OL-Rph	Pin Insulator flash over at P.R Nagar Park	No
10		Lalaguda	Vijayapuri	11KV	V	15:30	17:10	1:40	EL	No Visible Fault due to heavy rain & wind	No
11		Lalaguda	Chenna Reddy	11KV	V	15:45	16:55	1:10	EL,OL-Bph	Tree branches fallen on lines at Badam Apts	No
12		Lalaguda	Lalapet	11KV	V	15:30	17:33	2:03	EL	No Visible Fault due to heavy rain & wind	No
13		Lalaguda	Nagarjuna Nagar	11KV	V	15:40	17:45	2:05	EL	Tree branches fallen on lines at S.S Heights Apts	No
14		R.P.Nilayam	Vaishnavi Matha	11KV	VI	16:20	18:20	2:00	EL	Tree branches fallen on lines at Satya Complex	No
15		R.P.Nilayam	Venkatapuram	11KV	VI	16:30	18:20	1:50	EL	No Visible Fault due to heavy rain & wind	No
16		Chilikalguda	Bhokalpur	11KV	V	15:40	19:45	4:05	EL	No Visible Fault due to heavy rain & wind	No
17		Chilikalguda	P.R.Nagar	11KV	V	15:40	18:10	2:30	EL	No Visible Fault due to heavy rain & wind	No
18		Chilikalguda	Dandu Pentaiah	11KV	V	15:40	19:30	3:50	EL	No Visible Fault due to heavy rain & wind	No
19		Chilikalguda	New Boiguda	11KV	V	15:40	18:20	2:40	EL	No Visible Fault due to heavy rain & wind	No
20		Chilikalguda	Pragatools	11KV	V	15:40	20:00	4:20	EL	Tree branches fallen on lines at Pragatools	No
21		Chilikalguda	Water Works	11KV	V	15:40	17:40	2:00	EL	No Visible Fault due to heavy rain & wind	No
22		Road No.2	Lumbini Mall	11KV	X	15:27	18:24	2:57	EL	Tree branches fallen on lines at Sagar Society	No
23		Gymkhana	Mud Fort	11KV	V	15:45	18:40	2:55	All Indication	Bus Coupler Bph Red hot at SS	No
24		Gymkhana	Apollo	11KV	V	15:45	19:45	4:00	All Indication	Tree branches fallen on lines at Various locations	Arranged Partial loads on 11KV Vikrampuri feeder
25		Gymkhana	Pared Ground	11KV	V	15:45	20:05	4:20	All Indication	3No. Poles fell down at Pared Ground	Only partial fdr charged
26		Road No.3	Amrutha	11KV	X	15:31	17:32	2:01	EL,OL	Tree branches fallen on lines at Road No.14	No
27		Road No.3	Nandi Nagar	11KV	X	15:32	17:00	1:28	EL	No Visible Fault due to heavy rain & wind	No
28		Road No.3	Times of India	11KV	X	15:35	17:45	2:10	EL	HT Line snapped at Road No.3	No
29		Road No.3	Meridian	11KV	X	16:19	17:35	1:16	EL	Tree branches fallen on lines at Road No.7	No
30		Gunrock	Anjaiah Nagar	11KV	VI	15:50	18:20	2:30	EL,OL	Tree branches fallen on lines	Arranged B/F on 11KV Lal Bazar fdr
31		Gunrock	Tirumalagiri	11KV	VI	15:45	18:20	2:35	EL,OL	Tree branches fallen on lines	Arranged B/F on 11KV Surya Enclave fdr

32	Osm. University	Osm. University	11KV	V	15:45	17:05	1:20	EL	No Visible Fault due to heavy rain & wind	No
33	Osm. University	Mettuguda	11KV	V	15:50	21:45	5:55	OL-R&Yph	Tree branches fallen on lines at Mettuguda	No
34	Osm. University	Ladies Hostel	11KV	V	15:55	21:30	5:35	OL-Bph	Tree branches fallen on lines at Stadium	No
35	Osm. University	Keshav Nagar	11KV	V	15:55	18:50	2:55	EL	Tree branches fallen on lines at Keshav Nagar	No
36	Nehru Nagar	Contonment	11KV	V	16:15	0:10	7:55	EL,OL-Rph	Tree branches fallen on lines at Street No.3	No
37	Nehru Nagar	West Marredpally	11KV	V	16:18	23:05	6:47	EL,OL-Rph	Tree branches fallen on lines at Street No.3	No
38	Nehru Nagar	Teachers Colony	11KV	V	16:21	20:48	4:27	EL	Tree branches fallen on lines at Street No.3	No
39	Road No.12	Kanaka Durga Temple	11KV	X	15:30	18:35	3:05	EL	Faulty 3Way RMU at Kotak Bank	No
40	Road No.12	N.B.T.Nagar	11KV	X	15:46	17:35	1:49	EL	No Visible Fault due to heavy rain & wind	No
41	Road No.12	C.R.P.F.	11KV	X	15:40	17:55	2:15	All Indication	Tree branches fallen on lines at Renuka Chowdary's House	No
42	Clock Tower	Minerva	11KV	V	16:26	18:52	2:26	EL,OL	Tree branches fallen on lines at Minerva Grand	No
43	Clock Tower	Anjali	11KV	V	16:26	17:50	1:24	EL,OL-R&Bph	No Visible Fault due to heavy rain & wind	No
44	Clock Tower	Station Road	11KV	V	16:26	18:10	1:44	EL,OL	Tree branches fallen on HT lines at Station Road	No
45	Clock Tower	St. Mary's	11KV	V	16:26	19:20	2:54	EL,OL	Tree branches fallen on HT lines at St. Marry's School	No
1	Salarjung	Q.Q.Stadium	11KV	III	03.35	05.10	01.35	All Indication	Cable fault	Arranged B/F on 11KV Gansi Bazar & Shah Gunj feeders
2	Chanchalguda	Anand Nagar	11KV	VIII	15:45	18:34	2:49	EL	Tree branches fallen on lines at Anand Nagar	No
3	Chanchalguda	Islamiya	11KV	VIII	15:44	19:00	3:16	EL	Tree branches fallen on lines at Dabeerpura Bridge	No
4	Chanchalguda	Chowni	11KV	VIII	15:45	18:22	2:37	EL	Tree branches fallen on lines at Chowni	No
5	Chanchalguda	Arya Samaj	11KV	VIII	15:46	18:06	2:20	EL,OL	No Visible Fault due to heavy rain & wind	No
6	Chanchalguda	Chanchalguda	11KV	VIII	15:52	18:45	2:53	EL,OL-Rph	Tree branches fallen on lines at Chanchalguda Jail	No
7	Chanchalguda	ACP Office	11KV	VIII	15:53	17:50	1:57	EL	Tree branches fallen on lines at ACP Office	No
8	Salarjung	Sadath Nagar	11KV	VIII	18:26	19:35	1:09	EL,OL	No Visible Fault due to heavy rain & wind	No
9	Salarjung	Purani Haveli	11KV	III	16:32	18:16	1:44	EL,OL	No Visible Fault due to heavy rain & wind	Added loads on 11KV Salarjung Museum fdr
10	Salarjung	Pathergatti	11KV	III	16:32	19:02	2:30	EL,OL	No Visible Fault due to heavy rain & wind	No
11	Malakpet	Chaderghat	11KV	VIII	17:25	19:55	2:30	All Indication	No Visible Fault due to heavy rain & wind	No
12	Teegalaguda	Teegalaguda	11KV	VIII	15:45	17:05	1:20	OL-R&Bph	No Visible Fault due to heavy rain & wind	No
13	Teegalaguda	Milk Booth	11KV	VIII	15:45	17:03	1:18	OL-Yph	No Visible Fault due to heavy rain & wind	No
14	Teegalaguda	Shanker Nagar	11KV	VIII	15:45	17:03	1:18	OL-R&Yph	No Visible Fault due to heavy rain & wind	No
15	Teegalaguda	Shivalayam	11KV	VIII	15:45	17:01	1:16	OL-R&Yph	No Visible Fault due to heavy rain & wind	No
16	Teegalaguda	Waheed Nagar	11KV	VIII	15:45	17:04	1:19	OL-Rph	No Visible Fault due to heavy rain & wind	No
17	Teegalaguda	Housing Board Colony	11KV	VIII	15:56	18:50	2:54	EL	HT Jumper cut at Water Tank	No
18	Teegalaguda	RTA Office	11KV	VIII	15:50	23:35	7:45	EL	Big tree fallen on lines at RTA Office	No
19	Laxmi Nagar	Shankeshwara Bazar	11KV	VIII	15:39	19:40	4:01	OL-Rph	Tree branches fallen on lines at Shakeshwar Bazar	No
20	Laxmi Nagar	Edgah	11KV	VIII	15:40	19:52	4:12	EL	Tree branches fallen on lines at Edgah	No

21	Laxmi Nagar	Laxmi Nagar	11KV	VIII	15:48	18:48	3:00	EL	Tree branches fallen on lines at Laxmi Nagar	No
22	Laxmi Nagar	Vinay Nagar	11KV	VIII	15:50	19:32	3:42	EL	Tree branches fallen on lines & Conductor snapped at Bharath Garden	No
23	Laxmi Nagar	Singareni Colony	11KV	VIII	15:51	19:22	3:31	EL	Tree branches fallen on lines at Singareni Colony	No
24	Laxmi Nagar	S.B.H	11KV	VIII	15:53	19:43	3:50	EL	Tree branches fallen on lines at Laxmi Nagar	No
25	Laxmi Nagar	Dhobighat	11KV	VIII	15:49	19:58	4:09	EL	Tree branches fallen on lines at Dhobighat	No
26	Yakuthpura	Dharmavanth	11KV	VIII	15:42	17:40	1:58	EL	Foreign material fallen on lines at Dharmavanth	No
27	Yakuthpura	Bada Bazar	11KV	VIII	15:42	21:12	5:30	EL	Tree branches fallen on lines at Bada Bazar	No
28	Yakuthpura	Somnath Temple	11KV	VIII	15:47	16:54	1:07	EL	No Visible Fault due to heavy rain & wind	No
29	Yakuthpura	Stravani Hospital	11KV	VIII	15:47	16:54	1:07	EL	No Visible Fault due to heavy rain & wind	No
30	Yakuthpura	Khan Nagar	11KV	VIII	15:47	18:14	2:27	EL	Pin Insulator flash over at Khan Nagar	No
31	Yakuthpura	Moula Ka Chilla	11KV	VIII	15:56	21:00	5:04	EL	Tree branches fallen on lines at Moula Ka Chilla	No
32	Malakpet	Municipal Colony	11KV	VIII	15:37	21:30	5:53	EL,OL	Tree branches fallen on lines at Yashoda Hospital backside	No
33	Malakpet	M.M.H.	11KV	VIII	15:35	17:10	1:35	EL	No Visible Fault due to heavy rain & wind	No
34	Malakpet	Dabeerpura	11KV	VIII	15:40	19:10	3:30	EL	Faulty DTR at Dabeerpura	No
35	Malakpet	Komatiwadi	11KV	VIII	15:42	17:15	1:33	EL	No Visible Fault due to heavy rain & wind	No
36	Malakpet	Plant Protection	11KV	VIII	15:42	19:30	3:48	EL	Tree branches fallen on lines at Malakpet	No
37	Malakpet	Chaderghat	11KV	VIII	15:43	17:10	1:27	EL	No Visible Fault due to heavy rain & wind	No
38	Malakpet	Malakpet	11KV	VIII	15:42	17:10	1:28	EL	No Visible Fault due to heavy rain & wind	No
39	Malakpet	Yasodha Hospital	11KV	VIII	15:44	19:05	3:21	EL	No Visible Fault due to heavy rain & wind	No
40	Malakpet	Noorkhan Bazar	11KV	VIII	15:47	19:15	3:28	EL	No Visible Fault due to heavy rain & wind	No
41	Aliabad	Shamsheergunj	11KV	III	15:45	18:05	2:20	EL	HT Jumper cut at Opp. SS	No
42	Gunj	Race Course	11KV	VIII	15:40	21:34	5:54	EL	Tree branches fallen on lines at Malakpet Function Hall	No
43	Gunj	Palton	11KV	VIII	15:42	19:47	4:05	EL	HT Line snapped at Palton	No
44	Gunj	Muntaz College	11KV	VIII	15:46	21:33	5:47	EL	Tree branches fallen on lines at Muntaz College	No
45	Gunj	Judges Colony	11KV	VIII	15:50	20:10	4:20	EL,OL-Bph	Banner fallen on lines at N.C.Colony	No
46	Gunj	Hari Hara Skhetra	11KV	VIII	15:55	20:15	4:20	EL	No Visible Fault due to heavy rain & wind	No
47	Hyderguda	Jana Priya AB Cable	11KV	III	15:45	16:50	1:05	EL	No Visible Fault due to heavy rain & wind	No
48	E.N.T.	E.N.T.	11KV	IX	15:40	18:15	2:35	EL,OL-Bph	Faulty DTR at Badi Chowdi PS	No
49	Vittalwadi	Narayanguda Water Works	11KV	IX	15:45	17:50	2:05	All Indication	No Visible Fault due to heavy rain & wind	No
50	Falaknuma	Farooq Nagar	11KV	III	16:50	21:30	4:40	EL,OL-Rph	Tree branches fallen on lines at Falaknuma	No
51	Falaknuma	Ravindra Naik Nagar	11KV	III	16:50	18:35	1:45	EL	Tree branches fallen on lines at Ravindra Naik Nagar	No
52	Kandikal Gate	G.M.Chowni	11KV	III	15:30	18:25	2:55	EL,OL	No Visible Fault due to heavy rain & wind	No
53	Petlaburz	Murali Nagar	11KV	III	15:55	19:45	3:50	EL	Twisted HT Lines at Murali Nagar	No
54	Petlaburz	Ghansi Bazar	11KV	III	15:48	18:15	2:27	EL	No Visible Fault due to heavy rain & wind	No
55	Malakpet B-Block	LIC Colony	11KV	VIII	15:43	21:50	6:07	EL	No Visible Fault due to heavy rain & wind	No
56	Malakpet B-Block	Samatha Degree College	11KV	VIII	15:43	21:16	5:33	EL	No Visible Fault due to heavy rain & wind	No

HYD S

57	Malakpet B-Block	C-Quarters	11KV	VIII	15:47	21:39	5:52	EL	No Visible Fault due to heavy rain & wind	No
58	Malakpet B-Block	Ekalavya Nagar	11KV	VIII	15:47	20:24	4:37	EL	No Visible Fault due to heavy rain & wind	No
59	Malakpet B-Block	Akber Bagh	11KV	VIII	15:52	19:54	4:02	EL	No Visible Fault due to heavy rain & wind	No
60	Malakpet B-Block	Anand Biscuti Factory	11KV	VIII	15:57	21:26	5:29	OL-B&Yph	No Visible Fault due to heavy rain & wind	No
61	Koti Womens College	Esamiya Bazar	11KV	IX	15:48	17:20	1:32	EL,OL	No Visible Fault due to heavy rain & wind	No
62	Ch' Baradari	Ch' Baradari	11KV	III	15:45	17:00	1:15	EL	No Visible Fault due to heavy rain & wind	No
63	Ch' Baradari	Ramnaspura	11KV	III	15:45	16:55	1:10	EL	No Visible Fault due to heavy rain & wind	No
64	Ch' Baradari	Fire Station	11KV	III	15:45	17:40	1:55	EL,OL	No Visible Fault due to heavy rain & wind	No
65	Santosh Nagar	Santosh Nagar	11KV	VIII	15:40	17:40	2:00	EL,OL	No Visible Fault due to heavy rain & wind	No
66	Santosh Nagar	Moon Star	11KV	VIII	15:48	20:05	4:17	EL	HT Line snapped at Vikas High School	No
67	Santosh Nagar	Jyothi Bagh	11KV	VIII	15:42	17:45	2:03	EL	No Visible Fault due to heavy rain & wind	No
68	C.R.P.F.	C.R.P.F.	11KV	III	16:35	20:40	4:05	EL	Tree branches fallen on lines at C.R.P.F. inside	No
69	Falaknuma	G.S.Darga	11KV	III	16:50	22:55	6:05	EL,OL-Rph	Tree branches fallen on lines	Partial fdr charged & remaining loads added on 11KV Vattepally fdr
70	Malakpet B-Block	Akber Bagh	11KV	VIII	20:30	22:07	1:37	EL,OL-R&Yph	Tree branches fallen on lines at Akber Bagh	No
71	Durga Nagar	Saleem Nagar	11KV	VIII	15:42	19:50	4:08	EL	Tree branches fallen on lines	Arranged B/F on 11KV MRO Office fdr
72	Devi Bagh	Rama Talkies	11KV	III	15:45	17:45	2:00	EL	LT Line snapped at Rama Talkies	No
73	Devi Bagh	Edgah	11KV	III	16:00	17:10	1:10	EL	No Visible Fault due to heavy rain & wind	No
74	Chanchalguda	Madannapet	11KV	VIII	15:55	1:20	9:25	EL	Tree branches fallen on lines at Madannapet Old PS	No
75	Miralam	Ranjan Colony	11KV	III	15:50	17:10	1:20	EL,OL-R&Yph	No Visible Fault due to heavy rain & wind	No
76	Miralam	Jahanuma	11KV	III	15:50	17:50	2:00	EL,OL-Rph	Tree branches fallen on lines at Jahanuma	No
77	Miralam	Ansari Road	11KV	III	16:20	17:40	1:20	EL,OL-Rph	Post type Insulator flash over at Ansari Road	No
78	Asmangadh	Jaya Nagar	11KV	VIII	15:45	20:30	4:45	EL,OL-R&Bph	No Visible Fault due to heavy rain & wind	No
79	Santosh Nagar	Raza Nagar	11KV	VIII	17:15	19:10	1:55	EL	Twisted lines at Rahaman Café	No
80	Malakpet	Komatiwadi	11KV	VIII	23:23	0:50	1:27	EL	Jumper cut at SS	Arranged B/F on 11KV Bibi Ka Alwa fdr
81	Moosarambagh	Moosarambagh	11KV	VIII	15:40	17:00	1:20	EL	No Visible Fault due to heavy rain & wind	No
82	Moosarambagh	Shalivahana Nagar	11KV	VIII	15:42	18:45	3:03	All Indication	No Visible Fault due to heavy rain & wind	No
83	Moosarambagh	S.B.I. Colony	11KV	VIII	15:45	17:59	2:14	EL	No Visible Fault due to heavy rain & wind	No
84	Moosarambagh	Dilshuk Nagar	11KV	VIII	15:15	18:44	3:29	EL	No Visible Fault due to heavy rain & wind	No
1	A.S.R.Raju Nagar	Golla Basti	11KV	VII	15.30	16.48	01.18	EL	No Visible Fault due to heavy rain & wind	No
2	A.S.R.Raju Nagar	Ushodaya Colony	11KV	VII	15.32	16.50	01.18	EL	No Visible Fault due to heavy rain & wind	No
3	A.S.R.Raju Nagar	A.S.R.Raju Nagar	11KV	VII	15.34	16.51	01.17	EL	No Visible Fault due to heavy rain & wind	No
4	A.S.R.Raju Nagar	Sai Garden	11KV	VII	15.37	16.54	01.17	EL	No Visible Fault due to heavy rain & wind	No
5	A.S.R.Raju Nagar	LIC Office	11KV	VII	15.42	16.48	01.06	EL	No Visible Fault due to heavy rain & wind	No
6	A.S.R.Raju Nagar	Jeevan Kalyan Nagar	11KV	VII	15.36	18.58	03.22	EL	Tree branches fallen on lines at Jeevan Kalyan Nagar	No
7	A.S.R.Raju Nagar	GHMC Park	11KV	VII	15.39	17.55	02.16	EL	Tree branches fallen on lines at Tallagadda	No
8	Narayanguda	Chikkadapally	11KV	II	15.40	17.15	01.35	EL	No Visible Fault due to heavy rain & wind	No
9	Gudi Malkapur	Sharada Nagar	11KV	VII	15.33	16.50	01.17	EL	No Visible Fault due to heavy rain & wind	No
10	Gudi Malkapur	Murad Nagar	11KV	VII	15.47	17.02	01.15	EL	No Visible Fault due to heavy rain & wind	No

11	Gudi Malkapur	Navodaya Colony	11KV	VII	15.42	18.55	03.13	EL	Tree branches fallen on lines at Syed Aliguda	No
12	Gudi Malkapur	Amba Garden	11KV	VII	15.41	19.25	03.44	EL	Tree branches fallen on lines at S.B.I Colony	No
13	Exhibition	Jawaharlal Nehru	11KV	I	15.56	17.00	01.04	EL	No Visible Fault due to heavy rain & wind	No
14	Exhibition	Collector Office	11KV	I	15.56	17.10	01.14	EL	No Visible Fault due to heavy rain & wind	No
15	Exhibition	Jagadish Market	11KV	I	15.56	16.58	01.02	EL	No Visible Fault due to heavy rain & wind	No
16	Hyderguda	Boggula Kunta	11KV	I	15.38	17.38	02.00	EL	Tree branches fallen on lines at Boggula Kunta	No
17	Hyderguda	Hyderguda	11KV	I	15.40	18.54	03.14	EL	DTR fault at Hyderguda	No
18	Hyderguda	King Koti	11KV	I	15.44	18.06	02.22	EL	No Visible Fault due to heavy rain & wind	No
19	Hyderguda	Abids	11KV	I	15.47	19.22	03.35	EL	HT Lines snapped at Nizam College	No
20	Asif Nagar	Kakatiya Nagar	11KV	VII	15.38	17.00	01.22	EL,OL-Bph	Tree branches fallen on lines at Kakatiya Nagar	No
21	Asif Nagar	Toli Chowki	11KV	VII	15.40	17.05	01.25	EL,OL-B&Rph	Tree branches fallen on lines at Delux Colony	No
22	Asif Nagar	Military	11KV	VII	15.40	17.15	01.35	EL	Tree branches fallen on lines at Military Area	No
23	Asif Nagar	Mehdipatnam OH	11KV	VII	15.42	16.58	01.16	EL,OL	No Visible Fault due to heavy rain & wind	No
24	Asif Nagar	Mehdipatnam Cable	11KV	VII	15.48	17.45	01.57	EL	Tree branches fallen on lines at Bus Depot	No
25	Asif Nagar	Jyothi Nagar	11KV	VII	15.50	17.02	01.12	EL	No Visible Fault due to heavy rain & wind	No
26	Asif Nagar	Hakeempet	11KV	VII	15.37	18.55	03.18	EL	HT Line snapped at Alsath Colony	No
27	Asif Nagar	Padmanaba Nagar	11KV	VII	15.45	19.20	03.35	OL-R&Bph	Pin Insulator flash over at Padmanaba Nagar	No
28	Asif Nagar	N.S.F Colony	11KV	VII	15.35	19.50	04.15	EL,OL-Bph	Tree branches fallen on lines at Neeraja Colony	No
29	Narayanguda	Narayanguda	11KV	II	15.40	18.10	02.30	EL	Tree branches fallen on lines at Blue And Bar	No
30	Bathkammakunta	Ahobilmutt	11KV	II	15.30	17.42	02.12	EL	Tree branches fallen on lines at Ahobilmutt	No
31	Bathkammakunta	Saibaba Temple	11KV	II	15.35	17.57	02.22	EL	Tree branches fallen on lines at Saibaba Temple	No
32	Bathkammakunta	C.E Colony	11KV	II	15.40	17.44	02.04	EL	Tree branches fallen on lines at C.E Colony	No
33	Bathkammakunta	Shivam Road	11KV	II	15.40	19.43	04.03	EL	Tree branches fallen on lines & HT Line snapped at T.R.T Quarters	No
34	Jawahar Nagar	Post Office	11KV	I	15.40	17.53	02.13	EL	Twisted Lines at Jawahar Nagar	No
35	Jawahar Nagar	Anjaiah Bhavan	11KV	I	15.40	17.45	02.05	EL	No Visible Fault due to heavy rain & wind	No
36	Jawahar Nagar	Jawahar Nagar	11KV	I	15.45	17.30	01.45	OL-R&Bph	No Visible Fault due to heavy rain & wind	No
37	Jawahar Nagar	Ashok Nagar	11KV	I	15.45	18.30	02.45	EL	No Visible Fault due to heavy rain & wind	No
38	Jawahar Nagar	Bank Of Baroda	11KV	I	15.50	18.20	02.30	OL-Bph	Tree branches fallen on lines at Narmada Hospital	No
39	Jawahar Nagar	J.N Home	11KV	I	16.20	18.00	01.40	EL	No Visible Fault due to heavy rain & wind	No
40	Zamistanpur	Balaji Nagar	11KV	II	15.40	18.20	02.40	EL,OL-Rph	No Visible Fault due to heavy rain & wind	No
41	Zamistanpur	Dayara Market	11KV	II	15.40	17.35	01.55	All Indication	No Visible Fault due to heavy rain & wind	No
42	Zamistanpur	Shastry Nagar	11KV	II	15.51	19.16	03.25	All Indication	No Visible Fault due to heavy rain & wind	No
43	Zamistanpur	Jamai Osmania	11KV	II	15.45	19.12	03.27	All Indication	No Visible Fault due to heavy rain & wind	No
44	Golnaka	Tulasi Nagar	11KV	II	15.46	18.26	02.40	All Indication	Tree branches fallen on lines at Mustafa Hotel	No



45		Golnaka	Moulana Azad Nagar	11KV	II		15.48	17.36	01.48	EL	No Visible Fault due to heavy rain & wind	No
46		Golnaka	Brahman Hostel	11KV	II		15.47	17.26	01.39	EL	Tree branches fallen on lines at Ramalayam FOC	No
47		Golnaka	Kamala Nagar	11KV	II		15.46	18.30	02.44	EL,OL-Bph	Brass Patti burntout at Lanka	No
48		Golnaka	Shivalayam Temple	11KV	II		15.48	17.29	01.41	EL	Tree branches fallen on lines at Golnaka	No
49		Golnaka	Sai Madhura Nagar	11KV	II		15.47	18.27	02.40	EL	No Visible Fault due to heavy rain & wind	No
50		Golnaka	Nehru Nagar	11KV	II		15.48	19.58	04.10	EL,OL-Bph	Brass Patti burntout at Aqua Café	No
51		Golnaka	Harazpenta	11KV	II		15.46	20.08	04.22	EL	Tree branches fallen on lines at Krishna Nagar	No
52		Lake View	Dilkusha	11KV	I		15.48	20.04	04.16	EL,OL-Rph	Tree branches fallen on lines at Dilkusha	No
53		Lake View	N.K.M.S Hotel	11KV	I		15.48	19.16	03.28	EL	Tree branches fallen on lines at NKM's Hotel	No
54		Lake View	Kapadia Lane	11KV	I		15.49	18.18	02.29	EL	Tree branches fallen on lines at Kapadiya Lane	No
55		Toli Chowki	B.S.N.L	11KV	VII		15.37	18.45	03.08	EL	Tree branches fallen on lines at B.S.N.L Office	No
56		Amberpet	Golnaka	11KV	II		15.35	17.45	02.10	EL	Tree branches fallen on lines at Tirumala Nagar	No
57		Amberpet	6 Number	11KV	II		15.36	17.55	02.19	EL	Tree branches fallen on lines at Sheraton Hotel	No
58		Amberpet	Zinda Tilismath	11KV	II		15.36	16.40	01.04	EL	No Visible Fault due to heavy rain & wind	No
59		Nampally	FAPCCI	11KV	VII		15.41	18.32	02.51	EL,OL-Bph	Tree branches fallen on lines at Criminal Court	No
60		Nampally	Pearl Regency	11KV	VII		15.42	18.10	02.28	EL	Tree branches fallen on lines at Pearl Regency	No
61		Nampally	V.N.C	11KV	VII		15.42	20.15	04.33	EL	Tree branches fallen on lines at B.S.N.L Office	No
62		Nampally	Amba Hospital	11KV	VII		15.41	18.34	02.53	EL	Tree branches fallen on lines at Amba Hospital	No
63		Nampally	Badi Masjid	11KV	VII		15.41	17.51	02.10	EL	Tree branches fallen on lines at Badi Masjid	No
64		Nampally	Nampally Hospital	11KV	VII		15.42	17.50	02.08	EL,OL-Rph	Tree branches fallen on lines at Nampally Hospital	No
65		Nampally	Red Hills	11KV	VII		15.39	18.37	02.58	EL	Tree branches fallen on lines at Red Hills	No
66		Z.P Office	Ramleela Maidan	11KV	I		15.33	19.31	03.58	EL	Tree branches fallen on lines at Ramleela Maidan	No
67	HYD C	Z.P Office	Z.P Office	11KV	I		15.35	18.00	02.25	EL,OL	No Visible Fault due to heavy rain & wind	No
68		Z.P Office	Banjara Avenue	11KV	I		15.45	18.50	03.05	EL,OL	No Visible Fault due to heavy rain & wind	No
69		Langerhouse	Prashanth Nagar	11KV	VII		16.20	18.50	02.30	EL	No Visible Fault due to heavy rain & wind	No
70		Langerhouse	Military Hospital	11KV	VII		16.20	18.10	01.50	EL	Tree branches fallen on lines at Military Hospital	No
71		Langerhouse	Netaji Nagar	11KV	VII		16.20	18.16	01.56	EL	Tree branches fallen on lines at Om Nagar Park	No
72		Fever Hospital	Tourist Hotel	11KV	II		15.37	19.18	03.41	EL	Tree branches fallen on lines at Ratnadeep Super Market	No
73		Fever Hospital	Fever Hospital	11KV	II		15.40	19.41	04.01	EL	11KV Pole damaged at Anjaiah Quarters	No

74	Fever Hospital	BKP Bus Depot	11KV	II	15.40	20.50	05.10	EL	Tree branches fallen on lines at Anuradha Apts	No
75	Fever Hospital	C.C.S.Hospital	11KV	II	15.40	19.44	04.04	EL	Tree branches fallen on lines at Bhoomaiah Galli	No
76	Fever Hospital	Kachiguda	11KV	II	16.02	19.14	03.12	EL	No Visible Fault due to heavy rain & wind	No
77	I.T.I. Mallepally	Afzal Sagar	11KV	VII	15.41	17.19	01.38	EL	No Visible Fault due to heavy rain & wind	No
78	I.T.I. Mallepally	Zaheera Masjid	11KV	VII	15.41	17.13	01.32	EL	No Visible Fault due to heavy rain & wind	No
79	I.T.I. Mallepally	Zaheera Masjid	11KV	VII	17.48	19.15	01.27	EL	No Visible Fault due to heavy rain & wind	No
80	I.T.I. Mallepally	Indira Nagar	11KV	VII	15.40	19.44	04.04	EL	Line melted at Indira Nagar	No
81	I.T.I. Mallepally	Anwar UI Uloom	11KV	VII	15.49	20.05	04.16	EL	Tree branches fallen on lines at Anwar UI Uloom College	No
82	Fever Hospital	Nalla Kunta	11KV	II	15.40	22.13	06.33	EL	Tree branches fallen on lines at Bindu Mall Apts	No
83	Vittalwadi	I.C.I.C.I.	11KV	I	15.43	18.15	02.32	All Indication	No Visible Fault due to heavy rain & wind	No
84	Vittalwadi	Taj Mahak	11KV	I	15.45	20.40	04.55	All Indication	Tree branches fallen on lines near Bahar Café	No
85	Vittalwadi	Basanth Colony	11KV	II	15.45	20.25	04.40	EL,OL-Bph	Tree branches fallen on lines at Barkathpura Chaman	No
86	Vittalwadi	Y.M.C.A.	11KV	II	15.45	21.25	05.40	All Indication	HT Line snapped at Y.M.C.A. Ground	No
87	Vittalwadi	APCO	11KV	II	15.45	21.00	05.15	All Indication	Tree fallen on Lines at Narayanguda Water Works	No
88	Vittalwadi	Kamineni Hospital	11KV	I	15.45	18.00	02.15	All Indication	No Visible Fault due to heavy rain & wind	No
89	Indira Park	Secretariat	11KV	I	15.50	18.05	02.15	EL	No Visible Fault due to heavy rain & wind	No
90	Indira Park	Kuchipudi	11KV	I	15.55	18.00	02.05	EL	No Visible Fault due to heavy rain & wind	No
91	Indira Park	Gulshan Nagar	11KV	I	15.40	20.10	04.30	EL	No Visible Fault due to heavy rain & wind	No
92	Indira Park	Gagan Mahal	11KV	I	15.50	17.45	01.55	EL	No Visible Fault due to heavy rain & wind	No
93	Chilkaiguda	Musheerabad	11KV	I	15.40	18.40	03.00	EL	No Visible Fault due to heavy rain & wind	No
94	Chilkaiguda	Parsigutta	11KV	II	15.40	17.55	02.15	EL	No Visible Fault due to heavy rain & wind	No
95	Chilkaiguda	44 Bus Stop	11KV	II	15.40	21.40	06.00	EL	No Visible Fault due to heavy rain & wind	No
96	Chilkaiguda	Golconda X Road	11KV	II	15.40	17.40	02.00	EL	No Visible Fault due to heavy rain & wind	No
97	Narayanguda	City Central Library	11KV	I	15.40	19.30	03.50	EL	No Visible Fault due to heavy rain & wind	No
98	Narayanguda	Preventive Medicine	11KV	II	15.40	18.20	02.40	EL	Tree branches fallen on lines at Ambedkar Nagar College	No
99	Lumbini Park	A.P.Tourism	11KV	I	15.37	17.00	01.23	EL	No Visible Fault due to heavy rain & wind	No
100	Lumbini Park	T.T.D.	11KV	I	15.40	19.00	03.20	OL-Bph	Tree branches fallen on lines at Himayath Nagar	No
101	Lumbini Park	A.I.R.	11KV	I	15.40	17.01	01.21	OL-Bph	No Visible Fault due to heavy rain & wind	No
102	Erramanzil	Padmavathi Nagar	11KV	I	15.50	17.50	02.00	EL,OL	No Visible Fault due to heavy rain & wind	No
103	I.T.I. Mallepally	Anjuman	11KV	VII	15.35	19.48	04.13	EL	Tree branches fallen on lines at Zeba Bagh	No
104	A.C.Guards	Niloufer	11KV	VII	15.30	17.00	01.30	EL,OL-Bph	No Visible Fault due to heavy rain & wind	No
105	A.C.Guards	Shanthy Nagar	11KV	VII	15.35	18.00	02.25	EL,OL-Bph	Tree branches fallen on lines at Shanthy Nagar	No
106	A.C.Guards	Mahaveer OH	11KV	I	15.40	20.45	05.05	EL	Tree branches fallen on lines at Latif Plaza	No
107	A.C.Guards	Bazarghat	11KV	VII	15.40	16.50	01.10	EL	No Visible Fault due to heavy rain & wind	No
108	A.C.Guards	N.M.D.C.	11KV	VII	15.40	17.15	01.35	EL	No Visible Fault due to heavy rain & wind	No
109	A.C.Guards	Care Hospital	11KV	I	15.45	20.25	04.40	EL	Tree branches fallen on lines at Maheshwari Towers	No
110	Erramanzil	I.C.Quarters	11KV	I	15.50	17.54	02.04	EL,OL	Tree branches fallen on lines at I.C.Quarters	No

111	Erramanzil	Anugraha	11KV	I	15.50	20.43	04.53	EL,OL	Tree branches fallen on lines at Anugraha	No
112	Amberpet	Tilak Nagar	11KV	II	15.36	20.00	04.24	EL	Tree fallen on lines at Tilak Nagar	Added loads on 11KV Sai Madhura Nagar fdr
113	Fever Hospital	Sri Ram Nagar	11KV	II	15.40	01.29	09.49	EL	Tree branches fallen on lines at Barla Doddi,Sri Ram Nagar	No
114	Durga Nagar	Krishna Nagar	11KV	II	15.40	19.20	03.40	EL	Tree branches fallen on lines at D-Mart	No
115	Durga Nagar	Sunder Nagar	11KV	II	15.44	17.50	02.06	EL,OL-Rph	No Visible Fault due to heavy rain & wind	No
116	Nizam College	Roseary Convent	11KV	I	15.40	20.02	04.22	EL	No Visible Fault due to heavy rain & wind	No
117	Nizam College	Babu Khan Estate	11KV	I	15.40	20.20	04.40	EL	Tree branches fallen on lines at Babu Khan Estate	No
118	Nizam College	S.B.Nursing Home	11KV	I	15.44	19.10	03.26	EL	No Visible Fault due to heavy rain & wind	No
119	Nizam College	Galaxy Hotel	11KV	I	15.45	18.04	02.19	EL	No Visible Fault due to heavy rain & wind	No
120	Nizam College	Nizam College	11KV	I	15.45	19.30	03.45	EL	No Visible Fault due to heavy rain & wind	No
121	Nizam College	Little Flower	11KV	I	15.46	17.15	01.29	EL	No Visible Fault due to heavy rain & wind	No
122	N.I.M.S	Erramanzil	11KV	I	16.05	19.05	03.00	EL,OL	Tree branches fallen on lines at Erramanzil	No
123	Osm. University	Boudha Nagar	11KV	II	15.53	19.00	03.07	OL	Faulty DTR at Warasiguda	No
124	A.S.R.Raju Nagar	Jeevan Kalyan Nagar	11KV	VII	19.28	20.50	01.22	EL	Tree branches fallen on lines at Mehdipatnam	No
125	Chilalguda	Bolakpur	11KV	I	19.55	21.10	01.15	EL,OL	No Visible Fault	No
126	S.D.Hospital	Khadi Bandar	11KV	VII	15.39	18.32	02.53	EL,OL-R&Bph	No Visible Fault due to heavy rain & wind	No
127	Gudi Malkapur	Murad Nagar	11KV	VII	23.25	01.15	01.50	EL	Cable fault at Imli PT	No
128	I.T.I. Mallepally	P.S.Nagar	11KV	VII	15.40	19.00	03.20	EL,OL	Tree branches fallen on lines at N.M.D.C. Area	No
129	Mothi Mahal	Saleh Nagar	11KV	VII	23.48	01.52	02.04	All Indication	HT Jumper cut & DTR failed at Mothi Mahal	No