

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		3		3			
2	NLG	144	988		5		5		5			
3	MDK	107	933	3	3	2	3	2	3	1		1 No. 33KV Still
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>3</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>1</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>19</b>	<b>2</b>	<b>19</b>	<b>2</b>	<b>19</b>	<b>1</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 18.05.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	VIF	33KV	Sangareddy	21:55	Still					
2		Sadasivpet	Koheer	33KV	Sangareddy	17.45	18.45	01.00		No visible fault	Koheer	Alternate supply given from 33KV Jharasangam feeder emanating from 132KV Zaheerabad
3		Narsapur	Arobindo	33KV	Medak	12.20	15.10	02.50		Jumper cut	Arobindo	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Mallepally	11KV	Jadcherla	11.15	13.15	02.00		11KV Insulator failed near Marribavi tanda Side.	No
2		Midjil	Veljal	11KV	Jadcherla	07.40	09.40	02.00		Poles Damaged At Veljal( V).	No
3		K.V.Pet	Bandameedipally	11KV	Jadcherla	08.30	09.30	01.00		HT/LT near Jayaprakash Nagar Colony.	No
1	NLG	Cheedella	Industrial	11KV	Suryapeta	12:25	15:00	2:35		Conductor snapped	No
2		Kothapally	Korlapahad	11KV	Nalgonda	12.40	16.20	03.40		Jumper cut	No
3		Thurkapally	Thurkapally	11KV	Nalgonda	10.20	13.30	03.10		11KV Line cut	No
4		Mattampally	Mattampally	11KV	Huzurnagar	13.20	16.26	03.06		11KV Line snapped	No
5		Ananthagiri	Shanthy nagar	11KV	Huzurnagar	15:00	16:30	1:30		11KV Line snapped	No
1	MDK	Bollaram-I	Khatian	11KV	Patancheru	8:45	9:10	0:25		Jumper Cut	No
2		Reddypally	Khajipet	11KV	Medak	00.02	11.20	11.18		Jumper Cut	No
3		Reddypally	Chippalthurthy	11KV	Medak	00.00	10.20	10.20		Conductor Snapped	No
1	RR N	Jeedimetla SS-III	USP Organic	11KV	Jeedimetla	15:45	17:45	2:00		11kv line AB Cable Damaged at SVS Rubbar Company	No
1	RR E	Cherlapally-I	Phase-I	11KV	Sainikpuri	6:45	8:25	1:40		11Kv Insulator binding failed and 11KV HG fuse replaced at Sakhi Inida	No
2		Chakripuram	Simhapuri Colony	11KV	Keesara	08.00	18.55	10.55		11KV Line twisted at Vijayapuri Colony Main Road	No
3		Chakripuram	Ayyappa Nagar	11KV	Keesara	08.00	18.55	10.55		11KV Line twisted at Vijayapuri Colony Main Road	No
4		Chakripuram	SV Nagar	11KV	Keesara	11.22	13.05	01.43		Tree branches fallen on 11KV line at SV Nagar Road No.11	No
1	HYD N	Chilalguda	Pragatools	11KV	Sec'bad	00.15	05.30	05.15	EL,OL	Cable fault	Arranged B/F on 11KV C.C Nagar feeder
1	HYD S	Teegalaguda	RTA Saleem Nagar	11KV	Asmangadh	01.00	02.30	01.30	OL-Rph	Tree branches fallen on lines at RTA Office	No
1	HYD C	Vittalwadi	Y.M.C.A	11KV	Azamabad	01.40	04.39	02.59	EL	Cable fault	Arranged B/F on 11KV C.C.Shroff Hospital fdr