

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		5		5		5			
3	MDK	107	933	2	4	2	4	2	4			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	10	3	10	3	10	0	0	
	Grand Total	1082	6468	3	15	3	15	3	15	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	G.R Cable	33KV	Jadcherla	21.40	1.15 (20.05.18)	03.15		DUE to Juper cut	Balanagar	-
1	MDK	Kandhi	HFC-II	33KV	Sangareddy	14.05	16.30	02.25		BD due to 3no.Disks failed	Kandhi	-
2		Sadasivpet	Koheer	33KV	Sangareddy	09.30	12.25	02.55		BD due to After line petrolling no fault found	Sadasivpet	-

TSSPDCL - LMRC / Corporate office

Date: 19.05.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Rudraram	11KV	Jadcherla	11.15	15.00	03.45		11KV Insulator failed near Goinpally	-
1	NLG	Kudakuda	Ilapuram	11KV	Suryapet	13.20	16.00	02.40	E/L	Conductor snapped at Amboth Thanda	-
2		Gaddipaly	Gaddipally	11KV	Huzurnagar	06.00	10.00	04.00	EL	Due to Tree Branch fall on 11Kv line near Gaddipally village	-
3		Rajupeta	Jonnagaddalagudem	11KV	Nalgonda	11.05	14.50	03.45	E/L	11KV Jumper cut	-
4		Pamanagundla	Ismailpally	11KV	Nalgonda	09.00	11.00	02.00	E/L	11KV Jumper cut	-
5		Laxmidevigudam	Laxmidevigudam	11KV	Miryalaguda	08.00	11.30	03.30	E/L	11KV Jumper cut	-
1	MDK	Shalipet	Shalipet	11KV	Medak	02.50	10.10	07.20		B/D DUE TO 11 KV CONDUCTOR SNAPPED	-
2		Gavvalapally	Gavvalapally	11KV	Medak	00.00	11.00	11.00		B/D DUE TO 11 KV INSULATOR FAILED	-
3		Chippalthurthy	Chippalthurthy	11KV	Medak	01.30	10.30	09.00		B/D DUE TO 11 KV JUMPER CUT	-
4		Gandhariapally	Jaipuram	11KV	Medak	00.00	18.00	18.00		B/D DUE TO BRAKER PROBLEM	-
1	RR E	BANDLAGUDA	VAMBAYCOLONY	11KV	SAROORNAGAR	04.16	05.28	01.12	OL	11KV LOAD DART TO 11KV ROCK TOWN	-
2		PEDDAMBERPET	PASUMAMALA	11KV	SAROORNAGAR	05.00	06.30	01.30	OL	11KV POLE BORKEN AT KUNTLOOR	-
1	HYD S	Asmangadh	Gowtham Nagar	ST	VIII	01.43	03.40	01.57	OL-Y&Bph	Twisted Lines & 2No. Jumpers cut at Gowtham Nagar	-
2		Kanchanbagh	Kanchanbagh	ST	VIII	11.44	13.09	01.25	OL-Rph	No Visible Fault	-
3		Laxmi Nagar	Vinay Nagar	ST	VIII	23.35	00.42	01.07	OL-Rph	3no DTR kept off	(00:38) Opened AB Switch 38% feeder charged