

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	1	2	1	2	1	2			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	4	1	4	1	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		4		4		4			
3	MDK	107	933	2	5	2	5	2	5			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	9	3	9	3	9	0	0	
	Grand Total	1082	6468	4	13	4	13	4	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Kodangal	33KV	Mahabubnagar	17.05	17.55	00.50	E/L	for Tree follen on the Line at Kodangal SS	Kodangal	-
1	MDK	Pashamailaram	APL4	33KV	Sangareddy	16.55	20.55	04.00	B/D due to Disk failure	B/D due to Disk failure	Pashamailaram	-
2		Pashamailaram	BPL	33KV	Sangareddy	16.58	19.14	02.16	B/D due to Jumper cut	B/D due to Jumper cut	Pashamailaram	-
1	RR S	132kv Pargi	Rangampally	33KV	Vikarabad	15.25	17.05	01.40	EL	33kv Lighting Eraster Blast at 132 kv Pargi ss	132kv Pargi	-

TSSPDCL - LMRC / Corporate office

Date: 22.05.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kudakuda	X-press feeder	11KV	Suryapet	10.30	12.10	01.40	E/L	Jumper cut	-
2		Turkapally	M.Gowraram	11KV	Nalgonda	10.20	11.35	01.15	E/L	11KV line Jumper cut, Jumper cut	-
3		Urumadla	Yelikatte	11KV	Nalgonda	21.10	22.45	01.35	E/L	11KV Line Jumper cut	-
4		Singarajupally	Veeraboinapally	11KV	Devarakonda	07.00	09.00	02.00	E/L	Conductor Sanpped	-
1	MDK	Isnapur	Kyasaram	11KV	Sangareddy	16.50	17.55	01.05		B/d due to Insulator failure	-
2		Jinnaram	Jinnaram	11KV	Patancheru	12.35	13.40	01.05		B/D due to Jumper cut	-
3		SOL	BMF	11KV	Patancheru	17.00	19.20	02.20		B/d due to Tree branches fallen on the line	-
4		Narsapur	Narayanpur	11KV	Medak	06.38	07.50	01.12		B/d due to Insulater failure	-
5		Venkatraopet	Venkatraopet	11KV	Medak	08.50	10.50	02.00		B/d due to conductor snapped	-
1	RR S	Kodangal	Parsapuram	11KV	vikarabad	01.30	04.30	03.00	B/D	11kv Line snapped at Parsapuram gate	-
2		Marpally	Siripuram	11KV	vikarabad	01.57	03.55	01.58	B/D	11kv Line snapped at Siripuram.vg	-
1	HYD S	Chanchalguda	Anand Nagar	11KV	Asmangadh	00.10	02.00	01.50	EL,OL-Rph	1st Line AB Switch Jumper cut at Dilkusha Funtion Hall	-
2		Khilwath	Charminar	11KV	Charminar	02.08	03.28	01.20	All Indication	Cable fault near Telephone Exchange	-