

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	7	1	7	1	7			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	1	13	1	13	1	13	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988		4		4		4			
3	MDK	107	933		3		3		3			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	10	1	10	1	10	0	0	
	Grand Total	1082	6468	2	23	2	23	2	23	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.05.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Eklaspur	33KV	Narayanpet	11.30	13.45	02.15	E/L	2No's Pin Bindings damaged at Marikal SS	Eklaspur	No
2	RR N	Chinthal	UMCC	33KV	Medchal	04.08	05.16	01.08		Tree fallen on the 33KV line at Gajularamaram	UMCC	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBN	Thirumalapur	Dondlapally	11KV	Jadcherla	5:00	9:30	4:30		11 kv Jumper cut near Dondlapally	No
2		Kollur	Depally	11KV	Jadcherla	00.00	09.00	09.00		11kv Phase to Phase near Depally	No
3		Kollur	Nawabpet	11KV	Jadcherla	00.00	14.20	14.20		11kv Jumper cut near Nawabpet	No
1	NLG	Pamanagundla	Yerrasanigudem	11KV	Nalgonda	5:30	9:56	4:26	E/L	11 KV Jumper Cut and Insulator failed	No
2		Buggabiagudem	Buggabiagudem	11KV	Mirylaguda	05.00	10.00	05.00	E/L	11KV Jumper cut	No
3		Mattapally	Mattapally	11KV	Huzurnagar	19.20	22.30	03.10	E/L	11Kv Jumper cut near Mattapally village	No
4		Repala	Repala	11KV	Huzurnagar	06.05	08.20	02.15	E/L	Due to Tree branch near Repala village	No
1	MDK	Munipally	Budhera	11KV	Sangareddy	9:10	10:15	1:05		11KV Jumper cut	No
2		Gaddapotharam	Vishnu	11KV	Patancheru	12.50	15.10	02.20		Tree fallen on the 11KV line	No
3		Thogit	H.Ghanpur	11KV	Medak	00.22	04.00	03.38		Disc failed	No
1	RR N	K P HB	ShathavahanaNagar	11KV	Kukatpally	4:50	6:10	1:20		11KV Pin insulator failed	No
2		J D M SS-IV	Auto stand	11KV	Jeedimetla	04.00	06.15	02.15		11KV Disc failed	No
3		J D M SS-IV	Tagore	11KV	Jeedimetla	04.00	06.45	02.45		T/f Hg fuse failed near Shusheel Plastic company	No
4		HMT	Ganesh Nagar	11KV	Medchal	04.35	05.35	01.00		No visible fault	No
5		Subash Nagar	Jairam Nagar	11KV	Medchal	04.03	05.03	01.00		Tree fallen on the 11KV line	No
6		Shameerpet	Nalsar	11KV	Medchal	04.30	05.10	00.40		11KV Conductor Snapped	No
7		Nuthankal	Bharathi	11KV	Medchal	06.38	07.31	00.53		Bird fallen on the 11KV line	No
1	RR E	Chengicherla	My Villas	11KV	Habsiguda	05.15	06.00	00.45		11KV Pole damaged at Gandhi Nagar	No
1	HYD N	Kalyan Nagar	A.G.Colony	11KV	Banjara Hills	04.15	07.05	02.50	EL	Cable Jumper cut & Tree branches fallen on lines at A.G.Colony Gate	No
2		I.D.P.L	Wonder Plast	11KV	Bowenpally	04.35	06.00	01.25	EL	No Visible fault (due to heavy Wind & Gale)	No
3		I.D.P.L	S.V.C.I.E.	11KV	Bowenpally	04.35	06.15	01.40	EL	No Visible fault (due to heavy Wind & Gale)	No
4		Road No.22	Road No.5	11KV	Banjara Hills	05.02	06.35	01.33	EL	Brass Patti B/O at Road No.10	No
1	HYD C	S.D.Hospital	Khadi Bandar	11KV	Mehdipatnam	03.15	04.35	01.20	EL,OL-Rph	Cable fault at opp.Vidyachal Apts	Arranged B/F on 11KV C.C.Nehru Park fdr