

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	1	1	1	1	1			
	Total	606	3055	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		2		2		2			
3	MDK	107	933		5		5		5			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	7	2	7	2	7	0	0	
	Grand Total	1082	6468	3	10	3	10	3	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.05.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Eduloor	Kurumathy	11KV	Nalgonda	08.15	12.15	04.00	E/L	11KV line Cut	-
2		Kattangur	Mallaram	11KV	Nalgonda	08.30	11.50	03.20	E/L	11KV Line Insulator Fialur	-
1	MDK	Thogita	Aurangabad	11KV	Medak	13.40	17.30	03.50		B/d due to tree branches on 11 KV wires	-
2		Sardhana	Jakkannapet	11KV	Medak	09.05	13.05	04.00		B/D due to AB Switch repair	-
3		Kowdipally	Mohd Nagar	11KV	Medak	00.00	07.00	07.00		B/D due to poles broken	-
4		Salabathpur	Mohd. Nagar	11KV	Medak	09.00	12.00	03.00		B/D due to poles broken	-
5		Gandhariaply	Gandharpally	11KV	Medak	06.00	06.44	00.44		B/D due to 11 KV line cut	-
1	RR S	Balajinagar	Dhanalaxmi	11KV	Kondapur	07.43	08.45	01.02		11KV Line AB Switch Opened. Apartments T/F Failed at MIG 154, KPHB Road No - 1.	-
1	RR E	CRPF	Chennapur	11KV	Habsiguda	07.50	10.00	2.10		25KVA T/F Failed at Arundathi Nagar and 25KVA T/F Failed at Malkaram	-
1	HYD S	Kandikalgate	Ashamabad	11KV	Charminar	06.55	08.05	01.10	EL,OL	UG Cable fault	Arranged B/F on 11KV Indira Nagar feeder

TSSPDCL - LMRC / Corporate office

Date: 28.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Hamsanpally	33kv	Mahabubnagar	14.50	17.02	02.12	E/L	for Pin binding Failed at Pole No 58	Hamsanpally	-
2		Singotam	Narsaipally	33kv	Nagarkurnool	08.19	10.59	02.40	E/L	Tree Branches Fallen on AB Switch	Narsaipally	-
1	HYD N	132KV Jubilee Hills	Hitech City Service) (HT	33kv	Jubilee Hills	08.55	11.57	03.02	OL-Bph	----	Hitech City Service) (HT	Loads transferred onto 132KV Madhapur SS via 33KV Madhapur-1 fdr