

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	5	23	5	23	5	23			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	5	24	5	24	5	24	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	(Within 24)		(Above 24)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT			2	11	2	11	2	11			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	14	3	14	3	14	0	0	
	Grand Total	1082	6468	8	38	8	38	8	38	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.05.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Grid	33KV	Mahabubnagar	22.15	00.00	01.45	O/L	Break down Not Rectified	Koilkonda Water Grid	-
1	Siddipet	Husnabad	Koheda	33KV	Siddipet	15.45	18.40	02.55		Insulator failed	Koheda	-
2		Musthyala	Komuravelly	33KV	Siddipet	17.45	18.40	00.55		Insulator failed	Komuravelly	-
1	RR N	Malkaram	Rathnalayam	33KV	Medchal	19.58	23.00	03.02		33KV jumper cut in SS	Rathnalayam	-
2		132KV Medchal	33KV Athiwelly	33KV	Medchal	21.40	23.05	01.25		Tree fallen on the 33KV Line	33KV Athiwelly	-
3		132KV Medchal	33KV Kandlakoya	33KV	Medchal	20.18	22.40	02.22		Tree fallen on the 33KV Line	33KV Kandlakoya	-
4		132KV Medchal	33KV Devarayamjal	33KV	Medchal	20.18	22.40	02.22		Tree fallen on the 33KV Line	33KV Devarayamjal	-
5		132KV Medchal	33KV Medchal-I	33KV	Medchal	20.15	23.59	03.44		Tree fallen on the 33KV Line	33KV Medchal-I	-

TSSPDCL - LMRC / Corporate office

Date: 29.05.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Midjil	Munnanoor	11KV	Jadcherla	11.30	14.30	03.00		11 Kv Jumper Cut Touched By The Channel Near Munnanoor Sarpanch Bavi Side.	-
1	NLG	Eduloor	Parada	11KV	Nalgonda	12.10	14.40	02.30	E/L	Jumper cut	-
2		Eduloor	G.B.Gudem	11KV	Nalgonda	05.00	08.30	03.30	E/L	Insulator failure	-
1	Siddipet	Nangnoor	Akkanapally	11KV	Siddipet	16.00	19.00	03.00		Pole Damage	-
2		Rampur	Palamakula	11KV	Siddipet	15.30	19.00	03.30		11 KV Wire Cut	-
3		Kondamrajally	Gatlamalyala	11KV	Siddipet	16.20	20.20	04.00		Pole Damage	-
4		Thornal	Thornal	11KV	Siddipet	06.05	07.45	01.40		Tree Branches fall on the 11 kv line	-
5		Thornal	Appanapally	11KV	Siddipet	11.31	12.12	00.41		Jumper Cut	-
6		Chinthamadka	Machapur	11KV	Siddipet	09.50	10.50	01.00		11 KV Wire Netting	-
7		Kondapur	Govardanagiri	11KV	Siddipet	14.00	15.28	01.28		Tree Branches fall on the 11 kv line	-
8		GANDIPALLY	All Feeders	11KV	Siddipet	16.30	00.00	07.30		Due to wind and rain	-
9		DHARMARAM	Nandaram	11KV	Siddipet	21.30	00.00	02.30		Due to wind and rain	-
10		DHARMARAM	DHARMARAM	11KV	Siddipet	21.30	00.00	02.30		Due to wind and rain	-
11		DHARMARAM	IFS	11KV	Siddipet	16.30	21.30	05.00		Due to wind and rain	-
1		Vijayanagar	New Venkateshawarnnagar	11KV	Kukatpally	21.25	22.50	01.25	E/L	Due Heavy Rain	-
2		Vijayanagar	AS Raju nagar	11KV	Kukatpally	21.25	22.55	01.30	EL/OL	Due Heavy Rain	-
3		Vijayanagar	Jayanagar	11KV	Kukatpally	21.40	23.50	02.10	EL&OL	Tree Branches Fallen on the 11kv line At Road 3 Vijayanagar	-
4		Huda Truck park	Sri Sai Nagar	11KV	Kukatpally	21.55	23.20	01.25	EL&OL	Tree Branches Fallen on the 11kv line At Vidayapress	-
5		H M T Hills	AddaGutta	11KV	Kukatpally	22.35	00.05	01.30	EL&OL	Tree Branches Fallen on the 11kv line & 11kv Pole Daimage At ICICI bank addagutta	-
6		G Vikas	Reddy Colony	11KV	Kukatpally	22.40	00.55	02.15	EL&OL	11kv Pin Insultor Failure At Bus Body Miyapur	-
7		Mayuri nagar	Laxmi Nagar	11KV	Kukatpally	22.35	23.45	02.20	EL&OL	T/F Brass Patti Cut At Laxmi nagar	-
8		Mayuri nagar	Cable	11KV	Kukatpally	22.35	23.50	01.10	EL&OL	11kv AB Cable Failure At Mayurinagar	-
9		J D Mss-IV	Tagorea	11KV	Jeedimetla	21.00	22.10	01.10	EL/OL	Due TO Heavy Rain	-
10		J D M SS-II	Phase-IV	11KV	Jeedimetla	21.16	00.55	03.39	EL/OL	11kv AB cable failure At phase-Iv[Due Heavy Rain}	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
11	RR N	Jagathgirikutta	Shiridi Hills	11KV	Medchal	21.28	00.00	02.32		AB Cable failed at Shiridi Hills	-
12		Gowdavelly	Basaragadi	11KV	Medchal	22.04	23.40	01.36		11KV Pin Insulator failed at Basaragadi Village	-
13		GP Pally	GP Pally	11KV	Medchal	21.30	00.00	02.30		Tree fallen on the 11KV Line at Forest	-
14		Medchal	Housing Board	11KV	Medchal	22.30	00.00	01.30		Tree fallen on the 11KV Line at Medchal	-
15		Medchal	CMR	11KV	Medchal	22.30	00.00	01.30		Tree fallen on the 11KV Line at Medchal	-
16		Medchal	Victory	11KV	Medchal	22.30	00.00	01.30		Tree fallen on the 11KV Line at Medchal	-
17		Aliabad	Majeedpur	11KV	Medchal	21.30	23.40	02.10		Tree fallen on the 11KV Line at Majeedpur Village	-
18		Aliabad	Bommarajpet	11KV	Medchal	21.30	00.00	02.30		Tree fallen on the 11KV Line at Bommarajpet Village	-
19		Aliabad	Jaganguda	11KV	Medchal	21.30	00.00	02.30		Tree fallen on the 11KV Line at Jaganguda Village	-
20		Kandlakoya	Kandlakoya	11KV	Medchal	22.40	00.00	01.20		Tree fallen on the 11KV Line at Kandlakoya Village	-
21		Kandlakoya	Saigeetha Asramma	11KV	Medchal	22.40	00.00	01.20		Tree fallen on the 11KV Line at Saigeetha Asramam	-
22		Devarayamjal	Kottapet	11KV	Medchal	22.45	00.00	01.15		Tree fallen on the 11KV Line at Kottapet Village	-
23		Devarayamjal	Pothaipally	11KV	Medchal	22.45	00.00	01.15		Tree fallen on the 11KV Line at Pothaipally Village	-
1	RR E	Yadgarpally	Yadgarpally	11KV	Keesara	08.30	09.40	01.10		Bird fallen on T/F near Chenna Reddy Thota	-