

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		10		10		10			
7	RR(E)	168	403		9		9		9			
8	Hyd	194	1044		44		44		44			
	Total	606	3055	0	63	0	63	0	63	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	12		6		6		6		8 Nos. 33KV Still
2	NLG	144	988	4	4	4	4	4	4			
3	MDK	107	933	10	14	8	14	8	14	2		2 Nos. 33KV Still
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	26	18	18	18	18	18	8	0	
	Grand Total	1082	6468	26	81	18	81	18	81	8	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepur	33KV	Mahabubnagar	19.45	00.00	04.15	O/L		Vepur	
2		Marikal	Eklaspur	33KV	Mahabubnagar	19.15	21.20	02.05	O/L	Pin Binding Replasmnt near Railway Track	Eklaspur	No
3		Putta pad	Salkarpet	33KV	Mahabubnagar	19.35	00.00	04.25	E/L		Salkarpet	
4		Narayanapet	Kotakonda	33KV	Narayanapet	19.40	00.30	04.50	E/L	2No Pin Insulator Replasmnt at Ammi Reddy Pally Village	Kotakonda	No
5		Wanaparthly	Kothakota	33KV	Wanaparthly	21.50	00.05	02.15	E/L&O/L	Back Feeding Supply taken form Kanayapally SS	Kothakota	Back Feeding Supply taken form Kanayapally SS at 24:05Hrs
6		leeza	Gattu	33KV	Gadwal	22.10	00.00	01.50	E/L&O/L		Gattu	
7		Shadnagar	Maamidipally	33KV	Jadcherla	17.25	20.42	03.17	E/L&O/L	LA Jumper Cut near at 220KV SS Shadnagar	Maamidipally	No
8		Shadnagar	Vijayanand	33KV	Jadcherla	17.25	01.10	07.45	E/L&O/L	Tree Fallen on the 33KV Line	Vijayanand	No
9		Shadnagar	Mogiligidda	33KV	Jadcherla	17.25	23.45	06.20	E/L&O/L	Tree Fallen on the 33KV Line	Mogiligidda	No
10		Shadnagar	Salasar	33KV	Jadcherla	17.25	00.00	06.35	E/L&O/L		Salasar	
11		Shadnagar	Srem Core	33KV	Jadcherla	17:25	00.00	06.35	E/L&O/L		Srem Core	
12		Midjil	Velgomula	33KV	Jadcherla	23.15	00.00	00.45	E/L		Velgomula	
1	NLG	Miryalaguda	Miryalaguda	33KV	Miryalaguda	18:15	21:15	3:00		Disc failed	Miryalaguda	No
2		Miyalaguda	Matur	33KV	Miryalaguda	18.15	20.25	02.10		Disc failed tree fallen on the line Heavy gail and Wind	Matur	No
3		Miyalaguda	Tripuraram	33KV	Miryalaguda	18.15	20.25	02.10		Tree fallen on the 33KV line heavy gail and wind at N.G.Ranga.	Tripuraram	No
4		Wadapally	A.D.Pally	33KV	Miryalaguda	18.45	23.10	04.25		Pin insuletor failed	A.D.Pally	No
1	MDK	Kandi	HFC-II	33KV	Sangareddy	2:00	13:20	11:20		Pin binding failed & Jumper cut	HFC-II	No
2		Kandi	HFC I	33KV	Sangareddy	01.55	13.45	11.50		Tree fallen on the line	HFC I	No
3		Kandi	Alkabeer	33KV	Sangareddy	02.10	13.45	11.35		Tree fallen on the line	Alkabeer	No
4		Kandi	ITW Signode	33KV	Sangareddy	02.15	18.55	16.40		Disc insulators failed	ITW Signode	No
5		Pashamailaram	Manjeera	33KV	Sangareddy	17.25	20.40	03.15		Jumper cut	Manjeera	No
6		Pashamailaram	APL IV	33KV	Sangareddy	01.45	09.30	07.45		Jumper cut	APL IV	No
7		Pashamailaram	APL IV	33KV	Sangareddy	17.58	00.00	06.02		Bus Jumper cut in 132KV Pashamailaram SS	APL IV	
8		Sadashivapet	Munipally	33KV	Sangareddy	16.05	20.55	04.50		Tree fallen on the line at Aroor village	Munipally	No
9		Zaheerabad	Jharasangam	33KV	Zaheerabad	17.50	21.00	03.10		Tree fallen on the line	Jharasangam	No
10		Pedda Shankarampet	Alladurg	33KV	Medak	18:06	0:00	5:54			Alladurg	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nuthankal	Polumaila	11KV	Suryapet	7:20	9:30	2:10	E/L	Conductor snapped	No
2		Famanagundla	Pittampally	11KV	Naigonda	08.25	11.40	03.15	E/L	11KV insulators failed	No
3		Devarakonda	Devarakonda Town 2	11KV	Devarakonda	17.30	18.45	01.15	E/L	HTLT	No
4		Rajavaram	Thirumalagiri	11KV	Miryalaguda	17.30	18.30	02.00	E/L	11KV Jumper cut at Yellapuram Thanda	No
1		Patancheru	MIA-1	11KV	Sangareddy	18:00	19:30	1:30		Jumper cut	No
2		Sangareddy - 1	Tallapally	11KV	Sangareddy	03.30	06.30	02.00		Bird fallen on the line	No
3		Sangareddy - 1	Friday Market	11KV	Sangareddy	17.05	18.00	00.55		Tree branch fallen on the line	No
4		Sangareddy - 1	Tallapally	11KV	Sangareddy	16.52	18.20	01.28		Tree branch fallen on the line	No
5		Kondapur	Gangaram	11KV	Sangareddy	07.00	10.00	03.00		Tree branch fallen on the line	No
6		Kondapur	Marepally	11KV	Sangareddy	12.00	13.30	01.30		T/F Felldown from Plinth	No
7		Cheryal	Julka	11KV	Sangareddy	03.45	06.10	02.25		Jumper cut	No
8		Cheryal	Kandi	11KV	Sangareddy	03.50	14.00	10.10		Conductor snapped & Insulator failed	No
9		Cheryal	Kalivemula	11KV	Sangareddy	03.35	06.00	02.25		Conductor snapped	No
10		Sangareddy - 2	SRD-3	11KV	Sangareddy	18.00	19.15	01.15		Jumper cut	No
11	Malkapur	Industrial	11KV	Sangareddy	16.35	17.35	01.00		B/D due to phase to phase	No	
12	Cheryal	Dulchand	11KV	Sangareddy	03.30	07.45	04.15		Jumper cut	No	
13	Cheryal	DVR	11KV	Sangareddy	16.40	17.50	01.10		AB Switch failed	No	
14	Isnapur	Patodia	11KV	Sangareddy	5:30	5:50	0:20		Due to heavy rain & wind	No	
1	RR N	G Vikas	Reddy Colony	11KV	Kukatpally	18.46	20:25	1:39	E/L	11KV Pin insulator failed	No
2		Huda Truck Park	Sri Sai Nagar	11KV	Kukatpally	18.15	19.40	01.25	EL/OL	11KV Pin insulator failed	No
3		G Vikas	Kendriya Vihar	11KV	Kukatpally	19.45	21.00	01.15	EL&OL	Tree fallen on The 11KV line	No
4		UMCC	Crusher	11KV	Medchal	18.20	21.00	02.40		11KV Pin insulator failed	No
5		Jagathgiri	Shiridi Hills	11KV	Medchal	17.55	19.54	01.59		11KV AB Cable failed	No
6		Subash Nagar	Padma Nagar	11KV	Medchal	18.25	20:25	02.00		No visible fault	No
7		Subash Nagar	Saibaba Nagar	11KV	Medchal	18.23	19.07	00.44		Due to phase to phase	No
8		Kolthur	Kolthur	11KV	Medchal	19.00	21.05	02.05		Tree fallen on The 11KV line	No
9		Alabad	Ravileela	11KV	Medchal	20.30	22.00	01.30		Binding wire fallen on the 11KV Line	No
10		Town Medchal	Balaji Nagar	11KV	Medchal	20:15	21:10	0:55		Conductor snapped	No
1	RR E	NGRI	St.No.08	11KV	Habsiguda	4.01	4.59	0.58		11KV Line snapped	No
2		NGRI	Scientist Colony	11KV	Habsiguda	19.10	20.15	01.05		33KV Pole bending and Touched to 11KV line	No
3		Moula-Ali	HCL	11KV	Sainikpuri	18.09	19.26	01.17		11KV AB Switch Open at Road No.4 Krishna Nagar	No
4		Moula-Ali	Mirzalaguda	11KV	Sainikpuri	18.10	21.00	02.50		No visible fault	No
5		Anandbagh	NMDC	11KV	Sainikpuri	18.40	19.40	01.00		11KV Line disc failed	No
6		Cherlapally-I	Nagaram	11KV	Sainikpuri	19.20	19.50	00.30		11KV Line cut	No
7		Kushaiguda	Neredmet	11KV	Sainikpuri	18.30	19.30	01.00		Tree branches fallen on the 11KV line	No
8		Kushaiguda	AS Rao Nagar	11KV	Sainikpuri	18.15	19.30	01.15		Tree branches fallen on the 11KV line	No
9		Mother Dairy	Ganesh Nagar	11KV	Saroomnagar	19:06	20:30	1:24		No visible fault	No
1		Macha Bollarum	Reddy Enclave	11KV	VJ	18.25	19.30	01.05	EL	No Visible Fault (Heavy Rain & Wind)	No
2	HYD N	Addagutta	Tagore Home	11KV	V	18:55	20:20	1:25	EL	Construction banner on lines at Naveen Super Market	No
3		Gymkhana	Rani Bagh	11KV	V	18:20	20:15	1:55	EL	Cable fault at Indiramma Nagar	No
4		Pragatools	Indo Swing	11KV	V	18:25	19:48	1:23	EL,OL-Rph	No Visible Fault (Heavy Rain & Wind)	No
5		Prashasan Nagar	Arogya Sri	11KV	X	19:30	20:54	1:24	EL	Tree branches fallen on lines at Road No.45	No
6		Marredpally	Addagutta	11KV	V	18:50	20:10	1:20	EL	No Visible Fault (Heavy Rain & Wind)	No
7		Film Nagar	B.V.Bhavan	11KV	X	18:35	22:20	3:45	EL,OL-Rph	Cable fault at B.V.Bhavan	Arranged B/F on 11KV Andhra Bank fdr
8		Toli Chowki	Hanuman Temple	11KV	X	20:02	21:07	1:05	OL-Bph	Tree branches fallen on lines at Pratap Reddy's House	No
9		Nehru Nagar	Nehru Nagar	11KV	V	19:05	20:40	1:35	EL	Disc Insulator flash over at Kasturiba College	No
10		Macha Bollarum	Sai Reddy Nagar	11KV	VJ	18:40	22:10	3:30	EL	Disc Insulator flash over at Sai Reddy Nagar	No
11		Yellareddyguda	Engineers Colony	11KV	X	18:02	20:00	1:58	EL,OL-Bph	Tree branches fallen on lines at Sri Ram Apts	No
12		Prashasan Nagar	B.N.R.Hills	11KV	X	19:30	00:56	05:26	EL	Pin Insulator flash over at B.N.R.Hills	No
1		HYD S	Ch' Baradari	Ch' Baradari	11KV	III	18:35	20:20	01:45	EL,OL-Yph	HT Jumper cut at Mochi Colony
2	Miralam		Mustafa Nagar	11KV	III	18:35	20:25	1:50	EL	Pin Insulator flash over at Satra Masjid	No
3	Kanchanbagh		Darga	11KV	VIII	18:44	20:26	1:42	EL,OL-Rph	Tree branches fallen on lines at Matha PT	No
4	Falaknuma		Falaknuma UG	11KV	III	18:45	20:31	1:46	EL	Sparking AB Switch & Jumper cut at Zam Zam Cafe	No
5	Kandikalgate		Rakshapuram	11KV	III	19:00	20:50	1:50	EL,OL-R&Yph	Bamboo Stick fallen on lines & Line snapped at St.Mary School	No
6	Moosarambagh		S.B.I Colony	11KV	VIII	19:20	21:10	1:50	EL	Tree branches fallen on lines at S.B.I Colony	No
7	Gunj		Race Course	11KV	VIII	18:51	20:33	1:42	EL	Tree branches fallen on lines at Ajantha Colony	No
8	Panjesha		Dazzling School	11KV	III	18:55	20:10	1:15	All Indication	Tree branches fallen on lines at Dazzling School & Cable Jumper touching to Pole at Talabkatta	No
9	Falaknuma		Chatrinaka	11KV	III	19:35	21:00	1:25	OL	Cable End Kit failed at Chatrinaka X Road (1No. DTR kept off)	No
10	Asmangadh		Gadiannaram	11KV	VIII	18:22	21:52	3:30	EL	DTR AB Switch Insulator flash over at Sri Nilayam Apts, Gadiannaram	No
11	Asmangadh		Shiva Ganga	11KV	VIII	18:40	20:22	1:42	EL,OL	No Visible Fault (Heavy Rain & Wind)	No
12	Asmangadh		Gowtham Nagar	11KV	VIII	19.15	21.15	02.00	EL	Breaker problem at SS	Arranged B/F on 11KV Saibaba Temple fdr
1	HYD C	Jawahar Nagar	Jawahar Nagar	11KV	I	18.59	20.15	01.16	EL	No Visible Fault (Heavy Rain & Wind)	Arranged B/F on 11KV Post Office fdr
2		Z.P Office	Z.P Office	11KV	I	18.24	20.14	01.50	OL	No Visible Fault (Heavy Rain & Wind)	No
3		Amberpet	6 Number	11KV	II	18.45	20.00	01.15	EL	Tree branches fallen on lines at Bata Show Room	No
4		Amberpet	Sanjeevaiah Nagar	11KV	II	18.25	20.40	02.15	EL,OL-Rph	Tree branches fallen on lines at Tilak Nagar	No
5		Bathkammakunta	C.E Colony	11KV	II	18.25	20.30	02.05	EL,OL-Rph	Pin Insulator flash over at Nanda Raj Gowd	No
6		Bathkammakunta	Bathkammakunta	11KV	II	18.25	19.50	01.25	EL,OL-Rph	No Visible Fault (Heavy Rain & Wind)	No
7		Bathkammakunta	Shivam Road	11KV	II	18.25	20.45	02.20	EL,OL-Rph	Tree branches fallen on lines at Shivam Road	No
8		Fever Hospital	Tourist Hotel	11KV	II	19.10	20.20	01.10	EL	Faulty DTR at Badruka DTR	No
9		Fever Hospital	Sriram Nagar	11KV	II	19.30	20.40	01.10	EL	Tree branches fallen on lines at SS backside	No
10		Fever Hospital	BKP Bus Depot	11KV	II	18.34	20.00	01.26	EL	Tree branches fallen on lines at Kachiguda	No
11		Durga Nagar	Krishna Nagar	11KV	II	19.25	21.10	01.45	EL,OL-Rph	Tree branches fallen on lines at Krishna Nagar	No
12		Hyderguda	Boggu Kunta	11KV	II	18.20	20.50	02.00	EL,OL-Rph	Faulty DTR at Meena Bazar	No
13		Asif Nagar	Hakimpet	11KV	VII	18.20	19.50	01.30	EL	No Visible Fault (Heavy Rain & Wind)	No
14		Asif Nagar	Kakatiya Nagar	11KV	VII	18.20	20.10	01.50	EL,OL	No Visible Fault (Heavy Rain & Wind)	No
15		Narayanguda	Preventive Medicine	11KV	II	18.20	19.35	01.15	EL,OL-Rph	No Visible Fault (Heavy Rain & Wind)	No
16		Narayanguda	Narayanguda	11KV	II	18.20	19.35	01.15	EL,OL-Rph	No Visible Fault (Heavy Rain & Wind)	No
17	Hyderguda	Urdu Hall	11KV	II	18.17	22.00	03.43	EL	No Visible Fault (Heavy Rain & Wind)	Partial fdr charged & remaining loads added on 11KV Himayath Nagar fdr	
18	Exhibition	J.N.	11KV	I	19.10	22.00	02.50	EL	Pin Insulator flash over at Collector Office	No	
19	Jawahar Nagar	Ashok Nagar	11KV	I	18.29	19.45	1:16	EL	No Visible Fault (Heavy Rain & Wind)	No	
20	Goinaka	Sai Madhura Nagar	11KV	II	18.47	20.00	01.13	EL	No Visible Fault (Heavy Rain & Wind)	No	