

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	2	3	2	3	2	3			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	4	3	4	3	4	0	0	
	Grand Total	1082	6468	3	4	3	4	3	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.11.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Chinchode	33kv	Shadnagar	12.15	13.15	01.00	EL	AB Switch open at Burgula(Garden Lizard Fallen on the Line)	Chinchode	-
1	NLG	Marriguda	33Kv Water Grid	33kv	Nalgonda	10.40	12.45	02.05		Chaist to Earh Falt	33Kv Water Grid	-
2		Ramannapet	Veliminedu	33kv	Nalgonda	08.55	11.40	02.45		33KV Insulator Fail	Veliminedu	-

TSSPDCL - LMRC / Corporate office

Date: 01.11.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Aitipamula	G.B Gudem	11kv	Nalgonda	08.00	10.00	02.00	EL	HT By LT Line Melting	-
2		Velugupally	Velugupally	11kv	Suryapet	11.05	13.05	02.00	EL	Insulator flashover	-
3		Sirikonda	Balluthanda	11kv	Huzurnagar	05.10	08.00	02.50	EL	Due to 11Kv line cutted	-
1	MDK	Bollaram -I	Soubhagya	11kv	Sangareddy	01.00	03.04	02.04		B/D due to Conductor Snapped	-