

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	8	0	8	0	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 06.11.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Reddygudem	Kukkadam	11KV	Suryapet	6:20	19:10	2:50	EL	Conductor snapped	No
2		Mellacheruvu	Y madaram	11KV	Huzurnagar	04.00	06.30	02.30	EL	Jumper cut	No
3		MR.Gudem	Basapuram	11KV	Bhongir	08.30	09.30	01.00	EL	Conductor snapped	No
4		Rajapet	Renikunta	11KV	Bhongir	09.30	14.00	04.30	EL	Conductor snapped	No
1	MDK	Patancheru Town	Town Ind	11KV	Patancheru	15:00	16:30	1:30		Conductor snapped	No
1	HYD N	H.A.L	Samrat	11KV	Bowenpally	17.45	18.55	01.10	All Indi	3No HT Lines snapped at Navajeevan Nagar	No
1	HYD S	Falaknuma	Farooq Nagar	11KV	Charminar	15.48	17.15	01.27	EL,OL-Rph	Conductor snapped at Farooq Nagar	No
1	HYD C	Vittalwadi	Gandhi Kuteer	11KV	Azamabad	17.10	18.12	01.02	EL,OL-Rph	Cable Fault at Airbus Lane	No