

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | | | | | | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 2 | | 2 | | 2 | | | |
| | Total | 606 | 3055 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | 1 | | 1 | | 1 | | | |
| 2 | NLG | 144 | 988 | 2 | 2 | 2 | 2 | 2 | 2 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | 1 | | 1 | | 1 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 2 | 4 | 2 | 4 | 2 | 4 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 2 | 6 | 2 | 6 | 2 | 6 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 11.11.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|-----------------------------------|---|
| 1 | MBNR | Ponnakal | Ponnakal | 11KV | Jadcherla | 07.00 | 08.10 | 01.10 | | Phase to Phase near Ponnakal | - |
| 1 | NLG | Cheedella | Gajulamalkapuram | 11KV | Suryapet | 04.30 | 07.25 | 02.55 | EL | Conductor snapped | - |
| 2 | | Aitipamula | Rasoolgudem | 11KV | Nalgonda | 13.18 | 15.30 | 02.12 | EL | 11KV Jumper cut | - |
| 1 | SDPT | Husnabad | Husnabad Town-2 | 11KV | Husnabad | 10.35 | 11.15 | 00.40 | | Break down due to breaker problem | - |
| 1 | HYD S | Attapur | Kishanbagh OH | 11KV | Asmangadh | 07.55 | 10.35 | 02.40 | EL,OL | Jumper cut at Gurudwara | (08:25 Hrs) 50% Partial feeder charged stood OK |
| 2 | HYD N | Bhudevi Nagar | Maruthi Nagar | 11KV | Erragadda | 12.20 | 13.25 | 01.05 | EL | Cable fault at SS | Arranged B/F on 11KV Chinna Kamela feeder |

TSSPDCL - LMRC / Corporate office

Date: 11.11.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--------------------------|-----------------------|---------------------------|
| 1 | NLG | Munagala | Bethavolu | 33kv | Huzurnagar | 12.30 | 14.25 | 01.55 | | Breaker Problem | Bethavolu | - |
| 2 | | Shaligowraram | Akaram | 33kv | Nalgonda | 17.10 | 18.20 | 01.10 | | Lighting arrested failed | Akaram | - |