

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	1		1		1				
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1		1		1				
	Total	606	3055	2	2	2	2	2	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	9	0	9	0	9	0	0	
	Grand Total	1082	6468	2	11	2	11	2	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.11.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR S	220kv Shamshabad	33kv Shamshabad-(Town)	33KV	RJNR	3:50	12:35	8:45	B/D	33KV Cable failure at ORR Railway crossing	33kv Shamshabad-(Town)	At 09:00 hrs. Alternate supply arranged from 33 KV Shamshabad-rural feeder
1	HYD N	132KV Erragadda	Jana Priya	33KV	Allwyn	00.50	01.03	00.13	EL,OL	Old Cable Joint failed	Jana Priya	Loads transferred onto 132KV Erragadda SS vai 33KV IDPL SS

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Moosapet	11KV	Jadcherla	06.30	10.10	03.40		11KV Wire cut near Nizalapur	No
1	NLG	Mukundapuram	Somaram	11KV	Huzurnagar	6:45	9:41	2:56	E/L	11KV Line cut	No
2		Mattampally	Choutupally	11KV	Huzurnagar	07.30	09.00	01.30	E/L	11KV Jumper cut	No
3		Karivirala	Karivirala	11KV	Huzurnagar	03.00	04.30	01.30	E/L	Insulator failed	No
4		Suraram	Suraram	11KV	Nalgonda	13.10	15.20	02.10	E/L	11KV Jumper cut	No
5		Rajupet	Rajupet	11KV	Nalgonda	07.30	12.10	04.40	E/L	11KV Jumper cut	No
6		Eduloor	Parada	11KV	Nalgonda	08.00	12.30	04.30	E/L	Insulator failed	No
7		Koppole	A.B.Colony	11KV	Devarakonda	05.00	07.30	02.30	E/L	11KV Jumper cut	No
8		Pittalagudem	Pittalagudem	11KV	Devarakonda	10:00	14:30	4:30	E/L	Insulator failed	No
1	RR N	ICICI	Bharath Biotech	11KV	Medchal	10:27	11:40	1:13		Snake fallen on the 11KV Line at Genetic Company	No
1	RR E	Yadgarpally	Thimapally	11KV	Keesara	1:30	3:30	2:00		11KV Disc failed at Thimaipally village	No