

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	1								
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	1	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		6		6		6			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	11	1	11	1	11	0	0	
	Grand Total	1082	6468	2	13	1	13	1	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.11.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Zaheerabad	Phiramil	33KV	Zaheerabad	02.30	07.30	05.00		BD due to After petrolling no fault at found		-
1	RR S	220kv Shamshabad	33kv Shamshabad-Rural	33KV	RJNR	00.25	03.45	03.20	B/D	33kv Y phase Jumper cut at Four pole structure		-

TSSPDCL - LMRC / Corporate office

Date: 15.11.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kandoor	Choudaipally	11KV	Jadcherla	09.04	14.50	05.46		11KV Disc Failure Near Sunkarampally (VI).	-
1	NLG	Penpahad	Dubba Thanda	11KV	Suryapet	08.30	11.00	02.30	E/L	11Kv Insulator flashover	-
2		Palakaveedu	Bothalapalem	11KV	Huzurnagar	03.30	07.00	03.30	E/L	11Kv line Snaped	-
3		Mattapally	Mattapally	11KV	Huzurnagar	00.00	02.30	02.30	E/L	11Kv Disk failure	-
4		Ananthagiri	Mogalaikota	11KV	Huzurnagar	02.15	05.00	02.45	E/L	HT /Lt fault occurred	-
5		Turkapally	M.Gouraram	11KV	Nalgonda	08.30	12.30	04.00	E/L	11KV Insulator failed	-
6		Voligonda	Voligonda(T)	11KV	Choutuppal	07.56	10.05	02.09	E/L	11kv Pin Insuletor Faill near Voliginda ss	-
1	MDK	Narayankhed	Jukal	11KV	Jogipet	15.15	16.20	01.05		B/D due to Conductor Snapped near Jukal(V)	-
2		Karasgutti	Outhathpur	11KV	Jogipet	06.00	08.10	02.10		B/D due to Conductor Snapped near Outhathpur(V)	-
3		Patancheru Town	Town	11KV	Patancheru	15.15	16.00	00.45		BD due to T/F cable brust	-
1	SDPT	Komuravelli	Kistampet	11KV	Siddipet	07.30	14.30	01.00		Conductor snapped	-
1	RR N	Subhash nagar	Ramraj Nagar	11KV	Medchal	21.10	22.40	01.30	BD	11KV Pin Insulator failed at Green Park	-
1	RR E	Sai nagar	Maruthi nagar	11KV	Habsiguda	03.30	04.30	01.00		11KV pole damaged due to car dashed at Maruthi nagar	-