

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988	1	10	1	10	1	10			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	13	1	13	1	13	0	0	
	Grand Total	1082	6468	1	20	1	20	1	20	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.11.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Dilchinchera	Garidepally	33KV	Huzurnagar	3:00	6:30	3:30	EL/OL	33KV Jumper cut	Garidepally	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	24 hrs	11KV	Jadcherla	07.45	10.53	03.08		11KV Insulator failed near Bathai thota at Janampet	No
2		Kothapally	Kanchan pally	11KV	Jadcherla	06.31	09.02	02.31		Tree fallen on 11KV line near ranipet (V)	No
1	NLG	B.Chandupatla	Thimmapuram	11KV	Suryapeta	4:30	7:15	2:45		Insulator flashover	No
2		Mattampally	Choutapally	11KV	Huzurnagar	06.00	07.30	01.30		11KV Insulator failed	No
3		Garidepally	Ponugodu	11KV	Huzurnagar	07.00	09.30	02.30		11KV Line snapped	No
4		Angadipeta	Akkampally	11KV	Devarakonda	08.00	09.30	01.30		11KV Insulator failed	No
5		Gurraladandi	Industrial	11KV	Bhongiri	05.10	08.10	03.00		11KV Disc failed near Pedhapally Villge	No
6		Rajapeta	Pamukunta	11KV	Bhongiri	06.00	09.45	03.45		11kv Insulator failed near Putagandhi Villge	No
7		Azeempeta	Azeempeta	11KV	Bhongiri	12.10	15.10	03.00		11KV Insulator failed near Kondampet Village	No
8		Thimannagudem	Chennaram	11KV	Nalgonda	02.00	05.00	03.00		11KV Line Jumper Cut	No
9		Kattangur	Kalimera	11KV	Nalgonda	02.50	06.00	03.10		11KV Line Jumper Cut	No
10		Narketpally	Mandra	11KV	Nalgonda	12:00	14:50	2:50		Insulator failed	No
1	MDK	Alamaipet	Alamaipet	11KV	Jogipet	16:40	18:25	1:45		Jumper cut near yettigadda(V)	No
1	RR S	Kismathpur	LV Prasad	11KV	RJNR	11:30	13:00	1:30		Breaker fault	B/F Given on 11KV Difence colony
1	RR N	Mayurinagar	Gokaraju Rangaraju	11KV	Kukatpally	9:45	10:50	1:05	EL/OL	Insulator failed	No
2		UMCC	UMCC	11KV	Medchal	06.00	16.15	10.15		CT PT failed at UMCC	No
3		Shameerpet	Alankrita	11KV	Medchal	08.20	09.40	01.20		11KV Disc failed at Celebraty Opposite	No
1	HYD N	Borabanda	Saradhi Nagar	11KV	Erragadda	02.08	03.58	01.50	EL,OL	Cable fault	Arranged B/F on 11KV Kalyan Nagar Park feeder
1	HYD S	Gunj	Judges Colony	11KV	Asmangadh	02.20	03.45	01.25	OL-Y&Bph	Cable Jumper Phase to Phase at Sohail Hotel	Arranged B/F on 11KV Yashoda Hospital fdr
2		Malakpet	Yashoda Hospital	11KV	Asmangadh	5:25	6:35	1:10	All Indication	Line AB Switch Jumper cut at Nalgonda X-Roads	No