

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	2	10	2	10	2	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.11.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Miryalaguda	Huzurnagar	33KV	Miryalaguda	14.31	16.30	01.59		Jumpet Cut Near Gudur Village		-
1	MDK	Borapatla	Feeder 4	33KV	Jogipet	07.10	10.20	03.10		B/D Due to Pin Insulator Failure		-

TSSPDCL - LMRC / Corporate office

Date: 22.11.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Gurukunta	11KV	Jadcherla	11.00	13.00	02.00		Due to 11 kv disk fail near makaloni kunta thanda.	-
1	NLG	Huzurnagar	Singaram	11KV	Huzurnagar	12.25	14.30	02.05	EL	11KV Line Snapped	-
2		Thogarrai	Kuchipudi	11KV	Huzurnagar	09.35	10.40	01.05	EL	11KV Line Snapped	-
3		Repala	Narsimhalagudem	11KV	Huzurnagar	07.40	10.00	02.20	EL	11KV Line Snapped	-
4		Nameragomla	RNC Inld	11KV	Bhongiri	02.02	07.45	05.43	EL	11KV Disk Failed Near Jamelapet Village	-
1	MDK	Gummadidala	Agrobell	11KV	Patencheru	11.15	12.10	00.55		B/D Due to Insulator Failure	-
1	RR N	Subhash nagar	Pragha tools	11KV	Medchal	21.35	22.40	01.05	BD	Bird fallen on the 11KV Line at Praghatools Colony	-
2		Bommarajpet	Ponnal	11KV	Medchal	04.30	05.30	01.00	BD	11KV Pin Insulator Failed at Madhu thota,Ponnal	-
1	HYD N	I.D.P.L	Bala Nagar	11KV	Bowenpally	10.45	12.02	01.17	EL	Cable fault at Bala Nagar	Partial fdr charged at 11:00Hrs & remaining loads added on 11KV Shivalayam fdr
1	HYD S	Petlaburz	Ghansi Bazar	11KV	Charminar	03.45	06.15	02.30	EL	Incoming Cable fault	Arranged B/F on 11KV Madina fdr