

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 24.11.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Kandi	Sangareddy - I	33KV	Sangareddy	18.10	19.30	01.20		BD DUE TO B PHASE JUMPER CUT AT KANDI SS	Kandi	No

TSSPDCL - LMRC / Corporate office

Date: 24.11.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Munagala	Kokkireni-II	11KV	Huzurnagar	03.45	07.10	03.25	EL	Due to Ab switch open	-
2		Kandibanda	N.B.Gudem	11KV	Huzurnagar	08.05	08.45	00.40	EL	HT/ LT Fault	-
3		Madugulapally	Kukkadam	11KV	Nalgonda	11.05	12.50	01.45	EL	11 KV Line Insulator Failed	-
1	RR N	Kompally	Kompally	11KV	Medchal	04.10	04.48	00.38		11KV Cable Kit failed at Dulapally Road	-
2		UMCC	Mahadevpuram	11KV	Medchal	09.30	10.00	00.30		11KV Line cut and replaced at Yandamuri Layout	-
3		Jagathgirigutta	Shirdi Hills	11KV	Medchal	18.20	21.40	03.20		11KV AB Cable Failed at RGK	-
1	HYD C	Chilkaiguda	Golconda X-Roads	11KV	Azamabad	02.25	03.50	01.25	EL,OL	Cable fault at Musheerabad P.S	Arranged B/F on 11KV Dayara Market feeder