

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 30.11.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Peddanandigama	33KV	Vikarabad	12.28	14.40	02.12	E/L	Tree Fallen on the 33KV line	Kodangal	No

## TSSPDCL - LMRC / Corporate office

Date: 30.11.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddarevelly	Rajapur	11KV	Jadcherla	10.40	13.00	02.20		.11KV Wire Cut And 11KV insulator Failure Near Bheemreddybavi Peddarevelly( Vi).	-
2		Peddarevelly	Chennavelly	11KV	Jadcherla	02.30	09.30	07.00		Tree Follen On The 11 Kv Line Near Chennavelly( Vi).	-
1	NLG	Reddygudem	Kukkadam	11KV	Suryapet	10.54	12.40	01.46	E/L	Squirrel fallen on the line	-
2		Chepur	Mosangi	11KV	Devarakonda	07.45	10.00	02.15	E/L	11Kv Jumper Cutt	-
1	HYD N	H.A.L	Sowbhagya Nagar	11KV	Bowenpally	11.25	12.50	01.25	EL	Cable fault at Sowbhaya Nagar	Partial fdr charged & remaing loads added on 11KV Giri Nagar fdr