

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------|------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 1 | | 1 | | 1 | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 1 | | 1 | | 1 | | | |
| | Total | 606 | 3055 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|-------------|-------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 4 | 1 | 4 | 1 | 4 | 1 | | | |
| 2 | NLG | 144 | 988 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 107 | 933 | 2 | 5 | 2 | 5 | 2 | 5 | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 6 | 10 | 6 | 10 | 6 | 10 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 6 | 12 | 6 | 12 | 6 | 12 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 01.10.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | MBNR | Annasagar | Tatikonda | 11kv | Jadcherla | 10.30 | 13.59 | 03.29 | | AB Switch Failed Near Thatikonda(V) | - |
| 1 | NLG | Penpahad | Anajipuram | 11kv | Suryapeta | 05.00 | 08.20 | 03.20 | E/L | Insulator Flashover | - |
| 2 | | Pamanagundla | Pittampally | 11kv | Nalgonda | 06.00 | 07.40 | 01.40 | E/L | 11KV Line Jumper cut | - |
| 3 | | Palem | Oogodu | 11kv | Nalgonda | 08.00 | 10.00 | 03.00 | E/L | 11KV Insulator Failure | - |
| 4 | | Garidepally | Ponugodu | 11kv | Huzurnagar | 04.30 | 06.50 | 02.20 | E/L | 11KV Line Jumper cut | - |
| 1 | MDK | Isnapur | wedia | 11kv | Sangareddy | 14.25 | 15.25 | 01.00 | | B/D Due to Jumper Cut | - |
| 2 | | EPIP-III | SAI DEEPA | 11kv | Sangareddy | 14.45 | 16.20 | 01.35 | | B/D Due to Conductor Snapped | - |
| 3 | | Isnapur | Kyasaram | 11kv | Sangareddy | 14.44 | 16.44 | 02.00 | | B/D Due to Jumper Cut | - |
| 4 | | Isnapur | Muthangi Agl | 11kv | Sangareddy | 14.55 | 16.55 | 02.00 | | B/D Due to Insulator Failure | - |
| 5 | | SRD-T-II | SRD-T-III | 11kv | Sangareddy | 17.10 | 17.55 | 00.45 | | B/D Due to tree branches fallen on the line | - |
| 1 | RR N | Medicity | Rajabollaram | 11kv | Medchal | 06.00 | 07.00 | 01.00 | | Bird Fallen on 11KV Line at Cheruvu,Akbarpet | - |
| 1 | HYD S | Panjesha | Panjesha | 11kv | III | 01.05 | 02.15 | 01.10 | EL,OL | Cable fault at Opp: Charminar Bus Stop | |

TSSPDCL - LMRC / Corporate office

Date: 01.10.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|-----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|---------------------------|
| 1 | MBNR | Maddur | Kothapally | 33kv | Narayanapet | 14.50 | 17.30 | 02.40 | E/L | Insulator Flash Over at Yerraguntla Thanda | Kothapally | - |
| 2 | | Maddur | Vepur | 33kv | Narayanapet | 14.35 | 21.15 | 06.40 | E/L&O/L | Insulator Damaged and V Crosaram Damaged near at Pedrapadu Village | Vepur | - |
| 3 | | Marikal | Koilkonda Water Gridd | 33kv | Narayanapet | 16.20 | 20.20 | 04.00 | E/L | Insulator Replacment | Koilkonda Water Gridd | - |
| 4 | | Gadwal | Nandinne | 33kv | Gadwal | 15.38 | 18.15 | 02.37 | E/L | Pin Insulator Failed at Chinta Revula | Nandinne | - |
| 1 | MDK | Pashamailaram | Manjeera | 33kv | Sangareddy | 16.58 | 17.35 | 00.37 | | B/D Due to tree Branches fallen on the line | Manjeera | - |
| 2 | | Zaheerabad | Mannapur | 33kv | Zaheerabad | 17.50 | 19.20 | 01.30 | | B/D Due to Insulator Failure | Mannapur | - |