

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	4	1	4	1	4	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.10.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Pashamailaram	BOC	33KV	Sangareddy	7:15	12:40	5:25		CTPT blast at company side	BOC	No

TSSPDCL - LMRC / Corporate office

Date: 02.10.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Alingapuram	Gundlapahad	11KV	Huzurnagar	8:00	10:00	2:00	EL	11KV Jumper cut	No
2		Keethavarigudem	K K Thanda	11KV	Huzurnagar	06.00	09.15	03.15	EL	11KV Jumper cut	No
1	MDK	Shalipet	Shalipet	11KV	Medak	0:00	10:45	10:45		Tree fallen on the 11KV line	No
2		Gangaram	Bandapothugal	11KV	Medak	19.15	10.30	15.50		Insulator failed	No
1	RR N	Devarayamjal	kottapet	11KV	Medchal	2:30	4:20	1:50		Bird fallen on the 11KV line	No
1	RR E	Cherlapally-IV	Sai Nagar	11KV	Sainikpuri	19:30	20:10	0:40		11KV Jumper cut at Jyothi Appartment	No
1	HYD N	Raheja	Gafoor Nagar	11KV	Jublee Hills	11.05	13.54	02.49	OL-Bph	Relay problem at SS	Arranged B/F on 11KV Vaishnavi Residency fdr
1	HYD S	Malakpet	Noorkhan Bazar	11KV	Asmangadh	15.30	17.25	01.55	OL-Rph	Cable fault at Noorkhan Bazar (1No. DTR kept off)	Arranged B/F on 11KV Komatiwadi feeder
2		Malakpet	Noorkhan Bazar	11KV	Asmangadh	17:35	19:10	1:35	EL,OL	Cable fault (3No. DTR's kept off)	