

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	8	0	8	0	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.10.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thogarrai	Kuchipudi	11KV	Huzurnagar	6:20	8:30	2:10	EL	11 KV Line snapped	No
2		Bibigudem	Bibigudem	11KV	Suryapet	12.30	14.30	02.00	EL	Insulator failed	No
3		Madgulapally	Kukkadam	11KV	Nalgonda	09.30	11.40	02.10	EL	11KV Line Jumper Cut	No
4		Aregudem	Chinnakaparthi	11KV	Nalgonda	06.30	10.10	03.40	EL	11KV Insulator Failed	No
5		Narketpally	M.Yedavaly	11KV	Nalgonda	12:15	16:00	3:45	EL	11KV Line Jumper Cut	No
1	RR N	Thurkapally	Thurkapally	11KV	Medchal	8:15	9:15	1:00		11KV Jumper cut and replaced at Prajay Water plant	No
2		Devarayamjal	Kottapet	11KV	Medchal	00.00	01.10	01.10		Tree fallen on the 11KV line at Radhika Garden	No
1	HYD C	Industrial Area	D.D.H	11KV	Azamabad	03.15	06.22	03.07	EL,OL-Rph	Cable fault	partial fdr charged at 03:50 hrs. remaining partial fdr arranged B/F on 11KV Shivam fdr