

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | 1 | | 1 | | 1 | | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | 1 | | 1 | | 1 | | | | |
| | Total | 606 | 3055 | 2 | 0 | 2 | 0 | 2 | 0 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 2 | | 2 | | 2 | | | | |
| 2 | NLG | 144 | 988 | | 1 | | 1 | | 1 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | 2 | | 2 | | 2 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 2 | 3 | 2 | 3 | 2 | 3 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 4 | 3 | 4 | 3 | 4 | 3 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 04.10.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|-------------------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|---|
| 1 | MBNR | Balanagar | G R Cable | 33KV | Jadcherla | 17.35 | 18.50 | 01.15 | E/L | AB Switch Open at Kettherddy Pally & Tree branches fallen on the line at Rangareddy Guda Chowarsta | G R Cable | - |
| 2 | | Marikal | Koukuntla | 33KV | Narayanapet | 15.25 | 18.35 | 03.10 | O/L | Insulator Replacment at Dukur Village | Koukuntla | - |
| 1 | RR N | Medchal | Steelmill | 33KV | Medchal | 09.18 | 10.55 | 01.37 | BD | 33KV B phase jumper cut and replaced in ss | 33KV Steelmill | - |
| 1 | HYD C | 132KV Imlibun - Seetharambagh | Gosha Mahal | CEN | Asif Ngr | 12.44 | 17.09 | 04.25 | EL | Bph Pin Insulator flash over & Line touching to Tower near Puranapool Bridge | Gosha Mahal | At 12.58 hrs Loads transferred onto 132KV Asif Nagar SS via 33KV Kulsumpura SS & 17.09 hrs Loads normalised |

TSSPDCL - LMRC / Corporate office

Date: 04.10.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|------------------------|---------------------------|
| 1 | NLG | Raghunadhpalem | Nakkalagudem | 11KV | Huzurnagar | 11.00 | 12.00 | 01.00 | E/L | 11KV Insulator failure | - |
| 1 | SDP | Thotapally | Kondapur | 11KV | Husnabad | 13.15 | 13.50 | 00.35 | | Insulator failure | - |
| 2 | | Bekkal | kutigal | 11KV | Husnabad | 06.00 | 10.00 | 04.00 | | Insulator failure | - |