

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 08.10.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD S	220KV Shivrampally	Hyderguda	ST	Malakpet	15.10	15.27	00.17	EL	Cable damaged by H.R.D.C. near Pillar No.218, PVNR Highway		Loads transferred onto 220KV Shivrampally SS via 33KV Karwan fdr

TSSPDCL - LMRC / Corporate office

Date: 08.10.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nuthanakal	Nuthanakal town	11KV	Suryapeta	15.55	17.30	01.35	E/L	Jumper cut	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	06.30	09.30	03.00	E/L	Jumper cut	-
3		Pamanagundla	Yerrasanigudem	11KV	Nalgonda	05.30	08.00	02.30	E/L	Insulator failure	-
4		Alingapuram	Gundlapahad	11KV	Huzurnagar	14.30	17.25	02.55	E/L	11KV Line cut	-
5		Repala	V.R.Puram	11KV	Huzurnagar	07.50	10.30	02.40	E/L	Jumper cut	-
1	RR S	Kokapet	Brundhavan colony	11KV	Ibrahimbagh	10.45	11.45	01.00		11KV Pole broken at mattigadda	-
1	RR N	Nizampet	Rajadhani School	11KV	Kukatpally	15.40	17.00	01.20	EL OL	11kv line Jumper cut & Crasaram Touch near pochamma Temple	-