

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	1	5	1	5	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.10.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Zaheerabad	Machanoor	33KV	Zaheerabad	12:20	16:30	4:10		Cable kit Jumper cut	Machanoor	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Paldugu	Panakabanda	11KV	Bhongir	11:40	14:15	2:35	E/L	11KV Pin insulator failed	No
2		Koduru	Loyapally	11KV	Suryapet	15.00	16.45	01.45	E/L	11Kv Conductor snapped	No
3		Dirincherla	Yallapuram	11KV	Huzurnagar	15.45	19.00	03.15	E/L	11Kv Conductor snapped	No
4		R N Palem	Nakkagudem	11KV	Huzurnagar	06.00	08.30	02.30	E/L	11Kv Conductor snapped	No
1	MDK	Isnapur	IDA Isnapur	11KV	Sangareddy	13:03	16:35	3:32		11KV Pole damaged	No
1	RR S	Chandanagar	Market	11KV	Gachibowli	17:05	18:10	1:05		Tree brabches fallen on the line	No
1	RR N	Aeap	Doctors Colony	11KV	Jeedimetla	5:37	6:45	1:08	EL/OL	11KV AB Cable End Kit failed at Pragna School	No
2		Shameerpet	Shameerpet	11KV	Medchal	13.25	15.15	01.50		11KV Conductor snapped at SC Colony Shameerpet	No
1	HYD C	ITI Mallepally	Zaheera Masjid	11KV	Mehdipatnam	17.30	19.20	01.50	EL	DTR AB Cable fault at Telengana Residential Hostel	No