

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1	5	1	5	1	5			
	Total	606	3055	1	5	1	5	1	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988		3		3		3			
3	MDK	107	933		3		3		3			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	9	1	9	1	9	0	0	
	Grand Total	1082	6468	2	14	2	14	2	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.10.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Khanapur	11kv	Jadcherla	07.56	10.45	02.49		11KV Line Phase to Phase near Shamgadda thanda	-
2		Midjil	Boinpally	11kv	Jadcherla	08.30	10.20	01.50		AB switch fail near Mallapur Village	-
3		Udityal	Udityal	11kv	Jadcherla	07.10	10.54	03.44		11KV Line Phase to Phase near Veerannapally Village	-
1	NLG	Reddygudem	Kothagudem	11kv	Suryapet	08.40	11.00	02.20	EL	Jumper cut	-
2		Kothagudem	Kothagudem	11kv	Miryalaguda	06.00	09.00	03.00	EL	11Kv Jumpr cut Near Hatagani Thanda	-
3		Mushampally	Muthyalammagudem	11kv	Nalgonda	08.00	10.20	02.20	E/L	11 KV Jumper Cut at Muthyalammagudem (V)	-
1	MDK	Kodur	Minpur	11kv	Jogipet	10.00	12.00	02.00		B/D due to Jumper Cut near Minpur(V)	-
2		Panchagama	Pipree	11kv	Jogipet	06.00	08.00	02.00		B/D due to Conductor Spanned near Pipree(V)	-
3		Nagadhar	Thanda	11kv	Jogipet	08.00	10.00	02.00		B/D due to Jumper Cut near Thanda (V)	-
1	HYD N	Chilalguda	Pragatools	11kv	V	18.00	19.30	01.30	EL	5Way RMU Insulator flash over at Opp. DE/Office	
2	HYD S	Yakuthpura	Somnath Temple	11kv	VIII	01.33	06.10	04.37	EL,OL-Bph	UG Cable fault at Agha PT	
3	HYD C	Golconda	Darga OH	11kv	VII	18.00	19.55	01.55	EL,OL-Yph	Lizard fallen on lines at Jaihind Colony	
4		Golconda	Mothi Mahal	11kv	VII	18.55	20.00	01.05	OL	Bird fault at Aazizia Masjid	
5		Golconda	Company Bagh	11kv	VII	18.58	20.35	01.37	EL,OL-Yph	Insulator flash over at Company Bagh	

TSSPDCL - LMRC / Corporate office

Date: 14.10.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narva	33kv	Narayanapet	09.50	11.25	01.35	E/L	33KV Jumper Cut near at 132KV SS Makthal	Narva	-
1	HYD N	132KV Erragadda	Kundanbagh (Idle)	33kv	Erragadda	01.10	05.20	04.10	EL	Cable fault at Pranahitha Apts, Opened AB Switch at 33KV Green Lands SS	Kundanbagh (Idle)	-