

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 15.10.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Thirumalaipally	Veltoor	33KV	Wanaparthi	21.35	02.35	05.00	E/L	Pin insulator failed	Veltoor	-

TSSPDCL - LMRC / Corporate office

Date: 15.10.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gangapur	Alwanpally	11KV	Rural	13.55	16.00	02.05		11KV Wire Cut near Thangallapally	-
1	NLG	Bopparam	Midthanapally	11KV	Suryapet	05.30	08.15	02.45	E/L	11Kv Conductor snapped	-
2		Dirincherla	Chellepally	11KV	Huzurnagar	07.30	08.40	01.30	E/L	11Kv Conductor snapped	-
3		Kalmalcheruvu	Kalmalcheruvu	11KV	Huzurnagar	17.15	19.20	02.05	E/L	11Kv Conductor snapped	-
4		Ganapuram	G.B.Pally	11KV	Devarakonda	08.00	12.00	04.00	E/L	11Kv Jumper Cut	-
1	SDP	Mushyal	Tharigoppula	11KV	Husnabad	00.00	16.25	16.25		BD due to CT Blasted at 132/33KV SS Mustyala	-
2		Chandlapur	Vitalapur	11KV	Siddipet	16.25	18.03	01.38		Due to HG Fuse wire Blow out in 33kv SS Chandlapur	-