

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		20		20		20			
7	RR(E)	168	403		21		21		21			
8	Hyd	194	1044		36		36		36			
	Total	606	3055	0	77	0	77	0	77	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	6	1	6	1	6	1			
2	NLG	144	988		7		7		7			
3	MDK	107	933	5	1	5	1	5	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	11	9	11	9	11	9	0	0	
	Grand Total	1082	6468	11	86	11	86	11	86	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.10.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220KVSS Palkonda	Bhoothpur	33KV	Mahabubnagar	17.03	19.30	02.27	EL	No visible fault and supply stood OK	Bhoothpur	No
2		220KVSS Palkonda	Janampet	33KV	Narayanapet	17.03	19.30	02.27	EL	No visible fault and supply stood OK	Janampet	No
3		Marikal	Kondapur	33KV	Narayanapet	19.00	20.10	01.10	EL	No visible fault and supply stood OK	Kondapur	No
4		Gadwal	Maldakal	33KV	Gadwal	15:20	18:01	2:41	EL	Tree Branches Removing on the line at Maldakal	Maldakal	No
5		Wanaparthi	Kodair	33KV	Wanaparthi	6:56	17:10	10:14	EL	33KV Pin insulators replaced at Appaipally Thanda	Kodair	No
6		Thirumalaipally	Veltoor	33KV	Wanaparthi	20.08	21.45	01.37	EL	No visible fault and supply stood OK	Veltoor	No
1	MDK	Pashamailaram	BPL	33KV	Sangareddy	5:15	15:30	10:15		Conductor snapped and CT blast	BPL	No
2		Pashamailaram	Nandigama	33KV	Sangareddy	05.15	09.45	04.30		Jumper cut and insulator failed	Nandigama	No
3		Zaheerabad	Machanoor	33KV	Zaheerabad	02.50	10.20	07.30		Conductor snapped	Machanoor	No
4		Zaheerabad	Jharasangam	33KV	Zaheerabad	03.05	06.05	03.00		Jumper cut	Jharasangam	No
5		Zaheerabad	Buchinelly	33KV	Zaheerabad	2:00	11:45	9:45		Jumper cut	Buchinelly	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Gurukunta	11KV	Jadcherla	10.20	12.10	01.50		11KV Disc failed near nawabpet (V)	No
1	NLG	Kethavarigudam	Kethavarigudam	11KV	Huzurnagar	5:00	7:50	2:50	EL	11KV Jumper cut	No
2		Krishapuram	Chithiriyala	11KV	Huzurnagar	06.00	07.00	01.00	EL	11KV Jumper cut	No
3		Kasarabad	Imampeta	11KV	Suryapet	14.15	16.55	02.40	EL	Disc flashover	No
4		Bollepally	Bollepally	11KV	Bhongir	13.45	15.00	01.15	EL	11KV Pin insulator failed	No
5		Chervupally	Dacharam	11KV	Nalgonda	11.05	13.50	02.45	EL	11KV Line jumper cut	No
6		Akaram	Vallala	11KV	Nalgonda	07.25	10.20	02.55	EL	11KV Line insulator failed	No
7		Biravunibanda	Thakalapadu	11KV	Nalgonda	5:35	8:06	2:31	EL	11KV Line insulator failed	No
1	MDK	Bollaram - I	Aurobindo	11KV	Sangareddy	10:15	12:15	2:00		11KV Jumper cut	No
1	RR N	Hudatruckpark	Shivalayam	11KV	Kukatpally	7:28	9:10	1:42	EL/OL,	11kv AB Cable Endkit failed at Kukatpally Police Station	No
2		Vijayanagar	Allwyn colony	11KV	Kukatpally	07.25	09.03	01.38	EL/OL,	Due To Heavy rain	No
3		Hudatruckpark	Shivalayam	11KV	Kukatpally	16.06	17.19	01.13	EL/OL,	11kv Disk Failure at Ramalayam	No
4		Nizampet	Journalist Colony	11KV	Kukatpally	06.40	07.50	01.10	EL/OL,	Due To Heavy rain	No
5		Vijayanagar	Aruna society	11KV	Kukatpally	07.14	08.30	01.16	EL/OL,	11kv Post Insultor Failur at aruna society	No
6		Jeedimetla-II	LV-III, Phase-V	11KV	Jeedimetla	00.01	02.01	02.00	EL	LV-III, UG Cable failed & Replecment at SS ,	No
7		Jeedimetla-II	LV-III, Excil	11KV	Jeedimetla	00.01	02.01	02.00	EL	LV-III, UG Cable failed & Replecment at SS ,	No
8		Jeedimetla-II	LV-III, Reedy labs	11KV	Jeedimetla	00.01	02.01	02.00	EL	LV-III, UG Cable failed & Replecment at SS ,	No
9		Jeedimetla-I	Sudharshan Drugs	11KV	Jeedimetla	07.00	09.30	02.30	OL	DUE to Heavy Rain	No
10		Jeedimetla-I	Thirumala	11KV	Jeedimetla	07.00	09.30	02.30	OL	DUE to Heavy Rain	No
11		Jeedimetla-I	Phase-II	11KV	Jeedimetla	07.00	09.30	02.30	OL	DUE to Heavy Rain	No
12		Jeedimetla-III	Vinayaka	11KV	Jeedimetla	07.30	11.50	04.20	EL/OL	11kv Conductor Snapped & CTBT prolem At WE Safety Glass Company	No
13		Jeedimetla-IV	AA Imatha	11KV	Jeedimetla	06.36	11.15	04.39	EL/OL	11kvDisk Failure& 11kv Pin Insultor At Bhagylaxmi colony	No
14		Jeedimetla-IV	Bhagylaxmi Colony	11KV	Jeedimetla	07.48	10.10	02.22	EL/OL	11kv Pin insultor failure at pipe Line Road	No
15		Jeedimetla-I	Shapurnagar	11KV	Jeedimetla	16.00	17.45	01.45	EL/OL	11kv Endy Kit Failure at kalavathinagar	No
16		Jeedimetla-I	Triumala	11KV	Jeedimetla	16.00	17.45	01.45	EL/OL	DUE to Heavy Rain	No
17		UMCC	Gajularamaram	11KV	Medchal	09.05	09.40	00.35	BD	Tree fallen on the 11KV Line at VSR Complex	No
18		Petbasheerbad	Vaishnavi Enclave	11KV	Medchal	08.45	10.10	01.25	BD	Tree fallen on the 11KV Line at Vaishnavi Enclave	No
19		Petbasheerbad	Balaji Hospital	11KV	Medchal	08.50	09.50	01.00	BD	Tree fallen on the 11KV Line at Bharathi Residency	No
20		Devarayamjal	Kottapet	11KV	Medchal	8:40	10:40	2:00	BD	11KV Pin Insulator & Disc failed at Prabhavathi Seeds	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	NGRI	HMT nagar	11KV	Habsiguda	8:25	9:25	1:00		Tree branches fallen on 11kv line at Street no 4 HMT nagar	No
2		Uppal	Raghavender nagar	11KV	Habsiguda	08.30	09.40	01.10		Soild core insulator fail at Praveen mudiraj house	No
3		Nacharam indore	Mallikarjuna nagar	11KV	Habsiguda	08.15	09.25	01.10		Coconut tree branches fallen on 11kv line at MS industries Chilkanagar	No
4		RGK	Kowkooor	11KV	Sainikpuri	05.35	06.30	00.55		Bird fallen on 11Kv line at Janapriya	No
5		RGK	Barsipet	11KV	Sainikpuri	09.25	09.55	00.30		11Kv Disk failure at Venkusha	No
6		RGK	Nissa	11KV	Sainikpuri	18.15	19.15	01.00		Tree branches fallen on 11Kv line at Nissa	No
7		Kushaiguda	Kamala Nagar	11KV	Sainikpuri	09.00	09.30	00.30		Tree branches fallen on 11Kv line at Telephone Exchange ECIL X Road	No
8		Kushaiguda	Rukminipuri	11KV	Sainikpuri	09.00	09.30	00.30		Post off Insulator failure at Shreya Hospital	No
9		Kushaiguda	Neredmet	11KV	Sainikpuri	11.00	11.35	00.35		11Kv Disk failure at Good Luck Café AS Rao Nagar	No
10		Yapral	Yapral	11KV	Sainikpuri	07.35	08.05	00.30		11Kv HG fuse Insulator failure at Sai Krupa Colony	No
11		Sainikpuri	Kalyan Garden	11KV	Sainikpuri	08.53	09.30	00.37		AB Switch Open at Kalyan Garden	No
12		Sainikpuri	Vijaypuri	11KV	Sainikpuri	08.50	09.50	01.00		Tree fallen on 11Kv line at Ayodhya Nagar	No
13		Cherlapally-II	Navodaya Colony	11KV	Sainikpuri	12.05	12.40	00.35		11Kv Insulator failure at Navodaya Colony Phase-V	No
14		Moula-Ali	Kailasagiri	11KV	Sainikpuri	09.05	09.45	00.40		11Kv Insulator failure	No
15		Moula-Ali	Gayathri Nagar	11KV	Sainikpuri	12.20	13.40	01.20		Polymer Disk failure at Near Sri Homes Appartment Chandha Bagh	No
16		VP Nagar	Officers Colony	11KV	Sainikpuri	08.40	10.20	01.40		Kite touched on 11Kv line at Kakathiya Nagar	No
17		VP Nagar	VV Puram	11KV	Sainikpuri	09.25	10.43	01.18		Tree branches fallen on 11Kv line at Barni Colony	No
18		Vasanthapuri	Durga Nagar Cable	11KV	Sainikpuri	08.43	09.49	01.06		11Kv Disc failure at Gayathri T/F Pevan Colony	No
19		Vasanthapuri	Ganesh Temple	11KV	Sainikpuri	08.51	09.34	00.43		11KV line touched at Ganesh Temple due to two lines twisting	No
20		Vasanthapuri	Ganesh Temple	11KV	Sainikpuri	18.09	18.52	00.43		Tree branches touched on 11Kv line at PVN Colony	No
21		Balaji nagar	Mahankali temple	11KV	Keesara	8:57	9:26	0:29		Tree branches fallen on 11kv line at Sri ram colony	No
1	HYD N	Kalyan Nagar	A.G.Colony	11KV	Jublee Hills	07.32	09.05	01.33	EL,OL-Rph	No Visible Fault	No
2		Osm. University	Mettuguda	11KV	Sec'bad	8:03	9:20	1:17	EL,OL-Bph	Faulty 5No. DTR's at Mettuguda X Road	No
3		Osm. University	RTC Hospital	11KV	Sec'bad	8:10	9:50	1:40	EL	No Visible Fault	No
4		Tirumalagiri	Sri Nagar Colony	11KV	Bowenpally	9:05	11:15	2:10	EL,OL-Yph	Pin Insulator flash over at Sri Nagar Colony	No
5		Gunrock	Tirumalagiri	11KV	Bowenpally	9:05	10:55	1:50	EL,OL-Rph	Pin Insulator flash over at Biryani Dharbar	No
6		Gunrock	Medchal	11KV	Bowenpally	9:05	11:35	2:30	EL	No Visible Fault	No
7		Clock Tower	Anjali	11KV	Sec'bad	9:30	10:57	1:27	EL,OL-R&Yph	No Visible Fault	No
8		Clock Tower	Station Road	11KV	Sec'bad	9:53	12:00	2:07	EL,OL-R&Bph	Cable Fault	Arranged B/F on 11KV Gurudwara fdr
9		N.I.M.S	Banjara Hills	11KV	Jublee Hills	16:15	17:40	1:25	EL	DTR Kept off at Gemini TV	No
10		Film Nagar	Apollo	11KV	Jublee Hills	16:20	17:30	1:10	EL,OL-Rph	No Visible Fault	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Moosarambagh	Moosarambagh	11KV	Asmangadh	08.45	10.30	01.45	EL	No Visible Fault	Arranged B/F on 11KV Shalivahana Nagar fdr
2		Chanchalguda	Islamiya	11KV	Asmangadh	14:50	16:41	1:51	OL-Rph	Cable Fault	Arranged B/F on 11KV Chanchalguda fdr
3		Asmangadh	Gowtham Nagar	11KV	Asmangadh	16:25	17:53	1:28	EL,OL-Yph	2No DTR's Kept off	Arranged B/F on 11KV Thirumala Hills fdr
4		Arundhathi Colony	Arundhathi Colony	11KV	Asmangadh	17:05	19:05	2:00	EL,OL-Rph	Disc Insulator flash over at Grave yard	No
5		Falaknuma	Jangam Mett OH	11KV	Charminar	17:26	19:06	1:40	EL	CT sparking at SS	Arranged B/F on 11KV Sharada College fdr
6		Kanchan Bagh	I.S.Sadan	11KV	Asmangadh	19:45	21:03	1:18	EL,OL-Rph	Insulator flash over at Chares	No
7		Salarjung	Madina	11KV	Charminar	23.40	01.05	01.25	All Indication	8no Jumper cut near Division Office	No
1	HYD C	Mothi Mahal	Company Bagh	11KV	Mehdipatnam	07.01	09.46	02.45	EL,OL-Bph	Disc Insulator flash over at Jangaiah Line AB Switc, Company Bagh	No
2		Golconda	Q.Q.Toombs	11KV	Mehdipatnam	07.10	08.20	01.10	EL	Pin Insulator flash over at Alsala School	No
3		Asif Nagar	Toli Chowki	11KV	Mehdipatnam	07.30	10.42	03.12	EL,OL-Rph	Faulty CT PT & End kit at Leather Factory	No
4		Vittalwadi	APCO	11KV	Azamabad	8:20	9:35	1:15	EL	Tree branches fallen on lines & Jumper cut at Opp. Narayanguda Water Works	No
5		Narayanguda	Chikkadpally	11KV	Azamabad	15:30	17:00	1:30	EL,OL-Rph	Pin Insulator flash over at Aora College	No
6		Asif Nagar	Padmanabha Nagar	11KV	Mehdipatnam	15:36	18:50	3:14	EL	Tree branches fallen on lines at 1st line AB Switch	No
7		Asif Nagar	Military	11KV	Mehdipatnam	15:36	20:12	4:36	EL	No Visible Fault	No
8		Asif Nagar	Hakimpet	11KV	Mehdipatnam	15:37	22:10	6:33	EL	Tree branches fallen on lines at Military Gate, Kendriya Vidyalaya School	No
9		Mothi Mahal	Company Bagh	11KV	Mehdipatnam	15:38	16:43	1:05	EL,OL-Bph	DTR fault at Afzal Colony	No
10		Asif Nagar	Kakatiya Nagar	11KV	Mehdipatnam	15:38	19:30	3:52	All Indication	Coconut Tree branches fallen on lines at Super Market	No
11		Langer House	Military Hospital	11KV	Mehdipatnam	15:40	17:30	1:50	All Indication	Tree branches fallen on lines at Military Area	No
12		Gudimalkapur	Amba Garden	11KV	Mehdipatnam	15:43	16:46	1:03	EL	No Visible Fault	No
13		Asif Nagar	Toli Chowki	11KV	Mehdipatnam	15:43	20:10	4:27	EL	No Visible Fault	No
14		Golconda	Darga OH	11KV	Mehdipatnam	15:45	18:46	3:01	EL	No Visible Fault	Arranged B/F on 11KV O.U.Colony fdr
15		Tolichowki	B.S.N.L	11KV	Mehdipatnam	15:50	20:55	5:05	EL	Big tree branches fallen on lines at BSNL Office	No
16		Golconda	Brindavan Colony	11KV	Mehdipatnam	16:00	20:45	4:45	EL	Tree branches fallen on lines at Koyessar Colony	No
17		Golnaka	Tulasi Nagar	11KV	Azamabad	16:29	17:32	1:03	EL	Tree branches fallen on lines at Royal Residence	No
18		Langer House	Military Hospital	11KV	Mehdipatnam	18:05	20:03	1:58	EL,OL-Rph	Tree branches fallen on lines at Jyothi Nagar	No
19		Toli Chowki	Paramount Hills	11KV	Mehdipatnam	19.50	23.30	03.40	EL,OL-Bph	2no Disc Insulator falsh over at Paramount Hills Gate No. 3 & 4	No