

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	6	1	6	1	6			
2	NLG	144	988		1		1		1			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	8	1	8	1	8	0	0	
	Grand Total	1082	6468	1	16	1	16	1	16	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.10.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Shanthinagar-I	33KV	Gadwal	03.10	04.41	01.31	O/L	Tree Fallen on the Line at Julakal(V)		NO

TSSPDCL - LMRC / Corporate office

Date: 18.10.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Rudraram	11KV	Jadcherla	07.00	08.40	01.40		11KV Jumper cut Near Rudraram(V)	-
2		Annasagr	Annasagr	11KV	Jadcherla	06.00	10.00	04.00		11KV Pole Broken Near Ravulapally	-
3		Annasagr	Town	11KV	Jadcherla	06.00	10.30	04.30		11KV Insulator Damaged Near Tatikonda(V)	-
4		Nawabpet	Nawabpet	11KV	Jadcherla	13.10	14.30	01.20		11KV Jumper cut Near Nawabpet	-
5		Kothamolgara	Kothamolgara	11KV	Jadcherla	09.15	10.10	00.55		Tree Fallen on the Line Near Patha Molgara(V)	-
6		Jadcherla	Alwanpally	11KV	Jadcherla	09.40	12.20	02.40		11KV Jumper Cut Near Jadcherla	-
1	NLG	Palem	Ogodu	11KV	Nalgonda	12.00	15.00	03.00	EL	11KV Line Jumper Cut	-
1	MDK	Collectorate	P.R pally	11KV	Sangareddy	13.50	17.03	03.13		B/D due to DTR failure.	-
1	RR S	MD Pally	MD Pally (V)	11KV	RJNR	08.20	10.40	02.20	B/D	CTPT Failed at Brundavan colony And 11kv Line Snapped at Brundavan colony and pulla reddy T/F	-
1	RR N	Town Medchal	Jyothi Nagar	11KV	Medchal	09.55	11.05	01.10		11KV Disc Failed at Relience Fresh,High Road	-
1	RR E	Yapral	Governement School	11KV	Sainikpuri	23.53	00.55	01.02		11Kv Disk failure at Mahankali Temple (AE/OP/Yapral)	-
2		Aushpaur	Madharam	11KV	Keesara	04.10	07.10	03.00		11KV Disk fail at Madharam village	-
1	HYD N	Gunrock	Tirumalgiri	11KV	Bowenpally	01.50	12.50	11.00	EL,OL-Rph	Pin Insulators flash over at Biryani Darbar & Post type Insulator flash over at Tirumalagiri	At 11.03 hrs Partial loads arranged B/F on 11KV Surya Enclave & Sri Nagar Colony feeders and Remaining partial loads added on 11KV Lal Bazar fdr at 12.50 hrs
1	HYD S	Ch' Baradari	Bilal Nagar	11KV	Charminar	17.25	19.10	01.45	EL,OL-Bph	Snapped HT 2No. Conductors at President Hotel & 2No. Jumpers cut at SS	-
1	HYD C	Erramanzil	I.C.Quarters	11KV	Saifabad	02.05	03.20	01.15	OL	Bird fallen on lines at Erramanzil	-
2		S.D Hospital	Ahmed Nagar OH	11KV	Mehdipatanam	12.30	13.44	01.14	EL	DC Supply failed to Breaker at SS	Arranged B/F on 11KV Police Mess feeder