

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		5		5		5			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	5	2	5	2	5	0	0	
	Grand Total	1082	6468	2	9	2	9	2	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.10.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Alampur	33KV	Shanthinagar-I	12.13	12.40	00.27		Conductor Sanpped and Alternate Supply Taken to 33KV Shanthinagar-II Feeder at 12:40Hrs	Shanthinagar-I	Alternate Supply Taken to 33KV Shanthinagar-II Feeder at 12:40Hrs
1	MDK	Kandi	SRD-Town -1	33KV	Sangareddy	13.30	17.30	04.00		BD due to 2No. Jumpuer cut near 132 kv SS & Laxmi Nagar.	SRD-Town -1	-

TSSPDCL - LMRC / Corporate office

Date: 20.10.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	Gajula malka puram	11KV	Suryapeta	07.25	10.00	02.35	E/L	Insulator flashover	-
2		Urumadla	Elikatte	11KV	Nalgonda	07.00	09.40	02.40	E/L	11KV Line Insulator failure	-
3		Nakrekal	Chandupatla	11KV	Nalgonda	04.00	08.00	04.00	E/L	11KV Line Jumper cut	-
4		Repala	Repala	11KV	Huzurnagar	04.05	07.00	02.55	E/L	11KV Line Jumper cut	-
5		Motakondur	Cholleru Indus	11KV	Bhongiri	07.30	11.30	04.00	E/L	11KV Line Pin Insulator failure	-
1	RR N	Vikas	Reddy Colony	11KV	Kukatpally	12.25	14.15	01.50	EL	11kv line Pin Insulater Failed at 7Hills Restarent BK Enclave	-
2		UMCC	Mini Industry	11KV	Medchal	05.50	07.30	01.40		11KV Pole Damaged at RM Nagar	-
1	HYD S	Miralam	Water Works	11KV	III	18.10	19.50	01.40	All Indication	O/G CT-PT fault at Water Works	-
1	HYD C	A.S.R.Raju Colony	L.I.C Office	11KV	VII	23.25	00.52	01.27	EL,OL-Rph	Cable failed at M.S.School	-