

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	2	1	2	1	2	1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	2	2	2	2	2	0	0	
	Grand Total	1082	6468	2	5	2	5	2	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.10.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Ramannapet	Arror	33KV	Bhongir	13.45	16.05	02.20	EL	33kv disck failed	Arror	-
2		Aitipamula	Kethepally	33KV	Nalgonda	14.04	17.05	03.01	EL	33 KV Jumper Cut	Kethepally	-

TSSPDCL - LMRC / Corporate office

Date: 21.10.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Nagasala	11KV	Mahabubnagar	09.00	11.10	02.10		11KV Insulator fail near Cherlapally	-
1	NLG	Phanigiri	Anantharam	11KV	Suryapet	04.50	07.30	02.40	EL	Disk Flashover & Conductor snapped	-
1	RR E	Moula-Ali	Moula-Ali	11KV	Sainikpuri	14.15	15.10	00.55		Kite Twisting on 11Kv line at Hanuman Nagar (L Insp Venkateshwarlu)	-
1	HYD N	Prashanth Nagar	Andhra Jyothi	11KV	VI	03.05	04.30	01.25	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Shakthipuram feeder
1	HYD S	Khilwath	Khazipura	11KV	III	02.30	04.17	01.47	EL,OL	Cable fault	Arranged B/F on 11KV Lal Darwaza fdr