

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		6		6		6			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	0	9	0	9	0	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.10.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddarevelly	Peddarevelly	11kv	Mahabubnagar	10.55	12.20	01.25		Phase to Phase Near peddarvelly (v)	-
1	NLG	Chityala	Chityala Town	11kv	Nalgonda	14.08	15.10	01.02	E/L	11KV line cut near by Substation Pole no.8	-
2		Nerada	Nerada Express	11kv	Nalgonda	13.30	14.20	00.50	E/L	11KV Insulator failed	-
3		Nandanam	Telephone Exch	11kv	Bhongir	06.05	08.50	02.45	E/L	11kv Line snpped at Nagireedy pally Near (V)	-
4		Palakaveedu	Palakeedu	11kv	Huzurnagar	03.15	05.45	02.30	E/L	11Kv Jumper cut	-
5		Mukundapuram	Somaram	11kv	Huzurnagar	15.00	18.00	03.00	E/L	11Kv Jumper cut	-
6		Raghunadapalem	Raghunadapalem	11kv	Huzurnagar	00.30	03.30	03.00	E/L	11Kv Jumper cut	-
1	MDK	Jackwell	Bobbiligama	11kv	Sangareddy	14.30	18.00	03.30		B/D due to Single phase DTR Failed	-
1	RR S	Gaganpahad	NPA(GPHD)	11KV	RJNR	14.50	16.45	01.55	B/D	11kv insulator Failed at Gaganpahad Village	-

TSSPDCL - LMRC / Corporate office

Date: 22.10.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RR S				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD N				NIL							-
8	HYD S				NIL							-
9	HYD C				NIL							-