

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	1	0	1	0	1	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	3	1	3	1	3			
3	MDK	107	933	3	2	3	2	3	2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	5	4	5	4	5	0	0	
	Grand Total	1082	6468	5	5	5	5	5	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.10.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	S R Palem	11KV	Suryapet	16:00	17:00	1:00	E/L	11Kv Insulator falshover	No
2		Mushampally	Muthyalammagude	11KV	Nalgonda	08.10	10.00	01.50	E/L	11Kv Line Insulator Fialure	No
3		Arjalabavi	Arjalabavi	11KV	Nalgonda	15.00	17.00	02.00	E/L	11KV Line Jumper Cut	No
1	MDK	Alamaipet	Alamaipet	11KV	Jogipet	1:00	4:20	3:20		Jumper cut	No
2		Thornal	Morgi	11KV	Jogipet	07.12	07.12	03.00		Conductor snapped	No

TSSPDCL - LMRC / Corporate office

Date: 24.10.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Aitipamula	Aitipamula	33KV	Nalgodna	15:10	18:50	3:40	E/L	33KV Line jumper cut	Aitipamula	No
1	MDK	Kandi	IIT	33KV	Sangareddy	23:20 (23.10.18)	6:00 (24.10.18)	6:40		Insulators failed	IIT	No
2		Jogipet	Dakur	33KV	Jogipet	03.30	05.30	02.00		Insulators failed	Dakur	No
3		Narayankhed	Sirgapur	33KV	Jogipet	04.00	06.00	02.00		Lightening arrestor failed	Sirgapur	No
1	HYD N	132KV Patigadda	James Street	33KV	Nehru Nagar	05.45	06.00	00.15	OL	Cable fault	James Street	Loads transferred onto 132KV Gunrock SS via 33KV Hakimpet SS