

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	1	1	1	1	1	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	3	1	3	1	3	0	0	
	Grand Total	1082	6468	2	4	2	4	2	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 31.10.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Alampur X Road	33KV	Gadwal	12.40	14.46	02.06	E/L	Breaker Problem	Alampur X Road	Alternate Supply arranged from 33KV Undavelly feeder at 14:46Hrs
1	RR N	Chintal	Subhash Nagar	33KV	MDCL	00.15	00.35	00.20		UG Cable damaged by Main Road, Infront of HMT SS (backfeeding to 33KV Petbasheerbad)	Subhash Nagar	-

TSSPDCL - LMRC / Corporate office

Date: 31.10.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kollur	Kollur	11KV	Jadcherla	14.30	16.40	02.10		DTR Problem at Kollur(Vi)	-
1	NLG	Akaram	Akaram	11KV	Nalgonda	05.40	07.20	01.40	E/L	11KV Jumper cut	-
2		Thipparthi	Marriguda AGL	11KV	Nalgonda	11.15	13.30	02.15	E/L	11KV Jumper cut	-
1	RR N	Kompally	Kompally	11KV	MDCL	19.40	20.20	00.40		11KV Jumper opened at Raja Rajeshwari Fuction Hall (AB Cable failed)	-