

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | 1 | | 1 | | 1 | | | |
| 6 | RR(N) | 54 | 550 | | | | | | | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 4 | | 4 | | 4 | | | |
| | Total | 606 | 3055 | 0 | 5 | 0 | 5 | 0 | 5 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 2 | | 2 | | 2 | | | | |
| 2 | NLG | 144 | 988 | | 7 | | 7 | | 7 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 2 | 7 | 2 | 7 | 2 | 7 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 2 | 12 | 2 | 12 | 2 | 12 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 01.09.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|-----------------------------------|-----------------------|--|
| 1 | MBNR | Mahabubnagar | Jadcherla | 33KV | Jadcherla | 19.24 | 19.50 | 00.26 | O/L | Clothes Fallen on the Line | Jadcherla | Alternate Supply Arranged From 132KV SS Polepally at 19:50Hrs. |
| 2 | | leeza | Maddelabanda | 33KV | Gadwal | 00.06 | 01.54 | 01.48 | E/L | Insulator Damaged Near Nagardoddy | Maddelabanda | AB Switch Opened at Nagardoddy at 1:48Hrs |

TSSPDCL - LMRC / Corporate office

Date: 01.09.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---|
| 1 | NLG | Ravulapally | Ravulapally | 11KV | Suryapet | 07.15 | 10.00 | 02.45 | E/L | Jumper cut | - |
| 2 | | Mattampally | Pedaveedu | 11KV | Huzurnagar | 03.00 | 06.15 | 03.15 | EL | Due to Insulator failure | - |
| 3 | | Amaravaram | Srinivasapuram | 11KV | Huzurnagar | 02.10 | 05.10 | 03.00 | EL | Due to 11Kv line snapped | - |
| 4 | | Dirsincherla | Somaram | 11KV | Huzurnagar | 17.45 | 20.30 | 02.45 | EL | Due to 11Kv line cutted | - |
| 5 | | Thoragal | Madaram | 11KV | Nalgonda | 07.30 | 11.20 | 03.50 | E/L | 11KV Jumper cut | - |
| 6 | | Chandampeta | G.Polepally | 11KV | Devarakonda | 03.00 | 11.40 | 08.40 | E/L | Due to Insulator failure | - |
| 7 | | K.M.pally | Palvai | 11KV | Devarakonda | 12.10 | 15.45 | 03.35 | E/L | Jumper Cut | - |
| 1 | RR S | Lanco Hills | Khajaguda | 11KV | GCB | 03.17 | 04.49 | 01.32 | | 11KV Pole Damaged near Bhavani School. | - |
| 1 | HYD N | Bowenpally | Ferozguda | 11KV | VI | 00.20 | 02.15 | 01.55 | EL | Cable Jumper damaged at Rly Track | - |
| 1 | HYD S | Miralam | Ranjan Colony | 11KV | III | 01.40 | 02.45 | 01.05 | EL,OL-R&Bph | No Visible Fault | Arranged B/F on 11KV Satherbagh fdr |
| 2 | | Falaknuma | Vattapally | 11KV | III | 16.55 | 18.05 | 01.10 | EL,OL-Rph | Insulator faish over at Nice Hotel | - |
| 1 | HYD C | Golconda | Narayanamma College | 11KV | VII | 17.16 | 19.12 | 01.56 | EL | I/C Cable fault | Partial loads added on 11KV Brindhavan Colony fdr |