

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	0	14	0	14	0	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Rajapeta	Renukunta	11KV	Bhongiri	14.00	16.30	02.30	E/L	11KV Line Snapped	-
2		Mattampally	Pedaveedu	11KV	Huzurnagar	03.10	06.00	02.50	E/L	11KV Insulator failure	-
3		Kanagal	Kanagal AGL	11KV	Nalgonda	05.00	09.00	04.00	E/L	11KV Insulator failure	-
4		Aregudem	Chinakaparthi	11KV	Nalgonda	09.30	12.30	03.00	E/L	11KV Line cut	-
5		Indugula	Malaparaju gudem	11KV	Nalgonda	05.00	09.00	04.00	E/L	11KV Line disk failure	-
6		K.M.Pally	Palavai	11KV	Devarakonda	12.10	15.10	03.00	E/L	Jumper cut	-
1	RR S	Upparpally	Parmareddy hills	11KV	RJNR	13.10	15.18	02.08	B/D	Kites fallen on 11KV line at Jalalabanagar, LAB Switch Sparking cut at Forest Office	-
2		Ibrahimbagh	Osmansagar	11KV	IBGH	15.00	17.13	02.13	B/D	11KV Insulator failed at Manchirevula	-
1	RR E	Moula-Ali	Mirzalaguda	11KV	Sainikpuri	17.10	18.20	01.10		11Kv Disk failure at near SS	-
2		Chengicherla	RTC	11KV	Keesara	00.10	02.10	02.00		11KV Polymer Disc failed at Kamela Main Road	-
1	HYD S	Kandikal Gate	Rakshapuram	11KV	III	15.20	16.32	01.12	EL,OL	Twisted Lines at Shivalayam	-----
2	HYD C	Mothi Mahal	Saleh Nagar	11KV	VII	15.06	17.03	01.57	EL,OL-Yph	HT Jumper cut & Fault DTR at Dhankota	-----
3		Nizam College	Little Flower	11KV	I	15.25	16.48	01.23	EL,OL	Pin Insulator flash over at Krishna Veni School Lane	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
4		Jawahar Nagar	Anjaiah Bhavan	11KV	I	17.20	18.30	01.10	EL	Cable fault at Sahara Bakery	Arranged B/F on 11KV Jawahar Nagar fdr

TSSPDCL - LMRC / Corporate office

Date: 02.09.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBN				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	SDPT				NIL							-
5	RR S				NIL							-
6	RR N				NIL							-
7	RR E				NIL							-
8	HYD				NIL							-