

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	1	0	1	0	1	0	0	
	Grand Total	1082	6468	0	6	0	6	0	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Aitipamula	Gangadevigudem	11KV	Nalgonda	11.20	13.45	02.25	EL	11 KV Line Cutting	-
1	RR N	Jeedimetla -II	Excel	11KV	Jeedimetla	09.28	10.50	01.22	EL/OL	11kv Endy Kit failure At Phase-II	-
2		Suraram	Matrix	11KV	Jeedimetla	00.01	03.15	03.14	EL/OL	11kv Jumper open Opp Matrix Company	-
3		Aleap	Aleap	11KV	Jeedimetla	04.00	05.30	01.30	EL/OL	11kv aleap feeder LV Jumper Cut IN sub station	-
1	HYD C	Fever Hospital	C.C.S Hospital	11KV	Azamabad	05.10	06.50	01.40	EL,OL-Bph	I/C Cable fault at Fever Hospital	Arranged B/F on 11KV YMCA feeder
2		Narayanguda	Chikkadpally	11KV	Azamabad	10.47	11.50	01.03	EL,OL-Rph	Flexy fallen on lines at Venkateswara Temple	-