

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		4		4		4			
6	RR(N)	54	550		7		7		7			
7	RR(E)	168	403		9		9		9			
8	Hyd	194	1044		26		26		26			
	Total	606	3055	0	46	0	46	0	46	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	0	54	0	54	0	54	0	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Gundepuri	Pasthala	11KV	Suryapet	7:20	10:00	2:40	E/L	Disc failed	No
2		Dirincherla	Town-1	11KV	Huzurnagar	17.22	18.45	01.28	EI	Disc failed	No
3		Dirincherla	Somaram	11KV	Huzurnagar	19.00	21.20	02.20	EL	Conductor snapped	No
4		Biravunibanda	M.G.Kothapally	11KV	Nalgonda	09.30	11.30	02.00	E/L	11KV Line Cut	No
5		Arlagaddagudem	Thatikal	11KV	Nalgonda	07.30	09.40	02.10	E/L	11 KV Jumper Cut	No
6		Marriguda	Vattipally	11KV	Devarakonda	13.00	15.10	02.10	E/L	Jumper Cut	No
7		Peddathanda	Peddathanda	11KV	Bhongir	06.00	10.00	04.00	EI	Insulator failed	No
8		Kondamadugu	Nemeragomla	11KV	Bhongir	7:00	11:30	4:30	EI	Insulator failed	No
1	RR S	Gachibowli	Sudharshan Nagar	11KV	Gachibowli	17:46	19:10	1:24		Flexy fallen on the 11kv line at Navayuga Opposite, Sudharshan Nagar	No
2		Gachibowli	Gopanpally	11KV	Gachibowli	17.45	20.00	02.15		Fiber cable fallen on the 11kv line at Citizen Hospital, Gopanpally	No
3		KPHB	Dharmareddy Colony	11KV	Kondapur	19.30	20.30	01.00		11kv Disc failed at Ramalayam Temple, KPHB Colony	No
4		Upparpally	Fortview colony	11KV	Rajendranagar	16.46	17.57	01.11		11KV Insulator failed and Flexy fallen on 11KV line at Fort view colony	No
1	RR N	Vijayanagar Colony	Aruna Society	11KV	Kukatpally	18:25	19:45	1:20		Disc insulator failed at Vijalaxmi Apartment	No
2		Mayurinagar	KTR Colony	11KV	Kukatpally	18.20	19.30	01.10		Tree branches fallen on the 11kv Line near Sulochan Tower	No
3		DP pally	Gandimaisamma	11KV	Jeedimetla	18.00	19.30	01.30		11kv line cut with Hevy wind and rain	No
4		Aleap	Doctors Colony	11KV	Jeedimetla	18.30	20.20	01.50		Tree branches fallen on the 11kv line	No
5		Jeedimetla -V	Hetro	11KV	Jeedimetla	00.05	01.30	01.25		11kv Endy Kit failed at Simlax Company	No
6		Shameerpet	Devarayamjal	11KV	Medchal	07.10	10.00	02.50		11KV Disc failed at Devarayamjal Village	No
7		Medicity	IDA-I	11KV	Medchal	3:00	4:20	1:20		11KV Disc failed at Harshath Poultry Farm, Rajabollaram	No
1	RR E	Boduppall	Hema nagar	11KV	HBG	17:05	17:40	0:35		Tripped on EL & disc failed at hema nagar road no 10	No
2		Mallapur2	Narshima nagar	11KV	HBG	18.00	18.45	00.45		11kv Disc failed at MS Biriyni point	No
3		Yapral	Kowkooor	11KV	SKP	07.20	08.05	00.45		Bird fallen on 11Kv line at Registration Colony	No
4		Kushaiguda	Kushaiguda	11KV	SKP	07.20	08.00	00.40		11Kv Disc failed at Chaina Bazar	No
5		Yapral	Yapral	11KV	SKP	18.05	18.50	00.45		Tree branches fallen on 11Kv line at Saikrupa Colony	No
6		Peerzathiguda	Shankar nagar	11KV	Keesara	03.25	05.45	02.20		11kv Disc failed at Ganesh nagar	No
7		Keesara	Ankireddypally	11KV	Keesara	04.25	05.40	01.15		Tree branches fallen on 11kv line	No
8		Chengicherla	RTC	11KV	Keesara	15.55	16.55	01.00		Pin insulator failed	No
9		Aushapur	Aushapur	11KV	Keesara	2:10	6:50	4:40		11kv Disc failed at Aushapur village	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Road No.12	Kanaka Durga	11KV	Jublihills	16.45	18.10	01.25	EL,OL	No Visible Fault (Heavy wind and Gale)	No
2		Road No.12	C.R.P.F	11KV	Jublihills	16:46	18:14	1:28	EL,OL	No Visible Fault (Heavy wind and Gale)	No
3		M.L.A Colony	Shopping Complex	11KV	Jublihills	16:55	18:00	1:05	All Indication	No Visible Fault (Heavy wind and Gale)	No
4		Film Nagar	M.L.A Colony	11KV	Jublihills	17:10	19:40	2:30	EL,OL-Bph	Tree branches fallen on lines at Darga	No
5		Chinna Thokatta	Old Bowenpally	11KV	Bowenpally	17.15	18.25	01.10	EL,OL-Bph	No Visible Fault (Heavy wind and Gale)	No
6		Addagutta	Tagoure Home	11KV	Sec'bad	17.30	18.55	01.25	EL,OL-Rph	Conductor snapped & Disc flash over at Kumar Driving School	No
7		R.P.Nilayam	Nagadevatha	11KV	Bowenpally	18:05	20:10	2:05	EL	No Visible Fault (Heavy wind and Gale)	No
8		Tirumalagiri	Satya Sai	11KV	Bowenpally	19:58	21:25	1:27	All Indication	DTR fault at Satya Sai Envlave	No
9		Bora Banda	Kalyan Nagar Park	11KV	Erragadda	18:10	21:52	3:42	EL,OL	Cable fault at Kalyan Nagar Park	Arranged B/F on 11KV Saradhi Nagar fdr
1	HYD S	Miralam	Zoo Park	11KV	Charminar	17.05	19.20	02.15	EL,OL-Rph	HT Line snapped at Tadbun X Road	No
2		Falaknuma	Jangam Mett AB Cable	11KV	Charminar	17.25	18.55	01.30	All Indication	Tree branches fallen on lines at Andhra Bank	No
3		E.N.T	C.B.I	11KV	Begumbazar	18.07	19.35	01.28	All Indication	Canara bank HT Service faulty	No
4		Womens College	Quthbiguda	11KV	Begumbazar	17:20	20:30	3:10	EL,OL	No Visible Fault	Arranged B/F on 11KV Kendriya Sadan fdr & 11KV ENT fdr
5		Womens College	Ganesh Temple	11KV	Begumbazar	17.38	20.35	02.57	EL,OL	No Visible Fault	Arranged B/F on 11KV Prabath fdr
1	HYD C	Mothi Mahal	Balancer	11KV	Mehdipatnam	16.56	18.30	01.34	EL,OL	Faulty 11KV Fathe Darwaja fdr loads	No
2		S.D.Hospital	Ahmed Nagar OH	11KV	Mehdipatnam	16:38	18:44	2:06	OL-Rph	Tree branches fallen on lines at J' Hills School	No
3		Alluri Seetha Rama RL.I.C		11KV	Mehdipatnam	16:45	19:20	2:35	EL,OL-Rph	Disc failed at Ravi Teja Apts	No
4		Tolichowki	B.S.N.L	11KV	Mehdipatnam	16:48	18:40	1:52	EL,OL-Rph	Tree branches fallen on lines at BSNL Office	No
5		I.T.I Mallepally	Anwar Uloom College	11KV	Mehdipatnam	16.56	19.15	02.19	EL,OL-Rph	Pin Insulator flash over at Badi Masjid	No
6		A.C.Gaurds	Mahaveer UG Cable	11KV	Mehdipatnam	17.03	18.33	01.30	EL	Rat fallen in RMU at Singareni Bhavan	No
7		Zamistanpur	Jamai Osmania	11KV	Azamabad	17.14	18.24	01.10	OL-R&Yph	Tree branches fallen on lines at Shivalayam	No
8		Fever Hospital	Barkathpura Bus Depo	11KV	Azamabad	17.54	19.50	01.56	EL,OL-Rph	Pin Insulator flash over at Kachiguda Jr.College	No
9		Mothi Mahal	Saleh Nagar	11KV	Mehdipatnam	19.58	21.25	01.27	All Indication	Tree branches on lines & twisted lines at Dhankota	No
10		Tolichowki	Paramount Hills	11KV	Mehdipatnam	16:50	21:57	1:59	EL,OL-Rph	Pin Insulator flash over at More Super Market	At 03:40 hrs. Partial feeder charged
11		Tolichowki	Paramount Hills	11KV	Mehdipatnam	22:55	0:05	1:10	EL	No Visible Fault	No
12		S.D.Hospital	S.D.Hospital	11KV	Mehdipatnam	21:46	2:46	5:00		RMU Cable fault at Military Area	No