

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044	1	9	1	9	1	9			
	Total	606	3055	1	19	1	19	1	19	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4	5	4	5	4	5			
2	NLG	144	988		3		3		3			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	10	4	10	4	10	0	0	
	Grand Total	1082	6468	5	29	5	29	5	29	0	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Tirumalapur	Dondlapally	11KV	Jadcherla	08.05	10.15	02.10		11 KV Jumper Cut Near Dondlapally (V)	No
2		Addakal	Gudibanda	11KV	Jadcherla	12.15	14.06	01.51		11 KV Disc Failure Near Gudibanda (V)	No
3		Janampet	Annasagar	11KV	Jadcherla	02.00	09.30	07.30		11 KV Insulator Failure Near Gajulapet (V)	No
4		Rajapur	Salgutti	11KV	Jadcherla	2:50	11:00	8:10		CT/PT Failure near Lotus Company.	No
5		Rajapur	Mallepally	11KV	Jadcherla	03.10	12.20	09.10		11 KV Disc failure Near Rajapur (V)	No
1	NLG	Mattampally	Mattampally Town	11KV	Huzurnagar	11:20	13:45	2:25	E/L	11KV Insulator failed	No
2		Raghunadapalem	Gundlapally	11KV	Huzurnagar	05.30	08.30	03.00	E/L	11KV Disc failed	No
3		Mellacheruvu	V.R.Puram	11KV	Huzurnagar	14.20	15.20	01.00	E/L	Bird fallen on the 11KV line	No
1	MDK	Patancheru Town	Allwyn	11KV	Patancheru	5:20	7:30	2:10		Insulator failed	No
2		Patancheru Town	Shanthinagar	11KV	Patancheru	05.50	06.55	01.05		Jumper Cut	No
1	RR S	Rajendranagar	Sulemannagar	11KV	Rajendranagar	17:00	18:15	1:15		Bird fallen on the 11KV line at Suleman nagar	No
2		Gachibowli	Gopanpally	11KV	Gachibowli	06.10	07.20	01.10		No visible fault	No
1	RR N	Dp pally	Gandi Mai samma	11KV	Jeedimetla	18:30	19:30	1:00	EL	11kv Conductor Snapped At Gandi maisamma	No
2		Gowdawelly	Basaragadi	11KV	Medchal	08.00	09.30	01.30		11KV Pin Insulator failed at Basaragadi Village	No
1	RR E	Nacharam	Multisteel	11KV	Habsiguda	8:12	8:50	0:38		11KV Pin Insulator failed near Dart Company at IDA Nacharam	No
2		Moula-Ali	Venkateshwara Nagar	11KV	Sainikpuri	00.47	01.55	01.08		Polymer Disk failure at Phase-II	No
3		Moula-Ali	Malkajiri	11KV	Sainikpuri	18.45	20.00	01.15		CT Blast at SS Yard	No
4		Cherelapally-IV	BN Reddy Nagar	11KV	Sainikpuri	09.05	09.40	00.35		11Kv line Patrolling Done But no fault found	No
5		Ghatkesar	Ghatkesar	11KV	Keesara	09.40	10.35	00.55		Tree branches fallen on 11kv line at Ghatkesar Main Road	No
6		P&T Colony	Medipally	11KV	Keesara	18:40	19:30	0:50		Lizard fallen on 11kv line at kranthi Colony	No
1	HYD S	Ch' Baradari	Fire Station	11KV	Charminar	09.25	11.25	02.00	OL-Rph	Tree branches fallen on lines at Ch' Baradari	Arranged B/F on 11KV Ch'Baradari fdr
1	HYD C	Jawahar Nagar	Post Office	11KV	Saifabad	01.30	02.55	01.25	EL	Faulty DTR at Jawahar Nagar	No
2		Asif Nagar	Jyothi Nagar	11KV	Mehdipatnam	4:30	6:55	2:25	EL,OL-Rph	Conductor snapped & Tree branches fallen on lines at Jyothi Nagar Clny	Arranged B/F on 11KV Military Hospital fdr
3		Asif Nagar	Kakatiya Nagar	11KV	Mehdipatnam	6:45	9:05	2:20	EL	Tree branches fallen on lines at Kakatiya Nagar	No
4		Nampally	Bada Masjid	11KV	Mehdipatnam	7:42	8:50	1:08	EL	AB Cable fault at Opp. Qutubshah Apts	No
5		Golnaka	Sai Madhura Nagar	11KV	Azamabad	07.44	08.54	01.10	OL	Tree branches fallen on lines at Sai Madhura Nagar	No
6		Fever Hospital	Kachiguda Railway Station	11KV	Azamabad	07.58	09.10	01.12	EL,OL	CT PT Fault at Railway Station	No
7		Fever Hospital	Tourist Hotel	11KV	Azamabad	07.58	13.54	05.56	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Moulana Azad Nagar fdr
8		Durga Nagar	Chenna Reddy Nagar	11KV	Azamabad	16.02	17.25	01.23	EL	Bird fault at old Saraswathi School	No

TSSPDCL - LMRC / Corporate office

Date: 12.09.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	G R Cable	33KV	Jadcherla	05.42	06.42	01.00	EL	No visible fault	G R Cable	No
2		Makthal	Jaklair	33KV	Narayanapet	01.20	01.50	00.30	EL	No visible fault	Jaklair	No
3		Gadwal	RWS	33KV	Gadwal	02.45	03.07	00.22	EL	Insulator failed	RWS	Loads Diverted to 33KV Nandinne Feeder
4		Wanaparthly	Chinnamaroor	33KV	Wanaparthly	7:15	7:35	0:20	EL	Jumper cut	Chinnamaroor	Alternate Supply Arranged From 132KV SS Chinnamaroor at 7:20Hrs.
1	HYD C	132KV Asif Nagar	Asif Nagar	33KV	Asif Ngr	04.20	05.50	01.30	EL	Bus Jumper cut at 33KV Asif Nagar SS	Asif Nagar	Loads transferred onto 132KV Asif Nagar SS via 33KV Karwan fdr