

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044									
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	0	13	0	13	0	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Chamapoor	Singaram	11KV	Bhongiri	05.00	08.30	03.30	E/L	11KV Insulator failure	-
2		Ramannapeta	Komaiguda	11KV	Choutupal	12.40	16.40	04.00	E/L	11KV Line Snapped	-
3		Eduloor	Kuramarthy	11KV	Nalgonda	14.40	16.20	01.40	E/L	11KV Jumper cut	-
4		Madgulapally	Kukkadam	11KV	Nalgonda	07.00	10.30	03.30	E/L	11KV Insulator failure	-
1	SDP	Gouravelli	Gudatipally	11KV	Siddipet	11.10	12.05	00.55		HT/LT	-
2		Regulapally	Regulapally	11KV	Siddipet	15.02	15.36	00.34		Jumper cutting	-
1	RR S	Chandanagar	Engineer's Enclave	11KV	GCB	15.05	16.10	01.05	BD	11KV Pin Insulator Failed and LT Line Snapped at Om Shanthi Apartment's.	-
1	RR N	Suraram	Matrix	11KV	Jeedimetla	12.02	13.45	01.43	OL	UG Cable Damaged at near SS	-
2		Subhash nagar	Praghatools Colony	11KV	Medchal	04.40	05.30	00.50	BD	11KV Jumper cut and replaced at Jeedimetla	-
3		Medicity	Rajabollaram	11KV	Medchal	16.30	17.00	00.30	BD	11KV Line cut and replaced at Medicity Road	-
1	RR E	IDA Uppal	Jersey	11KV	HBG	19.33	20.55	01.22		100KVA DTR Insulator failed at Venkata Sai Entreprises	-
2		Nagaram	Bandlaguda	11KV	Keesar	13.23	13.59	00.36		Bird fallen on 11kv line at Sathya Narayana colony	-
3		Narapally	Parvathapur	11KV	Keesar	20.20	22.20	02.00		Tree branches Fallen on 11KV Line near CPRI	-